

---

**Pacific Northwest  
National Laboratory**

Operated by Battelle for the  
U.S. Department of Energy

**DOE Advanced Controls R&D  
Planning Workshop, June 11, 2003,  
Washington DC: Workshop Results**

MR Brambley  
P Haves  
SC McDonald  
P Torcellini

D Hansen  
DR Holmberg  
KW Roth

April 2005

Prepared for the U.S. Department of Energy  
under Contract DE-AC05-76RL01830



**DOE Advanced Controls R&D  
Planning Workshop, June 11, 2003,  
Washington DC:  
Workshop Results**

MR Brambley  
P Haves  
SC McDonald  
P Torcellini

D Hansen  
DR Holmberg  
KW Roth

April 2005

Prepared for the U.S. Department of Energy  
under Contract DE-AC05-76RL01830

## DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor Battelle Memorial Institute, nor any of their employees, makes **any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights.** Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof, or Battelle Memorial Institute. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

PACIFIC NORTHWEST NATIONAL LABORATORY

*operated by*

BATTELLE

*for the*

UNITED STATES DEPARTMENT OF ENERGY

*under Contract DE-AC05-76RL01830*

**Printed in the United States of America**

**Available to DOE and DOE contractors from the  
Office of Scientific and Technical Information,  
P.O. Box 62, Oak Ridge, TN 37831-0062;**

**ph: (865) 576-8401**

**fax: (865) 576-5728**

**email: reports@adonis.osti.gov**

**Available to the public from the National Technical Information Service,  
U.S. Department of Commerce, 5285 Port Royal Rd., Springfield, VA 22161**

**ph: (800) 553-6847**

**fax: (703) 605-6900**

**email: orders@ntis.fedworld.gov**

**online ordering: <http://www.ntis.gov/ordering.htm>**



This document was printed on recycled paper.

9/2003

**DOE Advanced Controls R&D Planning Workshop,  
June 11, 2003, Washington DC:  
Workshop Results**

MR Brambley<sup>(a)</sup>  
P Haves<sup>(c)</sup>  
SC McDonald<sup>(a)</sup>  
P Torcellini<sup>(e)</sup>

D Hansen<sup>(b)</sup>  
DR Holmberg<sup>(d)</sup>  
KW Roth<sup>(f)</sup>

April 2005

Prepared for  
the U.S. Department of Energy  
under Contract DE-AC05-76RL01830

Pacific Northwest National Laboratory  
Richland, Washington 99352

- 
- <sup>(a)</sup> Pacific Northwest National Laboratory
  - <sup>(b)</sup> U.S. Department of Energy
  - <sup>(c)</sup> Lawrence Berkeley National Laboratory
  - <sup>(d)</sup> National Institute of Science and Technology
  - <sup>(e)</sup> National Renewable Energy Laboratory
  - <sup>(f)</sup> TIAX, LLC



## PREFACE

The Building Technologies Program (BT) is one of 11 programs within the Office of Energy Efficiency and Renewable Energy (EE) at the U.S. Department of Energy (DOE). The mission of the Building Technologies Program is to develop technologies, techniques and tools for making residential and commercial buildings more energy efficient, productive, and affordable. The Building Technologies Program's goal is to develop cost effective tools, techniques and integrated technologies, systems and designs for buildings that generate and use energy so efficiently that buildings are capable of generating as much energy as they consume. One sub-program within BT is Commercial Building Integration. The Commercial Buildings Integration subprogram addresses energy saving opportunities in new and existing commercial buildings. This includes research, development, and demonstration of whole building technologies, design methods, and operational practices. Technology development efforts focus on cross-cutting, whole building technologies such as sensors and controls and more energy-efficient ventilation systems. This also includes efforts to improve commercial building energy codes and standards. These efforts support the net Zero Energy Buildings goal not only by reducing building energy needs, but also by developing design methods and operating strategies that seamlessly incorporate solar and other renewable technologies into commercial buildings.

The Commercial Building Integration sub-program is in the process of developing a five-year research and development plan for advanced control technologies for building applications. The goal of the planning process is to identify opportunities for targeted R&D that will result in significantly increased use of control technologies with a goal of saving energy. As a first step toward the development of a plan, DOE prepared background material to:

- Assess the current market and technical potential
- Analyze current and potential applications
- Investigate potential improvements to sensors and controls
- Identify efforts required in networks including standards and protocols
- Examine enhancements to applications of strategies such as commissioning, performance monitoring, and diagnostics.

The second step was to seek outside review and input into the planning process from technical and market experts from universities, other government agencies, and the private sector. These experts were invited to a one-day workshop in Washington, DC, on June 11, 2003. The workshop participants were given the opportunity to review the background planning material, listen to summary presentations of the results, and provide comments on the findings. The workshop participants also participated in breakout sessions where R&D opportunities were prioritized and refined.

The final step in the process is for DOE to use the input gathered during this planning process to develop a formal five-year plan. DOE will need to select from among the R&D opportunities

based on internally developed criteria. In some cases, additional analysis may be required to define the resource requirements as well as the prospective market impacts of suggested R&D pathways. DOE will continue to seek comment and input from outside parties as it works to refine this plan.

## SUMMARY

On June 11, 2003, representatives from universities, federal, and state government agencies, U.S. Department of Energy (DOE) national laboratories, and the private sector attended a one-day workshop in Washington, DC. The objective of the workshop was to obtain review and input of DOE's assessment of the market for advanced controls technology and potential R&D pathways to enhance the success of advanced controls in the buildings market place. Attendees were provided with a draft synthesis paper summarizing the market assessment and potential R&D pathways.<sup>1</sup> This background material was developed with the help of several DOE national laboratories, the National Institute of Standards and Technology, and private-sector consultants.

The workshop consisted of two sessions. During the morning session, participants were given an overview on each topic area in the synthesis paper (e.g., market analysis). This included an opportunity for comments and questions by participants. Some of the key observations were as follows:

- Market Assessment
  - Building control systems are often not purchased for their potential energy savings, but rather for reducing maintenance and other reasons.
  - Several existing controls approaches have the technical potential to reduce U.S. commercial building energy consumption by at least one quad per year.
  - Control systems are one of the last items considered during the design and construction process, which leads to lower-cost controls implementations.
  - In the predominant construction paradigms, contractors tend to re-use structural elements from building to building (with some site-related variation) and design work is often formula and rule-of-thumb driven. This works against the use of advanced controls approaches.
  - Building owners typically pay little attention to energy expenditures and savings potential because building energy expenses account for a diminutive fraction of total building economic activity (e.g., ~1% of total office expenses).
  - Operators have a difficult time understanding current systems, let alone advanced systems.
  - Currently, most advanced controls approaches have a very small market share.
  - The ability of building controls to provide non-energy benefits to building owners and occupants holds the key to greater future market penetration and national energy

---

<sup>1</sup> "Advanced Sensors and Controls for Building Applications: Market Assessment and Potential R&D Pathways," Synthesis Report, DRAFT, June 2003 (formerly titled Advanced Sensors and Controls R&D Plan for Building Applications).



savings. Building controls that improve indoor environmental quality (IEQ) can greatly improve their value to the building occupants, primarily by increasing the economic activity in the building, e.g., office worker productivity or retail sales. For instance, roughly a 2% increase in the productivity of office building occupants has the same economic impact as eliminating *all* building operations and energy expenditures – employee salaries simply account for a much, much larger portion of total building expenses. The market potential might be greater if R&D results in systems that are cheaper, easier to use, or have the functionality that consumers want (the current market assessment only deals with current technology).

- Current Applications and Strategies for New Applications
  - New functionality (e.g., demand response) increases market potential, but also adds complexity which may ultimately limit the market for these products.
  - DOE should develop a succinct vision of what control strategies could mean for building operation (e.g., disaster mitigation) rather than defining control strategies as a response to current needs.
- Sensors and Controls
  - While it is possible to develop sensors for a host of applications (e.g., mold detection, VOCs, CO<sup>2</sup>), the market for these types of sensors may not develop. The ability to monitor these contaminants implies a requirement to respond and may carry liability that building owners and operators are unwilling to assume.
  - There is a good deal of experience in other industries with sensors and control processes from which this program might benefit (e.g., Predictive Maintenance, as practiced in the nuclear industry).
  - A missing element is the human interface; how all this data is to be presented, interpreted, and acted upon.
- Networking, Security, and Protocols and Standards
  - Networks need to be self-configuring and self-healing as there will simply not be enough network engineers to satisfy future demand for services.
  - Communication is not just an issue of inter-control and interoperability but also of the ability to share data.
- Automated Diagnostics, Performance Measurement, Commissioning, and Optimal Control, and Tools
  - Automated diagnostics can be applied at three levels: the component level, the subsystem level, and the whole building level. Most of the R&D performed to date has been at the component and subsystem levels. The market analysis primarily deals with building-level systems.
  - More “commissioning” may be taking place in-house than is generally recognized as progressive maintenance staff perform these functions.

The afternoon consisted of breakout sessions on each R&D option area.

The workshop participants were asked to review the potential R&D pathways, identify high-priority activities, and outline a five-year path for each of these activities. The prioritization was based on project selection criteria developed by DOE:

- largest and quickest impact
- best use of finite resources
- greatest likelihood for market penetration
- ability to replicate results.

In addition, the participants were asked to identify DOE's role vis-à-vis other participants. The most promising R&D opportunities identified by the workshop participants were as follows:<sup>2</sup>

- Current Applications and Strategies for New Applications
  - Next-generation user and automatic controls for lighting and HVAC systems
  - Tools to simulate subsystem and building-level system controls (including utility interface)
  - Optimization of existing systems
  - Dynamic envelope control integration (lighting, thermal ventilation, chemical/bio filter)
- Sensors and Controls
  - Communication: wired vs. wireless (lower cost, powering)
  - Advanced sensors (volumetric air-flow, VOCs, etc.)
  - Testing and qualifying sensors, control systems, and human interfaces
  - Self-calibrating sensors
- Networking, Security, and Protocols and Standards
  - Information and security needs for protocols for new technologies and services
  - Utility-networking requirements
  - Ability to integrate existing component protocols into an advanced whole building master control system.

---

<sup>2</sup>A breakout session was not held for the Market Assessment. DOE is funding a follow on, more detailed Market Assessment, which will in part be shaped by input from the workshop participants.

- Automated Diagnostics, Performance Measurement, Commissioning and Optimal Control and Tools
  - Performance monitoring data management, analytical tools, and optimal sensor placement
  - Automated fault detection and diagnosis
  - Commissioning crosscutting test methods
  - Tools testing and evaluation (using simulation and active crosscutting tests).

# CONTENTS

<b>1.0</b>	Introduction .....	1
<b>1.1</b>	Workshop Objectives .....	1
<b>1.2</b>	DOE Project Selection Criteria .....	1
<b>1.3</b>	Overview of this Report .....	2
<b>2.0</b>	Market Assessment.....	3
<b>2.1</b>	Overview .....	3
<b>2.2</b>	Workshop Results .....	4
<b>3.0</b>	Current Applications and Strategies for New Applications .....	5
<b>3.1</b>	Overview .....	5
<b>3.2</b>	Workshop Results .....	6
<b>4.0</b>	Sensors and Controls .....	9
<b>4.1</b>	Overview .....	9
<b>4.2</b>	Workshop Results .....	10
<b>5.0</b>	Networking, Security, and Protocols and Standards .....	13
<b>5.1</b>	Overview .....	13
<b>5.2</b>	Workshop Results .....	14
<b>6.0</b>	Automated Diagnostics, Performance Measurement, Commissioning and Optimal Control and Tools.....	15
<b>6.1</b>	Overview .....	15
<b>6.2</b>	Workshop Results .....	16
	Appendix A – Workshop Agenda .....	19
	Appendix B - Workshop Attendees.....	23
	Appendix C - R&D Workshops .....	29



## 1.0 INTRODUCTION

One of the strategies identified in DOE's High-Performance Commercial Buildings<sup>3</sup> Roadmap is to

*“Develop systems integration, monitoring, and other technologies that enable commercial buildings to optimally achieve targeted performance levels over their life cycles.”*

The challenge includes the optimization of system interactions (e.g., windows, lights, and heating and cooling systems) despite the fact that most buildings are relatively “dumb” in their operation. The roadmap points the way but is silent as to how to get there. The goal of the Advanced Sensors and Controls R&D plan is to develop a pathway to achieve these advances with some specificity as to what needs to be accomplished in the next five years.

On June 11, 2003, representatives from universities, federal and state government agencies, U.S. Department of Energy national laboratories, and the private sector attended a one-day workshop in Washington, DC. In preparation for the workshop, attendees were provided with a draft synthesis paper summarizing the market assessment and potential R&D pathways.<sup>1</sup>

### 1.1 Workshop Objectives

The objective of the workshop was to review and provide input into DOE's assessment of the market for advanced sensors and controls technology and potential R&D pathways to enhance their success in the buildings marketplace. Through this workshop, DOE sought input and validation on both the market assessment and R&D pathways contained in the background synthesis paper.<sup>4</sup> DOE also wanted stakeholder input on the proper path forward, given the choices and the current understanding of the market, for a research program in advanced controls and sensors. In short, the strategy was to validate the needs (market assessment), develop R&D options to address these needs (pathways), and formulate a five-year R&D plan based on prioritized options.

### 1.2 DOE Project Selection Criteria

DOE has a set of project selection criteria. The first of these is to have a large and relatively near- to mid-term impact on both new and existing commercial buildings. The market assessment identifies the magnitude of current technology, but not potential future technology. The goal is to reduce overall source energy use, but peak demand is also a concern.

---

<sup>3</sup> “High-Performance Commercial Buildings High-Performance Commercial Buildings: A Technology Roadmap,” US Department of Energy, October 2000.

<sup>4</sup> Advanced Sensors and Controls for Building Applications: Market Assessment and Potential R&D Pathways,” DRAFT, June 2003.

Second, DOE wants to be certain it is making the best use of finite resources. As such, the five-year plan should identify not only the options, but also the need for collaborations with others and synergies (including dependencies) with other related technologies. DOE recognizes there is substantial research and development taking place in industry and by other government agencies.

Third, technologies should have attributes that will increase the probability of substantial market penetration. Energy savings alone, while a primary objective for DOE, is probably not enough of a motivating factor to achieve the full market potential. The cost of the technology and ease of use, as well as other attributes that increase market acceptance, are important.

Finally, the ability to replicate results is essential. Technologies and applications should be broad based and applicable to a variety of building types and uses. Technologies that require substantial modification or tuning for each installation will not find a broad application.

### **1.3 Overview of this Report**

Workshop participants were given overviews on the five topic areas in the synthesis paper:

- market assessment
- current applications
- sensors & controls
- networking security
- automated diagnostics.

Summaries of those overviews are provided in Chapters 2 through 6 below, along with results of discussions by workshop participants.

Appendix A of this report is the workshop agenda, Appendix B lists workshop attendees and their contact information, and Appendix C contains worksheets from the breakout groups. These worksheets were provided to DOE to assist in developing a prioritized multi-year plan.

## 2.0 MARKET ASSESSMENT

### 2.1 Overview

The goal of the market assessment is to identify the opportunities for building controls. In summary, the goal is to identify current control technologies and the extent of their use and to understand their energy saving potential. The market assessment also discusses barriers to building controls, as well as value propositions that can increase their likelihood of market adoption.

In 2002, the commercial buildings sector consumed 17.4 quadrillion Btus (Quads) of primary energy (including electricity generation losses), out of total U.S. annual consumption of about 100 quads. Heating, ventilation, and air conditioning (HVAC) and lighting account for about 32% and 25%, respectively, of primary commercial-sector energy consumption.<sup>5</sup> In addition, the “internal gains” from the heat generated in lighting is the principal contributor to building cooling loads.<sup>6</sup> This means that one strategy for reducing peak electric demands in cooling is better use and control of lighting.

The total U.S. sales of building controls (including equipment, and installation and services) equal about \$3 billion per year. Existing buildings account for about 75% of this market. Therefore, the retrofit market is a primary target of this endeavor.

Installation and commissioning accounts for more than 70% of Direct Digital Controls (DDC) building control system installed costs. As such, reductions in installation costs are very valuable. The cost to maintain the system is also significant.

In general, the market penetration of building controls has a negative correlation with the degree of sophistication. Penetration also varies with building size, i.e., smaller buildings have much fewer central control systems. Even though many central systems have very sophisticated functionality, users often do not take advantage of this functionality. Existing systems mainly serve building plant functions.

Data limitations make it difficult to quantify the market-achievable energy savings potential from alternative control approaches. The economics tend to be case-specific and, therefore, make extrapolation to develop a national energy saving potential very problematic. Most approaches appear to have a theoretical energy saving potential of at least 0.5 quads (assuming full market penetration), but the controls approaches studied typically have a large estimated payback period and energy savings ranges.

---

<sup>5</sup> Buildings Core Databook, 2004, Table 1.3.3 (<http://buildingsdatabook.eere.energy.gov/docs/1.3.3.pdf>)

<sup>6</sup> “Commercial Heating and Cooling Loads Component Analysis,” Lawrence Berkeley National Laboratory, June 1998, Table 24, p. 45 and Figure 3, p. 61.



Building owners often do not purchase control systems for their energy savings potential but to reduce maintenance expenses and for other reasons. A 2 to 4-year payback is typically required to interest the building operator in an Energy Management and Control System (EMCS). Control systems are usually considered rather late in the design and construction process, which limits the funds available for controls and the ability to consider more sophisticated controls.

The current market analysis broadly frames the opportunities for future R&D to increase the market share of building controls, be it through measures that reduce the installed cost of building controls or that provide meaningful non-energy benefits to building owners. What can R&D do to increase the amount of savings possible from the building stock?

- Enhance the Indoor Environment –Focus on measures that do more than save energy, most notably that enhance the productivity of the core economic activity of the building. Building economic activity (salaries, sales) accounts for a much greater portion of total building expenditures than energy.
- Reduce Installed Cost – Installation accounts for a significant part of the cost of new control systems. Lower installed cost reduces owners’ concerns about first cost, increasing the likelihood that owners will invest in building controls.
- Reduce Building Controls O&M Costs – lowering both system cost as well as general maintenance cost in the building through automation and early detection.

Overall, productivity gains have the potential to be a much more potent value proposition for building controls than energy savings. These goals can be complementary, but research aimed solely at reducing energy does not address this most potent market driver. A fundamental change is required in the way buildings are operated, both from a technical and business perspective, in order to realize the full potential, including energy savings, from advanced controls systems.

## **2.2 Workshop Results**

The workshop participants generally agreed that a follow-on market assessment was needed. What has not been explored in the initial study is the potential energy savings from more advanced technologies that would result from research and development. This type of analysis requires postulating the future cost and performance of advanced technologies that might be developed as a result of R&D. DOE has initiated this follow-on analysis with TIAX, LLC, which will be available in midyear in 2005.

The current market assessment focused on the market-achievable energy savings from existing technologies. There remains a great deal of uncertainty (sometimes as much as an order of magnitude) about what this potential is. This uncertainty primarily results from large ranges in economic attractiveness and, hence, the projected market penetration of the technologies.

## 3.0 CURRENT APPLICATIONS AND STRATEGIES FOR NEW APPLICATIONS

### 3.1 Overview

There is already substantial market experience with existing Energy Management and Controls Systems (EMCS). Better information is needed on current savings from current technologies and applications as we look to new applications. Better understanding is needed as to how current systems are being used, and to what degree, and what features or attributes are needed to improve existing performance.

System complexity remains an issue. Current systems are not reaching their full potential as users do not understand how to take advantage of advanced features. Once again this must be addressed to move forward into new applications and strategies.

New HVAC controls are not really improving on control algorithms. For the most part, they are limited to a single input and single output control. The human interface to these control systems also needs to be addressed as well as optimization for the entire building.

For lighting controls a host of issues arise. For instance, how do we bind the appropriate switch to the appropriate sensor? Daylighting is one of the biggest potentials for energy savings, but lighting quality control becomes difficult with daylighting. Finally, as lighting is a significant energy use, and also is a major contributor to the building's cooling load,<sup>7</sup> and in some sense variable, we need to be able to respond to utility control measures and still provide a quality working environment.

Present-day systems tend to be customized and wire-based. As a result, they are expensive, hard to maintain, and take significant effort to install and program. One of the challenge areas is to reduce these installation costs by developing systems that are more "self-learning," that reduce their costs of implementation. (i.e., "plug & play" in the computer industry).

Disaster minimization and mitigation is a potential new application area for building control systems (BCS). What are the potential building responses to an emergency situation? Is it possible to run building systems at different levels of operation and how do we control for this?

Demand response to changing electricity prices will require some sort of BCS. How should buildings respond (and to what degree) to real-time pricing of electricity? There is no real understanding of how this information and response mechanism would operate in a BCS. Current controls systems and existing models for designing buildings do not take this into account. There

---

<sup>7</sup> "Commercial Heating and Cooling Loads Component Analysis," Lawrence Berkeley National Laboratory, June 1998, Table 24, p. 45 and Figure 3, p. 61.

is no real global look at how to shift demand in the building. The usual response is just cycling air handlers on a ten-minute schedule or other simple strategies.

Optimization of energy use can be incorporated both into design and into operation. Current design tools are good at certain things, but do not necessarily look at demand response and other factors. On the operation side, it is unclear that the BCSs that are being installed now actually have the capability for optimization.

Since experiments with real buildings are costly, good models for building simulation are essential. You cannot develop design tools or BCSs without good underlying simulations. Many of the models used are not based on physics, but on empirical models.

There has been substantial discussion about natural ventilation. However, fire protection issues and other barriers limit the implementation of 100% naturally ventilated building designs. Thus we build hybrid systems. There is a potential market for BCS in managing these hybrid systems.

This is a natural tension between additional complexity and increased applications. For example, demand response is seen as useful and a potential market. However, forethought must be given as to what the desired outcome and features should be. DOE could assist this process by providing a more succinct vision of how a building should operate and hence the role of controls.

## **3.2 Workshop Results**

The next generation of user and automatic controls is needed. Two target systems were identified. These are

- lighting
- retrofit air conditioning (for buildings currently without A/C).

A “skunkworks” approach could be used to help industry define the next generation of lighting technologies. There would be parallel efforts in HVAC. These teams would work with a clean slate to develop new approaches.

A second area is tools and simulation. It is important to develop tools that could be used in the design phase, and then later in the commissioning and operating phases of the building. Tool development could start with a simplified version just to address lighting and HVAC. Other EMCS-like capability could be added in later years. Lab and field testing of the software against real data would be a longer term process. There is also a need to develop guidance in making simulation input assumptions during the design process.

A third area is optimization of existing systems. This would start with measurements of buildings that were designed using simulation tools. Predicted energy use would be measured against actual energy use. The idea would be to examine the use of tools to assess potential and to determine the viability and need for real-time optimization.

Finally, there is a need for the integration of all sensors and controls systems into a “Dynamic Envelope Control Integration System” or “Whole Building” control system. This would begin with an analysis of the requirements for the next generation of building control systems to handle not only traditional lighting and HVAC, but also building envelope interactions. An assessment would be made of the kinds of control strategies that are needed to link these subsystems. Included in this are issues of optimization in the context of real-time pricing and on-site generation.



## 4.0 SENSORS AND CONTROLS

### 4.1 Overview

A process cannot be controlled if it cannot be measured (or sensed). But in order to increase the use of sensors, costs need to be lower and reliability and performance improved. Sensors need to measure parameters we might not be measuring today. For instance, most sensors do not measure real occupancy, just motion.

New sensors (or broader application of novel sensors) may allow us to meet novel or emerging human needs (e.g., CO<sub>2</sub> and mold growth). However, these new sensors also present problems for building owners. The ability to measure also implies the ability to act to prevent or redress a problem. It also implies a standard against which contaminant levels are being measured (where none may exist).

If wireless sensors are seen as offering significant potential, especially for retrofits, the question arises as to how these will be powered. Low-cost batteries are one possibility, but battery replacement causes a maintenance issue and a disposal issue. A potential area of research is energy scavenging from vibration and other sources.

An identified gap is sensor system testing and qualification. How do we ensure that sensors operate in the field the same way they did in the laboratory and in both natural and human-created environments? There is also a need for testing to uncover problems that can occur with vandalism and other potential damage as well as long-term calibration issues.

On the controls side, there is a need for controls that provide smoother transitions when switching modes. Sometimes controllers fail to switch operating modes between seasons or during unusual weather occurrences. Fault tolerant controls are needed when there are faulty sensors. Controls also need to have predictive capabilities to have the ability to minimize peak demand.

Hybrid controls are systems that combine state machines and continuous controllers. There are opportunities for this industry to learn from other industries such as automotive and aerospace and to bring that knowledge to buildings. The question is: “What is the DOE role in bringing these sorts of hybrid controls to the building marketplace?”

Cost-effective methods are needed to retrofit controls. This will broaden the market to existing buildings and make upgrades possible.

The interaction of sensors and controls is important. Guidelines are needed for installation and selection in order to properly match sensors and controls. Ensuring good performance even under conditions of sensor failure is another need.

Actuators perform the mechanical task of opening and closing dampers and other physical operations. There is a need to improve the reliability, life and performance of actuators. There is a trade-off between optimal dynamic response and robustness. Control that is not robust can result in oscillatory behavior (hunting for the exact right setting). This can cause premature failure of the actuators.

An important area for research is the human-control system interaction. The need is to convey information, not data, and ideally to alert to problems and suggest remedies. Until the human interface is understood, systems will continue to operate well below their optimal level. System interfaces not only are for the building operator, but a level of system interface is needed for the building users.

In terms of actuator operation, there is a need to look at building operation in a totally new way. If cars were operated similar to commercial buildings, we would run the engine and transmission at maximum throttle and only use the brake to control the vehicle. We need to make controls that will maintain building operations with minimum expenditures of energy.

## **4.2 Workshop Results**

The approach was to take initial ideas for R&D topics and categorize them. Two new sections were identified as part of this process. The group established priorities, ranked the top three, and then provided detail on the five-year plan.

The top-rated area was communication for wireless control. The identified needs are as follows:

- 1) Assess what technologies are already out there in other fields, and how they can be applied in buildings.
- 2) Create and support standards for interoperability.
- 3) Research the potential for building control with wireless sensing and communication.

In addition, there is a need for standards to allow integration of wireless systems into existing building automation systems. Power scavenging should also receive some attention as well as further miniaturization to develop smaller sensors, increasing the range over which such devices can communicate, and extending to higher temperatures (for use in boilers, for example).

The second priority area was advanced sensors. Specific sensor concepts include

- 1) Volumetric air flow sensing
- 2) Low-cost power metering to see where the power is being used in buildings
- 3) Low-cost humidity sensors at about \$10 per sensor, compared to current costs of \$100 per sensor
- 4) A whole set of indoor air quality sensors to measure concentrations of CO<sub>2</sub>, mold, pollen, etc.
- 5) Biochemical and chemical sensors for threat detection with an emphasis on the security of building HVAC systems. (We assume this would require detection outside the

building envelope, but they could also detect contaminants released from within the building.)

Over the longer term, self-configuring, self-calibrating sensors should be investigated.

The third area was testing and qualifying sensors. The goal is not only to understand the limits of sensors, and improvements needed, but also to determine optimal selection and placement. Areas for further investigation are

1. Identification and characterization of testing conditions, e.g., threat conditions, temperature, and humidity.
2. Development of test procedures.
3. Development of a test facility and of a human interface test facility.





## 5.0 NETWORKING, SECURITY, AND PROTOCOLS AND STANDARDS

### 5.1 Overview

Workshop participants envision a future where buildings will be monitored and operated remotely. This additional capability will need to be addressed not only from a protocol and standards perspective, but perhaps more importantly, from a security perspective. This is a new area for building networking protocols.

There are additional desired capabilities in distributed intelligence and systems integration. Consideration must be given as to what protocols will be required to allow these new services and technologies to develop. What does the network need to look like to handle these new technologies? What are the security requirements for these new technologies? To what degree is "backwards compatibility" desired and what are the hurdles to this capability?

If we add to this the ability to respond to changing prices for energy, in real time, additional levels of complexity may ensue. As a result of utility deregulation, reserve margins may go down which increases price volatility. Buildings can have the capability to respond to increasing prices by shedding load (decreasing demand). Currently, there is limited market structure that allows (rewards) a building owner for shedding load based on the total utility system demand. As the ability for demand response adds additional complexity to building operation, more research is required to develop a theory of how this market will operate. There will be a fundamental shift from local control (the building operator) to global control of a building (by building owners or managers, or utilities). Security is but one aspect of interoperability that will have to span a range of building infrastructure(s).

Beyond remote control of buildings, there is also the possibility of information sharing with outside partners (utilities, energy service companies, vendors). This information could be used for performance monitoring and diagnostics, or something as simple as billing. This type of sharing could extend to application sharing where different operators have to control different aspects of building operation from both inside and outside the building. There are also issues of data ownership.

Immediate issues arise as to who owns the network (if it is shared on a local computer LAN). How are decisions made as to how many devices can connect so as not to overwhelm the network? Consideration must be given to network architecture and all associated components including cabling and existing standards. Self-configuring, self-healing networks are one answer to the increased demand for network standards.

BACNet is one of several options. But BACNet does not have to be the answer for all these increased services and needs. For instance, many industries are using XML to share data. Also, BACNet can be used for some features, but it is not necessarily the answer to security issues.

## **5.2 Workshop Results**

A primary research focus should be the utility networking requirements. What does the connection to the utility look like? An initial step would be to develop a first principles model that looks at the building-utility interface. A second step is to work with the appropriate standards organizations to define what is needed and to get these standards in place.

Another area of focus is security. This includes the security framework not only between buildings and utilities, but also anywhere else data or control might travel inside or outside the building. This is not only an issue for existing applications, but must also be considered for future applications.

A final area is to reduce the cost and complexity of networking through development of “Smart Networks.” This includes developing an information model to enable

- self-configuration
- self-healing network
- information exchange
- self-documentation.

This includes how to report and convey information to applications (e.g., access control, lighting, and ventilation) based on knowledge of occupancy. Finally, what would be required in the protocol and what is required in the network?

## **6.0 AUTOMATED DIAGNOSTICS, PERFORMANCE MEASUREMENT, COMMISSIONING AND OPTIMAL CONTROL AND TOOLS**

### **6.1 Overview**

Many buildings control systems are essentially “broken.” Energy systems are malfunctioning or disabled. Unfortunately, there is a lack of systematic information available as to the causes, remediation efforts, and paybacks. More information is needed.

The ultimate question is what is the size of the actual energy savings opportunity? Texas A&M has an established approach to “tuning up” existing buildings. Their team has been able to achieve energy savings of 20% with less than a two-year payback just from fixing faults and fine-tuning control strategies.

More information is needed on identifying typical problems in buildings and the best way to address them. Information is also required on the persistence level of savings through time, and on non-energy benefits.

A key to addressing wasteful energy use in buildings is getting the right information in a useful format. This is the essence of performance monitoring. Good visualization tools and the ability to compare performance with historical performance are also needed. Current EMCSs have poor capabilities and do not provide the right kinds of measurement.

Tools are also needed to perform automated diagnostics. These tools should provide both fault detection and diagnosis. An additional desired capability is active testing. Automated diagnostics falls into two categories. Some manufacturers supply diagnostics with individual components. Other firms are attempting to aggregate these component-based diagnostics to systems targeted at the whole building level (or higher).

Commissioning is hand-crafted. The process is manual, which increases costs and decreases the ability to replicate the process. Much commissioning is done in-house but is not labeled commissioning. Instead, it is labeled as repairs and maintenance. This process needs to be automated so that it can be shared and replicated. The ability to retro-commission is limited by the lack of poor benchmarks from bad or non-existent commissioning when the building was new.

Optimal control is the ability to manage energy use so as to maximize performance for the dollar. This includes responding to price changes and, when possible, shifting electricity consumption to off-peak hours. Two possible paths are to implement optimal control on-line in the building or conduct lab-based research to develop heuristic strategies that approximate optimal control and are potentially more robust. Optimal control can be expected to provide greater benefits when the

building includes thermal storage and/or on-site electricity generation to address peak load issues. While energy savings might be modest, cost savings can be significant. The buildings industry can learn from other process industries that are already doing this.

While there are very good building design tools, none at present includes the ability to model control strategies. This limits consideration of controls for eventual inclusion in the final design. The result is sub-optimal design from an energy standpoint.

## **6.2 Workshop Results**

This topic area included diagnostics, performance measurement, commissioning, and optimal control as well as tools. The workshop participants gave equal weighting to the importance of all these R&D areas except commissioning. Commissioning received no votes.

There are three areas included in performance monitoring:

- 1) Data management – There is a lot of data but storage and use is never centralized. Data protocols are needed.
- 2) Sensor location – Proper location is not very well understood now and may get worse as the sensors move throughout the building.
- 3) Analysis tools – Tools need to be integrated.

In the first two years, the research should focus on best practices for sensor selection and placement. Years three through five will focus on development of integrated tools and the extension to peak demand. An effort will also be needed in the area of data management.

Additional case studies are needed to determine the cost and benefits of commissioning.<sup>8</sup> Development of standardized tests should be the focus of the first two years. In years three through five, additional test methods should be developed and validated to determine their ability to achieve energy savings. In the longer term, research should focus on sensors that can “rediscover” building layout and usage to inform commissioning.

Two areas were identified for automated diagnostics:

- 1) Fault detection – What are the best methods and how can they be integrated?
- 2) Prioritization of faults - Which faults require more attention than others?

---

<sup>8</sup> Editor’s Note. Such a study was completed subsequent to the workshop. See Evan Mills, et al., “The Cost-Effectiveness of Commercial-Buildings Commissioning: A Meta-Analysis of Energy and Non-Energy Impacts in Existing Buildings and New Construction in the United States,” Lawrence Berkeley National Laboratory, LBNL-56637, December 2004.” Also available at: <http://eetd.lbl.gov/emills/PUBS/Cx-Costs-Benefits.html>

The first two years will focus on development, testing, and ranking of fault detection and diagnostic systems for standard systems and components. In out-years, this process will be extended to new systems.

Tools are needed for active tests that address the interactions between systems, e.g., HVAC and lighting controls. These tools should be tied to simulation models. Work should include improved interfaces as well as national, web-based access to these tools.



## **APPENDIX A**

### **Workshop Agenda**





## Appendix A – Workshop Agenda

### U.S. DOE Advanced Controls R&D Workshop

June 11, 2003, Washington, DC

#### Objective

Obtain review and input of the U.S. Department of Energy’s assessment of the market for advanced controls technology and potential R&D pathways to enhance the success of advanced controls in the buildings market place.

Time	Event	Presenter
8:30-9:00	Refreshments and Registration	
9:00-9:15	Welcome and Overview	David Hansen, US DOE
9:15-9:30	Agenda and Format	Sean McDonald, PNNL
9:30-10:00	Market Assessment	Kurt Roth, TIAX
10:00-10:15	<b>Break</b>	
10:15-10:45	Current Applications and Strategies for New Applications	Paul Torcellini, NREL
10:45-11:15	Sensors and Controls	Michael Brambley, PNNL
11:15-11:45	Networking, Security, and Protocols and Standards	David Holmberg, NIST
11:45-12:15	Auto. Diag., Perf. Monitoring, Comm., Optimal Control and Tools	Philip Haves, LBNL
12:15-1:00	<b>“Outside the Box” Lunch</b> (Lunch Provided)	Short presentations during lunch to get people thinking “outside the box.”
1:00-2:15	Breakout Sessions <ul style="list-style-type: none"> <li>• Response to presentation Q&amp;A</li> <li>• Refinements to R&amp;D options</li> </ul>	
2:15-2:30	<b>Break</b>	
2:30-3:00	Breakout Sessions <ul style="list-style-type: none"> <li>• Prioritization of R&amp;D opportunities</li> </ul>	
3:00-4:15	Presentation of Breakout sessions <ul style="list-style-type: none"> <li>• Current and New Applications</li> <li>• Sensors and Controls</li> <li>• Networking, Sec, Protocols &amp; Standards</li> <li>• Automated Diag, PM, Comm. and Optimal Control and Tools</li> </ul>	White Paper Leads
4:15-4:45	Cross-Cutting Issues & "Outside the box"	Sean McDonald, PNNL
4:45-5:00	Next Steps	David Hansen, DOE
5:00	Adjourn	



## **APPENDIX B**

### **Workshop Attendees**



## APPENDIX B - WORKSHOP ATTENDEES

Don Anderson, Principal  
ICF Consulting Inc  
9300 Lee Highway  
Fairfax, VA 22301  
phone: (703) 218-2774  
fax: (703) 934-3974  
email: DAnderson@icfconsulting.com

Karen Benedek  
TIAX, LLC  
15 Acorn Park  
Cambridge, MA 02140-2328  
phone: (617) 498-6061  
fax: (617) 498-7206  
email: benedek.k@tiaux.biz

David Bornside, Senior Principal Engineer  
Siemens Building Technologies  
1000 Deerfield Parkway  
Buffalo Grove, IL 60089  
phone: (847) 941-5422  
email: david.bornside@siemens.com

Joseph Borowiec, Associate Project Manager  
NYSERDA  
Building R&D  
17 Columbia Circle  
Albany, NY 12203  
phone: (518) 862-1090 ext. 3381  
fax: (518) 862-1091  
email: jcb@nyserda.org

Michael Brambley, Staff Scientist  
Pacific Northwest National Laboratory  
P.O. Box 999, MS K5-16  
Richland, WA 99352  
phone: (509) 375-6875  
fax: (509) 375-3614  
email: michael.brambley@pnl.gov

Martha Brook, P.E., Senior Mechanical  
Engineer  
California Energy Commission  
MS-42  
1516 Ninth Street  
Sacramento, CA 95814  
phone: (916) 654-4086  
fax: (916) 651-8886  
email: MBrook@energy.state.ca.us

Karl Brown  
California Institute for Energy Efficiency  
1333 Broadway Suite 240  
Oakland, CA 94612  
phone: (510) 287-3330  
email: karl.brown@ucop.edu

Steven Bushby  
NIST  
Building Environment Division (863)  
100 Bureau Drive, Stop 8631  
Gaithersburg, MD 20899-8631  
phone: (301) 975-5873  
email: steven.bushby@nist.gov

Ronald Caffrey  
BCS Partners  
2008 Carolina Circle N.E.  
St. Petersburg, FL 33703  
phone: (727) 528-9684  
fax: (same - call first)  
email: rcaffrey@tampabay.rr.com

Michael Chapman, Senior Architect, CHENG  
Naval Facilities Engineering Command  
Design Policy/Architecture  
1322 Patterson Avenue, SE  
Washington Navy Yard  
Washington, DC 20374-5065  
phone: (202) 685-9175  
fax: (202) 685-1577  
email: MCHAPMAN@navfac.navy.mil

David Claridge, Professor  
Texas A&M University  
Department of Mechanical Engineering  
College Station, TX 77843-3123  
phone: (979) 845-1280  
fax: (979) 862-2762  
email: Claridge@esl.tamu.edu

Dru Crawley  
U.S. Department of Energy  
1000 Independence Ave, SW, EE-2J  
Washington, DC 20585  
phone: (202) 586-2344  
fax: (202) 586-5557  
email: drury.crawley@ee.doe.gov

Paul Ewing, Leader  
RF & Microwave Systems Group  
Oak Ridge National Laboratory  
One Bethel Valley Road  
Building 3500 MS 6006 Room B18  
PO Box 2008  
Oak Ridge, TN 37831-6006  
phone: (865) 576-5019  
email: ewingpd@ornl.gov

Kevin Finnegan, Senior Project Manager  
Battery Park City Authority  
One World Financial Center  
New York, NY 10281-1097  
phone: (212) 416-4330  
fax: (212) 416-5314  
email: FinneganK@bpcauthor.org

Theo Frutiger, System Architect  
Siemens Building Technologies  
Siemens SBT HVAC Products  
1000 Deerfield Parkway  
Buffalo Grove, IL 60089  
phone: (847) 941-6255  
fax: (847) 941-4721  
email: theo.frutiger@siemens.com

Vijay Gupta, Senior Mechanical Engineer  
U.S. General Services Administration  
Office of the Chief Architect  
1800 F Street, NW  
Washington, DC 20405  
phone: (202) 501-0628  
fax: (202) 501-3393  
email: Vijay.Gupta@gsa.gov

David Hansen  
U.S. Department of Energy  
1000 Independence Ave, SW, EE-2J  
Washington, DC 20585  
phone: (202) 586-9192  
fax: (202) 586-5557  
email: david.hansen@ee.doe.gov

Tom Hartman  
The Hartman Company  
9905 39th Drive NE  
Marysville, WA 98270  
phone: (360) 658-1168  
fax: (360) 658-1178  
email: thartman@hartmanco.com

Philip Haves  
Lawrence Berkeley National Laboratory  
Building 90, MS 90-3074  
1 Cyclotron Road  
Berkeley, CA 94720  
phone: (510) 486-6512  
fax: (510) 486-4089  
email: PHaves@lbl.gov

David Holmberg  
NIST  
Building Environment Division (863)  
100 Bureau Drive, Stop 8631  
Gaithersburg, MD 20899-8631  
phone: (301) 975-6450  
email: david.holmberg@nist.gov

John House  
Iowa Energy Center  
Suite 124  
2521 Elwood Drive  
Ames, Iowa 50010-8263  
phone: (515) 294-0111  
fax: (515) 294-9912  
email: jhouse@energy.iastate.edu

Steve Karg  
Lithonia Lighting  
One Lithonia Way  
Building 1  
Decatur, GA 30035  
phone: (770) 987-4200  
email: skarg@lithonia.com

Roger Kisner  
Oak Ridge National Laboratory  
One Bethel Valley Road  
Building 37831 MS 6004  
P.O. Box 2008  
Oak Ridge, TN 37831-6004  
phone: (865) 574-5567  
email: kisnera@ornl.gov

Ron Lewis  
U.S. Department of Energy  
1000 Independence Ave, SW, EE-2J  
Washington, DC 20585  
phone: (202) 586-8423  
email: ronald.lewis@ee.doe.gov

Eric Lightner  
U.S. Department of Energy  
Office of Electric Transmission and  
Distribution  
1000 Independence Ave, SW, EE-2D  
Washington, DC 20585  
phone: (202) 586-8130  
fax: (202) 586-5860  
email: eric.lightner@ee.doe.gov

Vivian Loftness  
Carnegie Mellon University  
Architecture Department  
Head of the School of Architecture  
500 Forbes Avenue  
4919 Frew St. Room 201  
Pittsburgh, PA 15213  
phone: (412) 268-2356  
email: loftness+@andrew.cmu.edu

Tom Lohner, Vice President  
Teng & Associates  
4050 Innslake Drive  
Suite 300  
Glen Allen, VA 23060-3327  
phone: (804) 474-4550  
fax: (804) 474-4555  
email: lohnertj@teng.com

Sean McDonald  
Pacific Northwest National Laboratory  
901 D Street, SW  
Suite 900  
Washington, DC 20024  
phone: (202) 646-5217  
fax: (202) 646-5233  
email: sean.mcdonald@pnl.gov

John McKissack, P.E.  
The Kele Companies  
3300 Brother Boulevard  
Memphis, TN 38133  
phone: (901) 382-4300 ext. 3770  
fax: (901) 372-2531  
email: johnm@kele.com

Terrence McMahon  
BCS Partners  
135 Fort Lee Road  
Leonia, NY 07605  
phone: (201) 585-2050  
fax: (201) 585-1968  
email: mcmahontec135@aol.com

Mark Myers, Research Fellow  
United Technologies Research Center  
411 Silver Lane  
Mail Stop 129-85  
East Hartford, CT 06108  
phone: (860) 610-7538  
fax: (860) 660-1288  
email: MyersMR@UTRC.UTC.COM

Kurt Roth  
TIAX, LLC  
15 Acorn Park  
Cambridge, MA 02140-2328  
phone: (617) 498-6062  
email: roth.kurt@tiaux.biz

John Ryan  
U.S. Department of Energy  
1000 Independence Ave, SW, EE-2J  
Washington, DC 20585  
phone: (202) 586-8823  
fax: (202) 586-4617  
email: john.d.ryan@ee.doe.gov

Harvey Sachs, Director  
ACEEE  
Buildings Programs  
1001 Connecticut Ave NW, Suite 801  
Washington, DC 20036  
phone: (202) 478-7706  
email: hsachs@aceee.org



Michael K. Sahn  
Research Fellow & Energy System Group  
Leader  
United Technologies Research Center  
411 Silver Lane  
Mail Stop 129-65  
East Hartford, CT 06108  
phone: (860) 610-7605  
fax: (860) 660-1358  
email: SahmMK@UTRC.UTC.COM

Jeffrey Schein  
NIST  
Building Environment Division (863)  
100 Bureau Drive, Stop 8631  
Gaithersburg, MD 20899-8631  
phone: (301) 975-5874  
email: jeffrey.schein@nist.gov

John Seem  
Johnson Controls  
507 East Michigan Street  
Mail Stop M36  
Milwaukee, WI 53202  
phone: (414) 524-4677  
fax: (414) 524-5810  
email: John.E.Seem@jci.com

Sandy Smith  
ACEEE  
Buildings Programs  
1001 Connecticut Ave NW, Suite 801  
Washington, DC 20036  
phone: (202) 478-7700  
email: ssmith@aceee.org

Mike Stein  
Mike Stein Associates  
40 Alize Drive  
Kinnelon, NJ 07504  
phone: (973) 838-8140  
fax: (973) 838-8035  
email: mike.stein@worldnet.att.net

Randal Stites, Engineering Manager  
Hines GS Properties, Inc.  
901 D. Street, SW  
Box 18, Suite 290  
Washington, DC 20024-2169  
phone: (202) 484-8181  
fax: (202) 484-0579  
email: randal\_stites@hines.com

Paul Torcellini  
National Renewable Energy Laboratory  
1617 Cole Blvd  
Mail Stop 2722  
Golden, CO 80401-3393  
phone: (303) 384-7528  
fax: (303) 384-7540  
email: Paul\_Torcellini@nrel.gov

Stephen Treado  
NIST  
Building Environment Division (863)  
1000 Bureau Drive, Stop 8631  
Gaithersburg, MD 20899-8631  
phone: (301) 975-6444  
email: stephen.treado@ist.gov

Martin Weiland  
Manager of Government Outreach  
ASHRAE  
1828 L St. N.W., Suite 906  
Washington, DC 20036-5104  
phone: (202) 833-1830  
fax: (202) 833-0118  
email: mweiland@ashrae.org

Robert Williams  
Continental Automated Buildings Association  
(CABA)  
4200 NW 74th Court  
P.O. Box 901525  
Kansas City, MO 64151  
phone: (816) 746-4320  
fax: (212) 202-4493  
email: bobwilliams23@aol.com or  
bobwilliams23@sbdglobal.com

## **APPENDIX C**

### **R&D Worksheets**



## C.1 Sensors and Controls

R&D Program Area: Sensors and Controls

R&D Project Activity: Communication: Wired vs. Wireless

Team members:

Completed by:

Years	Activities	Outcomes	Partners
1-2	<ol style="list-style-type: none"> <li>1. Assessment of existing technologies from other fields that could be applicable to wireless for buildings for wireless and provide for low-cost, long life, etc.</li> <li>2. Create/support standards for interoperability, security and interference for wireless used in building automation.</li> <li>3. Research into doing control with wireless sensing and communication.                             <ul style="list-style-type: none"> <li>□ Develop technical alternatives for wireless control.</li> </ul> </li> <li>4. Integration with building automation systems (BAS).</li> </ol>	<ol style="list-style-type: none"> <li>1. Utilization and development plan for low-cost, long-life wireless systems</li> <li>2. Standards</li> <li>3. Method and process for closed loop control utilizing wireless sensor technology.</li> </ol>	
3-5	<ol style="list-style-type: none"> <li>1. Scavenging power</li> <li>2. Further miniaturization – capability to make smaller, lower-cost wireless sensors.</li> </ol>	<ol style="list-style-type: none"> <li>1. Technologies for scavenging power</li> <li>2. Technology for smaller, lower-cost, lower-power wireless sensors</li> </ol>	
5-10	<ol style="list-style-type: none"> <li>1. Increase wireless communication range</li> <li>2. Decrease power consumption of wireless sensors</li> <li>3. Extend sensors to higher temperatures and other more severe environmental conditions (e.g. for use in boilers)</li> </ol>	<ol style="list-style-type: none"> <li>1. Communication technology with longer ranges</li> <li>2. Lower power wireless sensors</li> <li>3. Wireless sensors for more hostile environments, such as boilers</li> </ol>	

R&D Program Area: Sensors and Controls

R&D Project Activity: Advanced Sensors

Team members:

Completed by:

Years	Activities	Outcomes	Partners
1-2	<ol style="list-style-type: none"> <li>1. Volumetric air-flow sensor, especially for use in low velocities.</li> <li>2. Low-cost power meters for end-use monitoring</li> <li>3. Low-cost relative humidity sensors - Low-cost IAQ sensors.</li> <li>4. Low-cost IAQ sensors for:               <ol style="list-style-type: none"> <li>a. CO<sub>2</sub></li> <li>b. VOC</li> <li>c. Mold</li> <li>d. Pollen...</li> </ol> </li> <li>5. Bio/chem sensors for threat detection application to HVAC and buildings.</li> </ol>	<ol style="list-style-type: none"> <li>1. Reliable, accurate, reasonable-cost volumetric air-flow sensor for use in HVAC systems</li> <li>2. Low-cost power meters</li> <li>3. \$10 relative humidity sensor</li> <li>4. Low-cost IAQ sensors for several indoor air contaminants</li> <li>5. Application needs and guides for detecting biological and chemical threats in buildings</li> </ol>	
3-5	<ol style="list-style-type: none"> <li>1. Self -* sensors. (* You name it. Configuring, calibrating, announcing, commissioning, etc.)</li> <li>2. Peripatetic sensors</li> <li>3. The human role in control systems (polling, real-time reporting, user interactions with controls, feedback, display, etc.)</li> </ol>	<ol style="list-style-type: none"> <li>1. Self-configuring, self-calibrating, self-announcing, self-commissioning sensors</li> <li>2. Peripatetic sensors</li> <li>3. Knowledge and guidance for improving user interfaces for controllers and control systems</li> </ol>	
5-10	<ol style="list-style-type: none"> <li>1. Ultimate processing &amp; memory on sensors</li> </ol>	<ol style="list-style-type: none"> <li>1. Smart sensors with processing and memory</li> </ol>	

R&D Program Area: Sensors and Controls

R&D Project Activity: Testing & Qualifying Sensors, Control Systems, and Human Interfaces

Team members:

Completed by:

<b>Years</b>	<b>Activities</b>	<b>Outcomes</b>	<b>Partners</b>
1-2	<ol style="list-style-type: none"><li>1. Identification and characterization of testing conditions.</li><li>2. Development of test procedures.</li><li>3A. Development of test facility.</li><li>3B. Development of human interface test facility.</li></ol>	<ol style="list-style-type: none"><li>1. Document identifying and characterizing testing conditions.</li><li>2. Test facility for sensors and control systems.</li><li>3. Test facility for human interfaces.</li></ol>	
3-5	<ol style="list-style-type: none"><li>1. Make use of the test facilities the industry norm via a certification program, rating system, or test program.</li></ol>	<ol style="list-style-type: none"><li>1. Implementation of a certification program, rating system or test program for sensors, controls, and user interfaces to them.</li></ol>	
5-10			

## C.2 Networking, Security Protocols & Standards

R&D Program Area: Networking, Security Protocols & Standards

R&D Project Activity: Protocols & Standards

Team members: David Holmberg, Steve Bushby, Paul Ewing, Steve Karg, Terry McMahon

Completed by: David Holmberg

Years	Activities	Outcomes	Partners
1-2	ID information needs for protocols to enable new network tech/services  ID security needs in protocols  Analyze BCS –lights (HVAC-lights) interconnection		
3-5	Demos	Publish studies Reference designs	
5-10			

R&D Program Area: Networking, Sec Protocols & Protocol Standards

R&D Project Activity: Utility-Networking Requirements

Team members: David Holmberg, Steve Bushby, Paul Ewing, Steve Karg, Terry McMahon

Completed by: David Holmberg

Years	Activities	Outcomes	Partners
1-2	<p>First principal model of complex controls  Works with ASHRAE, EPRI, IEEE on communication studies (formats, transport information requirements, security) NT-MT</p> <p>Security framework to enable BCS utility intercross  Lab demos services/proof-of-concept  What can DOE do to facilitate RTP</p>	<p>Input to standards bodies  Demos</p>	<p>EPRI  ASHRAE  Georgia Power  GE Power Systems  DOE</p>
3-5	<p>Demonstrate: field test</p> <p>Inter-operability of “new” with “old”</p>	<p>Educational documents</p>	
5-10			



R&D Program Area: Networking, Sec Protocols & Protocol Standards

R&D Project Activity: Smart Networking

Team members: David Holmberg, Steve Bushby, Paul Ewing, Steve Karg, Terry McMahon

Completed by: David Holmberg

Years	Activities	Outcomes	Partners
1-2	Develop information model to enable <ul style="list-style-type: none"> <li>- Self-configuration</li> <li>- Self-healing network</li> <li>- Information exchange</li> <li>- Self-documentation</li> </ul> Security analysis  Wireless issues  How to report and convey information and application development (e.g., access control, lighting and ventilation from knowing occupancy)	Paper(s)	International Alliance for Interoperations
3-5	Develop enabling protocol pieces  Networking developments  Test bed demo/field test	Educational documents  Results	
5-10			

### C.3 Current and New Applications

R&D Program Area: Current and New Applications

R&D Project Activity: Next Generation User & Automatic Controls

Team members:

Completed by:

Years	Activities	Outcomes	Partners
1-2	<p>Establish statement of work performance goals for “skunkworks” teams and RFQ for assemble teams (Lighting &amp; HVAC)</p> <p>‘3’ teams (each) complete paper studies of hardware choices and controls issues to develop conceptual alternatives - select one team identify regional design issues</p>	<p>e.g. Lighting: high level of control</p> <ul style="list-style-type: none"> <li>- Self configure</li> <li>- Reconfigurable fixture location and zone control</li> <li>- User satisfaction</li> <li>- Out-of-the-box installation performance (no commission)</li> <li>- Energy efficiency: annual, peak, demand with user feedback</li> <li>- Daylight performance façade</li> <li>- No parasitic loads</li> </ul> <p>e.g., HVAC</p> <p>Introducing cooling/ventilation in existing buildings without air conditioning now, while maintaining natural ventilation.</p> <p>Performance goals:            High-level of user satisfaction            ASHRAE standards            Energy efficiency: annual, peak, demands            Robust, low O&amp;M</p>	<p>Mfg x 3            Fixture            Ballast            Controller            Façade Controls            Lamp            Installer</p> <ul style="list-style-type: none"> <li>- GSA-End User/ERGO</li> </ul> <p>3 teams</p> <ul style="list-style-type: none"> <li>- HVAC water and air</li> <li>- Piping/ducting</li> <li>- Façade manufacturing /window manufacturing</li> </ul>

		<p>No commission/out-of-the box install</p> <p>High-level of user control-untrained user</p> <p>No parasitic load</p> <p>Natural ventilation/cooling effectiveness</p> <p>Dynamic zone control/modification</p> <p style="padding-left: 40px;">- Acoustic control</p>	<p>All 3 teams in each should succeed with variations in cost/performance choices – key to competitive supply for federal sector.</p>
3-5	<p>Engineering and prototyping of complete systems, testing with untrained installer and controls performance with untrained user.</p> <p>Demonstration/field project measurement including health and productivity gains.</p> <p>Life cycle costing based on volume production</p> <p>Take plug and play conditioning system to market</p>		
5-10			

R&D Program Area: Current and New Applications

R&D Project Activity: Tools and Simulation

Team members: John Ryan

Completed by:

Years	Activities	Outcomes	Partners
1-2	Design Phase (steady state) <ul style="list-style-type: none"> <li>- Catalog equipment configurations &amp; control strategies</li> <li>- Characterize a subset of hardware components in a standardized format</li> <li>- Develop software and lab test against research data.</li> </ul>	Design Phase  Tool that will simulate operation of subsystem controls in standalone mode <ul style="list-style-type: none"> <li>- Lighting</li> <li>- HVAC               <ul style="list-style-type: none"> <li>o Common systems</li> <li>o Less common</li> </ul> </li> </ul>	
3-5	Field test subsystem models Lighting HVAC  Add EMCS and utility modules	Tool that simulates EMCS – whole building including utility interface	
5-10	Operational Phase (steady state) <ul style="list-style-type: none"> <li>- Data collection thru EMCS</li> </ul>	Tool that simulates operational control system: sensor locations, piping configuration as built <ul style="list-style-type: none"> <li>- Embodied in EMCS system</li> </ul>	

R&D Program Area: Current and New Applications  
 R&D Project Activity: Optimization of Existing Systems  
 Team members:  
 Completed by:

Years	Activities	Outcomes	Partners
1-2	Measure building that used design tools – actual energy  Study using tools to assess potential  Determine viability/need for real-time optimization  Benchmark optimization from other industries find parallel industries	Access what is potential of real-time control vs. control	Universities, DOE 2 users Building Operators
3-5		How does hierarchal control approach account for <ul style="list-style-type: none"> <li>- DG/PV</li> <li>- pricing</li> <li>- inter-system priorities/interplay/affects</li> <li>- load shedding</li> </ul>	
5-10	Development of optimization science  Implementation of optimization strategies document savings		

R&D Program Area: Current and New Applications

R&D Project Activity: Dynamic Envelop Control Integration (Lighting, thermal ventilation, chemical/bio filter)

Team members:

Completed by:

Years	Activities	Outcomes	Partners
1-2	<p>Benchmark current technologies world wide</p> <p>Survey current product development and research</p> <ul style="list-style-type: none"> <li>- design research</li> <li>- technical product research</li> <li>- industry</li> <li>- national labs</li> </ul> <p>Workshops on regional climatic design responses</p>	<p>Report on challenges for each climatic zone and recommendations for further design development</p>	<ul style="list-style-type: none"> <li>- GSA</li> <li>- DoD</li> <li>- A-E Industry</li> <li>- Academia</li> <li>- Building Technology Industry               <ul style="list-style-type: none"> <li>o Lighting</li> <li>o Envelope</li> <li>o HVAC</li> </ul> </li> <li>- ASHRAE</li> </ul>
3-5	<p>Competitive prototyping of complete systems – next-generation</p> <ul style="list-style-type: none"> <li>- Switch filters (dynamic) envelopes</li> </ul> <p>DOE &amp; partner-funded demonstration projects – regionally focused</p> <p>Control strategies for interaction of equipment</p>	<p>Samples of next-generation prototype envelopes</p> <p>Performance data- regionally defined</p>	
5-10	<p>Completed pilot projects of next-generation envelopes with evaluation data</p>	<p>Regional guidelines for envelop design with performance data</p>	

## C.4 Automated Diagnostics, PM, Communication & Optimal Control Tools

R&D Program Area: Automated Diagnostics, PM, Communication & Optimal Control Tools

R&D Project Activity: Performance Monitoring

Team members:

Completed by:

Years	Activities	Outcomes	Partners
1-2	Data Management Integration Quality validation Std protocol EMCS access  Sensor selection and location (best practice) guidance	Protocol, approaches, algorithms	
3-5	Analysis tools (e.g., peak demand) Validate with operators. Enhance visualization.	Integrated tool options	
5-10	Sensor selection and location (advanced)  Extend previous year's efforts as needed	Advanced guidance	

R&D Program Area: Automated Diagnostics, PM, Comm. & Optimal Control Tools

R&D Project Activity: Automated Diagnostics

Team members:

Completed by:

Years	Activities	Outcomes	Partners
1-2	Develop, test and rank Fault Detection and Diagnostics (FDD) methods for standard systems and components (e.g. chillers, AHUs, VAVs) <ul style="list-style-type: none"> <li>- Includes passive and active testing</li> <li>-</li> </ul> Crosscutting leverage what's been developed in other (non-buildings) industries.	Prioritization of faults <ul style="list-style-type: none"> <li>- High occurrence and impacts</li> </ul> Prioritization of methods (convergence on "best practice")  Functional testing methods (consistent between crosscutting and Automated Fault Detection and Diagnostics (AFDD))	
3-5	Develop and test FDD methods for other/new systems and components <ul style="list-style-type: none"> <li>- Common factor across components – system diagnostics</li> </ul>	Methods of test (ASHRAE)	
5-10			



R&D Program Area: Automated Diagnostics, PM, Comm. & Optimal Control Tools

R&D Project Activity: Commissioning

Team members:

Completed by: Jeff Schein

Years	Activities	Outcomes	Partners
1-2	Field-based case studies	Determine costs and benefits of crosscutting, especially for new buildings. <ul style="list-style-type: none"> <li>- Develop problems for standardized facility tests.</li> </ul>	
3-5	Develop methods for energy-oriented cross-cutting.	Majority of existing test methods address fault of controls and HVAC systems. The proposed work will develop additional tests that address the interaction between systems to help evaluate energy performance of buildings.	
5-10	Environment (re)-discovery	“Plug and Play” nodes on building control networks.  As building layout changes, nodes adapt.  Includes knowledge of other nodes, i.e., where to directly change requirements.	

R&D Program Area: Automated Diagnostics, PM, Comm. & Optimal Control Tools

R&D Project Activity: Tools

Team members:

Completed by:

Years	Activities	Outcomes	Partners
1-2	<p>Simulation programs that model building energy systems and their interactions (HVAC, lighting, on-site generation ...) for crosscutting support.</p> <p>Tools for active crosscutting tests</p> <p>Controls simulations</p> <ul style="list-style-type: none"> <li>- R&amp;D for control strategies and FDD</li> <li>- Design</li> <li>- Education and training</li> </ul> <p>Models</p> <p>Interfaces</p> <p>National web-based access of controls simulation tools</p>		
3-5	Work continues		
5-10	Work continues		

R&D Program Area: Automated Diagnostics, PM, Comm. & Optimal Control Tools

R&D Project Activity: Market Characterization

Team members: Sensors and Controls Breakout Group

Completed by: Michael Brambley

Years	Activities	Outcomes	Partners
1-2	<ul style="list-style-type: none"> <li>• Human “dimensions” research</li> <li>• Identify more detailed stakeholder needs.</li> <li>• Establish consortia with partnerships especially owner/manager/operator.</li> </ul> <p>Building segmentation system (e.g., large/built-up and small/packaged)</p>	<p>Answer Question:</p> <ul style="list-style-type: none"> <li>• “What do people really want?”</li> <li>• Need to know for each key stakeholder and constituency in the building life cycle.</li> </ul> <p>Need to develop solutions that match business models.</p>	
3-5	<p>Link product development life cycle with building life cycle when considering product R&amp;D</p> <ul style="list-style-type: none"> <li>• More value in tools developed collaboratively with product developers, researchers, and building industry representatives.</li> </ul>	<p>Products enter the marketplace.</p>	
5-10	<p>Look for value-added (e.g., disaster mitigation) to combine R&amp;D funding resources.</p>		

## Distribution

### No. of Copies

#### OFFSITE

Don Anderson  
ICF Consulting Inc  
9300 Lee Highway  
Fairfax, VA 22301

Karen Benedek  
TIAX, LLC  
15 Acorn Park  
Cambridge, MA 02140-2328

David Bornside  
Siemens Building Technologies  
1000 Deerfield Parkway  
Buffalo Grove, IL 60089

Joseph Borowiec  
NYSERDA  
Building R&D  
17 Columbia Circle  
Albany, NY 12203

Martha Brook  
California Energy Commission  
MS-42  
1516 Ninth Street  
Sacramento, CA 95814

Karl Brown  
California Institute for Energy Efficiency  
1333 Broadway Suite 240  
Oakland, CA 94612

Steven Bushby  
NIST  
Building Environment Division (863)  
100 Bureau Drive, Stop 8631  
Gaithersburg, MD 20899-8631

Ronald Caffrey  
BCS Partners  
2008 Carolina Circle N.E.  
St. Petersburg, FL 33703

Michael Chapman  
Naval Facilities Engineering Command  
Design Policy/Architecture  
1322 Patterson Avenue, SE  
Washington Navy Yard  
Washington, DC 20374-5065

David Claridge  
Texas A&M University  
Department of Mechanical Engineering  
College Station, TX 77843-3123

Dru Crawley  
U.S. Department of Energy  
1000 Independence Ave, SW, EE-2J  
Washington, DC 20585

Paul Ewing  
RF & Microwave Systems Group  
Oak Ridge National Laboratory  
One Bethel Valley Road  
Building 3500 MS 6006 Room B18  
PO Box 2008  
Oak Ridge, TN 37831-6006

Kevin Finnegan  
Battery Park City Authority  
One World Financial Center  
New York, NY 10281-1097

Theo Frutiger  
Siemens Building Technologies  
Siemens SBT HVAC Products  
1000 Deerfield Parkway  
Buffalo Grove, IL 60089

Vijay Gupta  
U.S. General Services Administration  
Office of the Chief Architect  
1800 F Street, NW  
Washington, DC 20405

20 David Hansen  
U.S. Department of Energy  
1000 Independence Ave, SW, EE-2J  
Washington, DC 20585

Tom Hartman  
The Hartman Company  
9905 39th Drive NE  
Marysville, WA 98270

- 5 Philip Haves  
Lawrence Berkeley National Laboratory  
Building 90, MS 90-3074  
1 Cyclotron Road  
Berkeley, CA 94720
- 5 David Holmberg  
NIST  
Building Environment Division (863)  
100 Bureau Drive, Stop 8631  
Gaithersburg, MD 20899-8631
- John House  
Iowa Energy Center  
Suite 124  
2521 Elwood Drive  
Ames, Iowa 50010-8263
- Steve Karg  
Lithonia Lighting  
One Lithonia Way  
Building 1  
Decatur, GA 30035
- Roger Kisner  
Oak Ridge National Laboratory  
One Bethel Valley Road  
Building 37831 MS 6004  
P.O. Box 2008  
Oak Ridge, TN 37831-6004
- Ron Lewis  
U.S. Department of Energy  
1000 Independence Ave, SW, EE-2J  
Washington, DC 20585
- Eric Lightner  
U.S. Department of Energy  
Office of Electric Transmission and  
Distribution  
1000 Independence Ave, SW, EE-2D  
Washington, DC 20585
- Vivian Loftness  
Carnegie Mellon University  
Architecture Department  
Head of the School of Architecture  
500 Forbes Avenue  
4919 Frew St. Room 201  
Pittsburgh, PA 15213
- Tom Lohner  
Teng & Associates  
4050 Innslake Drive  
Suite 300  
Glen Allen, VA 23060-3327
- John McKissack  
The Kele Companies  
3300 Brother Boulevard  
Memphis, TN 38133
- Terrence McMahon  
BCS Partners  
135 Fort Lee Road  
Leonia, NY 07605
- Mark Myers  
United Technologies Research Center  
411 Silver Lane  
Mail Stop 129-85  
East Hartford, CT 06108
- 5 Kurt Roth  
TIAX, LLC  
15 Acorn Park  
Cambridge, MA 02140-2328
- John Ryan  
U.S. Department of Energy  
1000 Independence Ave, SW, EE-2J  
Washington, DC 20585
- Harvey Sachs  
ACEEE  
Buildings Programs  
1001 Connecticut Ave NW, Suite 801  
Washington, DC 20036
- Michael K. Sahn  
United Technologies Research Center  
411 Silver Lane  
Mail Stop 129-65  
East Hartford, CT 06108
- Jeffrey Schein  
NIST  
Building Environment Division (863)  
100 Bureau Drive, Stop 8631  
Gaithersburg, MD 20899-8631
- John Seem  
Johnson Controls  
507 East Michigan Street  
Mail Stop M36  
Milwaukee, WI 53202
- Sandy Smith  
ACEEE  
Buildings Programs  
1001 Connecticut Ave NW, Suite 801  
Washington, DC 20036

	Mike Stein Mike Stein Associates 40 Alize Drive Kinnelon, NJ 07504	<b>No. of Copies</b>	
		<b>ONSITE</b>	
	Randal Stites Hines GS Properties, Inc. 901 D. Street, SW Box 18, Suite 290 Washington, DC 20024-2169	<b>29 Pacific Northwest National Laboratory</b>	
		Michael Brambley (5)	K5-16
		Sean McDonald (20)	BWO
		Marylyn Placet	BWO
		Theresa Gilbride	BPO
		Information Release Office (2)	P8-55
5	Paul Torcellini National Renewable Energy Laboratory 1617 Cole Blvd Mail Stop 2722 Golden, CO 80401-3393		
	Stephen Treado NIST Building Environment Division (863) 1000 Bureau Drive, Stop 8631 Gaithersburg, MD 20899-8631		
	Martin Weiland ASHRAE 1828 L St. N.W., Suite 906 Washington, DC 20036-5104		
	Robert Williams Continental Automated Buildings Association (CABA) 4200 NW 74th Court P.O. Box 901525 Kansas City, MO 64151		

