

# Cost-Effectiveness of ASHRAE Standard 90.1-2010 for the State of Texas

R Hart

J Zhang

SA Loper

MI Rosenberg

EE Richman

M Myer

Y Xie

DB Elliott

November 2013



**Pacific Northwest**  
NATIONAL LABORATORY

*Proudly Operated by **Battelle** Since 1965*

# ASHRAE Standard 90.1-2010 Provides Cost-Effective Savings for Commercial Buildings in the State of Texas

Moving to the ANSI/ASHRAE/IES Standard 90.1-2010 version from the Base Code (90.1-2007) is cost-effective for all building types and climate zones in the State of Texas.

Table 1 shows the statewide economic impact of upgrading to 90.1-2010 in terms of the annual energy cost savings in dollars per square foot, the additional cost per square foot required by the upgrade, and the simple payback period in years. Average values are weighted averages for all building types considered in all climate zones in the state, based on weightings shown in Table 6.

Table 1. Texas Average Savings and Cost Weighted by Climate Zone and Building Type

Weighted Cost Savings and Added Cost per Square Foot	
Annual Cost Savings, \$/ft <sup>2</sup>	\$0.237
Added Construction Cost, \$/ft <sup>2</sup>	\$1.465
State of Texas Average Simple Payback, years	6.2

The report provides analysis of two Life Cycle Cost (LCC) scenarios:

**Scenario 1**, representing publicly-owned buildings, considers initial costs, energy, maintenance and replacement costs without borrowing or taxes.

**Scenario 2**, representing privately-owned buildings, adds borrowing costs and tax impacts.

Table 2 shows the statewide weighted average LCC net present value of savings from both scenarios, that is, the remaining savings after initial and replacement costs have been paid for. Average values are weighted averages of all climate zones and building types in the state as shown in Table 6. Individual building type LCC results are shown in Figures 1 and 2.

Table 2. Texas Average LCC Results Weighted by Climate Zone and Building Type

Weighted Net Life Cycle Cost Savings, by Ownership Scenario	
Scenario 1 (Publicly-Owned), \$/ft <sup>2</sup>	\$2.47
Scenario 2 (Privately-Owned), \$/ft <sup>2</sup>	\$3.16

Figure 1. Scenario 1: Net Life Cycle Cost Savings





Figure 2. Scenario 2: Net Life Cycle Cost Savings



# Cost-Effectiveness Results for Standard 90.1-2010 in the State of Texas

Life Cycle Cost (LCC) savings is the primary measure DOE uses to assess the economic impact of building energy codes.

**Savings are computed for two scenarios:**

**Scenario 1 (publicly-owned)** includes costs for initial equipment and construction, energy, maintenance and replacement and does not include loans or taxes.

**Scenario 2 (privately-owned)** includes the same costs as scenario 1 plus the initial investment is financed through a loan amortized over 30 years with corresponding tax deductions for interest and depreciation. Federal and state corporate income tax rates are applied.

Both scenarios include the residual value of equipment with remaining useful life at the end of the 30 years. Totals for building types, climate zones, and the state overall are averages based on Table 6 weightings.

Factors such as inflation and discount rates are different between the two scenarios, as described in the Cost-Effectiveness Methodology section.

**Table 3** shows that the value today of the total LCC savings over 30 years for buildings in scenario 1 average \$2.47 per square foot for 90.1-2010.

**Table 4** shows that the LCC savings over 30 years average \$3.16 per square foot for scenario 2.

**Table 5** shows that the primary benefit of ASHRAE Standard 90.1-2010, annual energy cost savings, average \$0.237 per square foot for both scenarios.

Table 3. LCC Savings (30 Years) from ASHRAE Standard 90.1-2010, Scenario 1 (\$/ft<sup>2</sup>)

Climate Zone & Representative City	Small Office	Large Office	Stand-Alone Retail	Primary School	Small Hotel	Mid-rise Apartment	All Building Types
2A Houston	\$1.79	\$3.51	\$1.84	\$5.66	\$2.56	\$0.44	\$2.52
2B San Antonio	\$1.67	\$2.76	\$1.80	\$5.61	\$2.59	\$0.49	\$3.80
3A Fort Worth	\$1.75	\$3.37	\$1.46	\$5.45	\$2.47	\$0.53	\$2.36
3B El Paso	\$1.73	\$2.38	\$1.77	\$5.48	\$2.58	\$0.39	\$2.49
4B Amarillo	\$1.52	\$2.96	\$1.52	\$5.31	\$2.63	\$0.65	\$1.98
All Climate Zones	\$1.77	\$3.44	\$1.69	\$5.57	\$2.54	\$0.47	\$2.47

Table 4. LCC Savings (30 Years) from ASHRAE Standard 90.1-2010, Scenario 2 (\$/ft<sup>2</sup>)

Climate Zone & Representative City	Small Office	Large Office	Stand-Alone Retail	Primary School	Small Hotel	Mid-rise Apartment	All Building Types
2A Houston	\$2.28	\$3.78	\$3.33	\$5.80	\$2.54	\$0.62	\$3.24
2B San Antonio	\$2.16	\$2.82	\$2.98	\$5.51	\$2.58	\$0.67	\$4.17
3A Fort Worth	\$2.25	\$3.61	\$2.88	\$5.53	\$2.44	\$0.71	\$3.05
3B El Paso	\$2.21	\$2.65	\$2.76	\$5.35	\$2.52	\$0.57	\$2.98
4B Amarillo	\$2.16	\$3.24	\$2.54	\$5.22	\$2.51	\$0.78	\$2.70
All Climate Zones	\$2.26	\$3.70	\$3.11	\$5.67	\$2.51	\$0.65	\$3.16

Table 5. Annual Energy Cost Savings from ASHRAE Standard 90.1-2010, Scenarios 1 and 2 (\$/ft<sup>2</sup>)

Climate Zone & Representative City	Small Office	Large Office	Stand-Alone Retail	Primary School	Small Hotel	Mid-rise Apartment	All Building Types
2A Houston	\$0.166	\$0.248	\$0.323	\$0.331	\$0.132	\$0.047	\$0.245
2B San Antonio	\$0.160	\$0.169	\$0.267	\$0.274	\$0.135	\$0.050	\$0.251
3A Fort Worth	\$0.165	\$0.236	\$0.292	\$0.308	\$0.123	\$0.052	\$0.231
3B El Paso	\$0.160	\$0.178	\$0.229	\$0.259	\$0.122	\$0.044	\$0.195
4B Amarillo	\$0.171	\$0.208	\$0.222	\$0.257	\$0.118	\$0.050	\$0.203
All Climate Zones	\$0.165	\$0.242	\$0.304	\$0.316	\$0.128	\$0.049	\$0.237

The U.S. Department of Energy (DOE) provides estimates of energy and cost savings from code adoption at the National, Climate Zone, and State levels. For more information on how these estimates were developed, visit the DOE Building Energy Codes website:

[www.energycodes.gov/development/commercial](http://www.energycodes.gov/development/commercial)

**U.S Department of Energy**  
Energy Efficiency and Renewable Energy  
BUILDING TECHNOLOGIES OFFICE

**EERE Information Center**  
1-877-EERE-INFO (1-877-337-3463)  
[www.eere.energy.gov/informationcenter](http://www.eere.energy.gov/informationcenter)

**Building Energy Codes**  
For information on Building Energy Codes, visit [www.energycodes.gov](http://www.energycodes.gov)

# Costs and Weightings for Standard 90.1-2010 in the State of Texas

## Construction Weighting of Results

Energy and economic impacts were determined and reported separately for each building type and climate zone. Cost-effectiveness results are also reported as averages for all prototypes and climate zones in the state. To determine these averages, results were combined across the different building types and climate zones using weighting factors shown in Table 6. These weighting factors are based on the floor area of new construction and major renovations for the six analyzed building prototypes in state-specific climate zones. The weighting factors were developed from construction start data from 2003 to 2007 based on an approach developed by Jarnagin and Bandyopadhyay (McGraw Hill Construction 2007, Jarnagin and Bandyopadhyay 2009).

Table 6. Construction Weights by Building Type

Climate Zone & Representative City	Small Office	Large Office	Stand-Alone Retail	Primary School	Small Hotel	Mid-rise Apartment	All Building Types
2A Houston	7.8%	4.2%	21.3%	10.9%	2.6%	8.7%	55.4%
2B San Antonio	0.1%	0.0%	0.4%	0.7%	0.1%	0.0%	1.3%
3A Fort Worth	5.6%	3.5%	14.2%	7.2%	1.2%	5.3%	37.0%
3B El Paso	0.9%	0.0%	2.1%	1.1%	0.5%	0.5%	5.1%
4B Amarillo	0.1%	0.0%	0.8%	0.1%	0.2%	0.0%	1.2%
All Climate Zones	14.5%	7.7%	38.9%	19.9%	4.5%	14.5%	100.0%

## Incremental Construction Cost

Cost estimates were developed for the differences between the Base Code and ASHRAE Standard 90.1-2010 as implemented in the six prototype models. Costs for the initial construction include material, labor, commissioning, construction equipment, overhead and profit. These costs were developed using a commercial cost estimation firm, engineering design consultants and RS Means 2012 Cost Data (RS Means 2012a,b,c; 2004, Thornton et al. 2013).

Table 7 shows incremental initial cost for individual building types in state-specific climate zones and weighted average costs by climate zone and building type for moving to ASHRAE Standard 90.1-2010 from the Base Code. The incremental cost may be negative for some building types and climate zones based on the downsizing of HVAC equipment resulting from reductions in heating and cooling loads due to improvements in ASHRAE Standard 90.1-2010, such as more efficient lighting systems and changes in the building thermal envelope.

Table 7. Incremental Construction Cost of ASHRAE 90.1-2010 (\$/ft<sup>2</sup>)

Climate Zone & Representative City	Small Office	Large Office	Stand-Alone Retail	Primary School	Small Hotel	Mid-rise Apartment	All Building Types
2A Houston	\$1.183	(\$0.001)	\$3.342	(\$0.110)	(\$0.173)	\$0.433	\$1.489
2B San Antonio	\$1.192	(\$0.335)	\$2.874	(\$0.333)	(\$0.171)	\$0.439	\$0.842
3A Fort Worth	\$1.200	(\$0.064)	\$3.347	(\$0.235)	(\$0.182)	\$0.442	\$1.474
3B El Paso	\$1.153	\$0.227	\$2.589	(\$0.382)	(\$0.231)	\$0.432	\$1.220
4B Amarillo	\$1.655	\$0.226	\$2.635	(\$0.272)	(\$0.370)	\$0.290	\$1.850
All Climate Zones	\$1.192	(\$0.029)	\$3.283	(\$0.178)	(\$0.189)	\$0.436	\$1.465

Table 8 shows simple payback results in years. Simple payback is the number of years required for energy cost savings to exceed the incremental first costs of a new code or code change proposals. Simple payback is not used as a measure of cost-effectiveness as it does not account for the time value of money, the value of energy cost savings that occur after payback is achieved, or any maintenance or replacement costs that occur after the initial investment.

Table 8. Simple Payback from ASHRAE Standard 90.1-2010, Scenarios 1 and 2 (Years)

Climate Zone & Representative City	Small Office	Large Office	Stand-Alone Retail	Primary School	Small Hotel	Mid-rise Apartment	All Building Types
2A Houston	7.1	Immediate	9.7	Immediate	Immediate	9.2	6.1
2B San Antonio	7.4	Immediate	10.1	Immediate	Immediate	8.7	3.4
3A Fort Worth	7.2	Immediate	10.6	Immediate	Immediate	8.4	6.4
3B El Paso	7.1	1.3	11.1	Immediate	Immediate	9.7	6.3
4B Amarillo	9.6	1.1	11.6	Immediate	Immediate	5.8	9.1
All Climate Zones	7.2	Immediate	10.8	Immediate	Immediate	9.0	6.2

## Cost-Effectiveness Methodology for Standard 90.1 in the State of Texas

LCC savings is the primary measure DOE uses to assess the cost-effectiveness of building energy codes.

### Cost-Effectiveness

DOE uses standard economic Life Cycle Cost (LCC) cost-effectiveness analysis methods in comparing ASHRAE Standard 90.1-2010 and the Base Code.

**LCC Savings:** LCC is the calculation of the present value of costs over a 30-year period including initial equipment and construction costs, energy savings, maintenance and replacement costs, and residual value of components at the end of the 30-year period. A separate LCC is determined for the Base Code and for ASHRAE Standard 90.1-2010. The LCC savings is the Base Code LCC minus the ASHRAE Standard 90.1-2010 LCC. Two cost scenarios are analyzed:

**Scenario 1** includes the costs listed above without borrowing or taxes.

**Scenario 2** includes the same costs as scenario 1 plus financing of the incremental costs through increased borrowing with associated tax impacts including mortgage interest deductions and depreciation. Corporate tax rates are applied.

Economic analysis factors such as discount rates are also different, as described in Table 10.

While not a true cost-effectiveness metric, Simple Payback is also calculated. Simple payback is the number of years required for accumulated annual energy cost savings to exceed the incremental first costs of a new code.

This analysis demonstrates that for all building types and climate zones in the State of Texas, ASHRAE Standard 90.1-2010 results in savings over the Base Code (ASHRAE Standard 90.1-2007).

**Hence, ASHRAE Standard 90.1-2010 is cost-effective in the State of Texas.**

The cost-effectiveness analysis compares the cost for new buildings meeting ASHRAE Standard 90.1-2010 compared to new buildings meeting a Base Code, ASHRAE Standard 90.1-2007 (ASHRAE 2010, ASHRAE 2007). The analysis includes energy savings estimates from building energy simulations and life cycle cost (LCC) and simple payback calculations using standard economic analysis parameters. The analysis builds on work documented in *Achieving the 30% Goal: Energy and Cost Savings Analysis of ASHRAE Standard 90.1-2010* (Thornton et al. 2011), and the cost-effectiveness analysis documented in *Cost-effectiveness of ASHRAE Standard 90.1-2010 Compared to ASHRAE Standard 90.1-2007* (Thornton et al. 2013).

### Building Prototypes and Energy Modeling

The cost-effectiveness analysis uses six building types represented by six “prototype” building energy models. These six are a subset of 16 prototype building energy models and represent 80% of commercial floor space. These models provide coverage of the significant changes in ASHRAE Standard 90.1 from 2007 to 2010 and are used to show the impacts of the changes on energy savings. The prototypes represent common construction practice and include the primary conventional heating, ventilating and air-conditioning (HVAC) systems most commonly used in commercial buildings. More information on the prototype buildings and savings analysis can be found at: [www.energycodes.gov/development/commercial/90.1\\_models](http://www.energycodes.gov/development/commercial/90.1_models).

Each prototype building is analyzed for each of the climate zones found within the state. Using the U.S. Department of Energy (DOE) EnergyPlus™ software, the six building prototypes summarized in Table 9 are simulated with characteristics meeting the requirements of the Base Code (ASHRAE Standard 90.1-2007) and then modified to meet the requirements of the next edition of the code (ASHRAE Standard 90.1-2010). The energy use and cost is then compared between the two sets of models.

**Table 9. Building Prototypes**

Building Prototype	Floor Area (ft <sup>2</sup> )	Number of Floors
Small Office	5,500	1
Large Office	498,640	13
Stand-Alone Retail	24,690	1
Primary School	73,970	1
Small Hotel	43,210	4
Mid-rise Apartment	33,740	4

### Climate Zones

Climate zones are defined in ASHRAE Standard 90.1 and include eight primary climate zones, the hottest being climate zone 1 and the coldest being climate zone 8. Letters A, B, and C are applied in some cases to denote the level of moisture, with A indicating moist or humid, B indicating dry, and C indicating marine. Figure 3 shows the national climate zones. For this state analysis, savings is analyzed for each climate zone in the state using weather data from a selected city within the climate zone and state, or where necessary, a city in an adjoining state with more robust weather data. The cities used are shown in Tables 3 through 8.



**Table 10. LCC Economic Parameters**

Economic Parameter	Scenario 1	Scenario 2
Study Period – Years <sup>1</sup>	30	30
Nominal Discount Rate <sup>2</sup>	3.90%	6.00%
Real Discount Rate <sup>2</sup>	3.00%	4.60%
Inflation <sup>3</sup>	0.90%	1.30%
Electricity Prices <sup>4</sup> per kWh	\$0.0817	\$0.0817
Natural Gas Prices <sup>4</sup> per therm	\$0.6700	\$0.6700
Energy Price Escalation Factors <sup>5</sup>	<i>Uniform present value factors</i>	<i>Annual escalation factors</i>
Electricity Price Escalation <sup>5</sup>	18.88	1.50%/year
Natural Gas Price Escalation <sup>5</sup>	20.90	2.72%/year
Loan Interest Rate <sup>6</sup>	NA	6.00%
Federal Corporate Tax Rate <sup>7</sup>	NA	34.00%
State Corporate Tax Rate <sup>8</sup>	NA	1.00%
Combined Income Tax Impact <sup>9</sup>	NA	34.66%
State and Average Local Sales Tax <sup>10</sup>	7.95%	7.95%

<sup>1</sup> A 30-year study period captures most building components useful lives and is a commonly used study period for building project economic analysis. This period is consistent with previous and related National 90.1 cost-effectiveness analysis (Thornton et al. 2013). It is also consistent with the cost-effectiveness analysis that was done for the residential energy code as described in multiple state reports and a summary report (DOE 2012). The federal building LCC method uses 25 years and the ASHRAE Standard 90.1 development process uses up to 40 years for building envelope code improvement analysis. Because of the time value of money, results are typically similar for any study periods of 20 years or more.

<sup>2</sup> The scenario 1 real and nominal discount rates are from the National Institute of Standards and Technology (NIST) 2011 annual LCC update for the federal LCC method (Rushing et al. 2011). The scenario 2 nominal discount rate is assumed to be the marginal cost of capital, which is set equal to the assumed loan interest rate (see footnote 6). The real discount rate is calculated from the nominal discount rate and inflation.

<sup>3</sup> The scenario 1 effective inflation rate is from the NIST 2011 annual LCC update for the federal LCC method (Rushing et al. 2011) consistent with the ASHRAE Standard 90.1 national cost-effectiveness analysis 30-year LCC analysis (Thornton et al. 2013). The scenario 2 inflation rate is the Producer Price Index for non-residential construction, February 2012 to February 2013 (Bureau of Labor Statistics 2013).

<sup>4</sup> Scenario 1 and 2 electricity and natural gas prices are state average prices from the United States Energy Information Agency (EIA) *Energy Outlook 2012* (EIA 2012).

<sup>5</sup> Scenario 1 energy price escalation rates are from NIST 2011 annual update for the FEMP LCC method (Rushing et al. 2011) consistent with the ASHRAE Standard 90.1 national cost-effectiveness 30-year LCC analysis (Thornton et al. 2013). The NIST uniform present value factors are multiplied by the first year annual energy cost to determine the present value of 30 years of energy costs and are based on a series of different annual escalation rates for 30 years. Scenario 2 uses national average annual real electricity price escalation rates for 2011 to 2040 (EIA 2013), 0.2% for electricity and 1.4% for natural gas. EIA publishes regional, but not state-specific, escalation rates; the regional rates are estimates and thought to not add additional accuracy to the state-level economic estimates. The effective nominal escalation rates calculated using the scenario 2 inflation rate of 1.3% are shown in the table above.

<sup>6</sup> The loan interest rate is estimated from multiple online sources listed in the references (Capital Funders 2012, Commercial Loan Direct 2013, and Steelhead Capital 2013).

<sup>7</sup> The highest federal marginal corporate income tax rate is assumed to apply.

<sup>8</sup> The highest marginal state corporate income tax rate is assumed to apply from the Federation of Tax Administrators (FTA 2013).

<sup>9</sup> The combined tax impact is based on state tax being a deduction for federal tax, and is applied to depreciation and loan interest.

<sup>10</sup> The state and average local sales tax is included in material costs in the cost estimate.

**Detailed Energy Use and Cost**

On the following pages, specific detailed results for Texas are included:

Table 11 shows the average energy rates used.

Tables 12.A and 12.B show the per square foot energy costs for 90.1-2007 and 90.1-2010 and the cost savings from 90.1-2010.

Tables 13.A and 13.B show the per square foot energy use for 90.1-2007 and 90.1-2010 and the use savings from 90.1-2010.

Tables 14.A through 14.E show the energy end use by energy type for each climate zone in the state.

**Table 11. Energy Rates for the State of Texas, Average \$ per unit**

Electricity	\$0.0817	kWh
Gas	\$0.6700	therm

Source: Energy Information Administration (EIA 2012)

**Table 12.A. Energy Cost Saving Results for ASHRAE Standard 90.1 in the State of Texas, \$ per square foot**

Climate Zone:	2A				2B				3A			
Code:	90.1-2007	90.1-2010	Savings		90.1-2007	90.1-2010	Savings		90.1-2007	90.1-2010	Savings	
<b>Small Office</b>												
Electricity	\$1.002	\$0.836	\$0.166	16.6%	\$0.952	\$0.793	\$0.160	16.8%	\$0.972	\$0.807	\$0.165	17.0%
Gas	\$0.000	\$0.000	\$0.000	-	\$0.000	\$0.000	\$0.000	-	\$0.001	\$0.001	\$0.000	0.0%
Totals	\$1.002	\$0.837	\$0.166	16.6%	\$0.952	\$0.793	\$0.160	16.8%	\$0.973	\$0.807	\$0.165	17.0%
<b>Large Office</b>												
Electricity	\$1.976	\$1.735	\$0.241	12.2%	\$1.918	\$1.756	\$0.162	8.4%	\$1.906	\$1.682	\$0.224	11.8%
Gas	\$0.021	\$0.013	\$0.007	33.3%	\$0.019	\$0.013	\$0.007	36.8%	\$0.030	\$0.018	\$0.012	40.0%
Totals	\$1.996	\$1.748	\$0.248	12.4%	\$1.937	\$1.768	\$0.169	8.7%	\$1.936	\$1.700	\$0.236	12.2%
<b>Stand-Alone Retail</b>												
Electricity	\$1.439	\$1.124	\$0.315	21.9%	\$1.393	\$1.121	\$0.272	19.5%	\$1.371	\$1.099	\$0.271	19.8%
Gas	\$0.045	\$0.037	\$0.008	17.8%	\$0.043	\$0.047	-\$0.004	-9.3%	\$0.066	\$0.045	\$0.020	30.3%
Totals	\$1.484	\$1.161	\$0.323	21.8%	\$1.435	\$1.168	\$0.267	18.6%	\$1.436	\$1.145	\$0.292	20.3%
<b>Primary School</b>												
Electricity	\$1.447	\$1.138	\$0.309	21.4%	\$1.365	\$1.116	\$0.249	18.2%	\$1.346	\$1.071	\$0.275	20.4%
Gas	\$0.079	\$0.057	\$0.022	27.8%	\$0.079	\$0.054	\$0.025	31.6%	\$0.099	\$0.066	\$0.033	33.3%
Totals	\$1.526	\$1.195	\$0.331	21.7%	\$1.444	\$1.169	\$0.274	19.0%	\$1.445	\$1.137	\$0.308	21.3%
<b>Small Hotel</b>												
Electricity	\$1.126	\$0.993	\$0.133	11.8%	\$1.129	\$0.994	\$0.135	12.0%	\$1.092	\$0.967	\$0.124	11.4%
Gas	\$0.134	\$0.135	-\$0.001	-0.7%	\$0.134	\$0.135	-\$0.001	-0.7%	\$0.141	\$0.142	-\$0.001	-0.7%
Totals	\$1.260	\$1.128	\$0.132	10.5%	\$1.263	\$1.129	\$0.135	10.7%	\$1.233	\$1.110	\$0.123	10.0%
<b>Mid-rise Apartment</b>												
Electricity	\$1.035	\$0.990	\$0.044	4.3%	\$1.050	\$1.002	\$0.047	4.5%	\$1.018	\$0.972	\$0.046	4.5%
Gas	\$0.011	\$0.008	\$0.002	18.2%	\$0.011	\$0.009	\$0.003	27.3%	\$0.024	\$0.019	\$0.006	25.0%
Totals	\$1.045	\$0.998	\$0.047	4.5%	\$1.061	\$1.011	\$0.050	4.7%	\$1.043	\$0.990	\$0.052	5.0%



**Table 12.B. Energy Cost Saving Results for ASHRAE Standard 90.1 in the State of Texas, \$ per square foot**

Climate Zone:	3B				4B			
Code:	90.1-2007	90.1-2010	Savings		90.1-2007	90.1-2010	Savings	
<b>Small Office</b>								
Electricity	\$0.917	\$0.757	\$0.160	17.4%	\$0.951	\$0.780	\$0.170	17.9%
Gas	\$0.000	\$0.000	\$0.000	-	\$0.002	\$0.001	\$0.001	50.0%
Totals	\$0.917	\$0.757	\$0.160	17.4%	\$0.953	\$0.781	\$0.171	17.9%
<b>Large Office</b>								
Electricity	\$1.895	\$1.722	\$0.173	9.1%	\$1.868	\$1.672	\$0.196	10.5%
Gas	\$0.016	\$0.011	\$0.005	31.3%	\$0.040	\$0.028	\$0.012	30.0%
Totals	\$1.910	\$1.733	\$0.178	9.3%	\$1.907	\$1.699	\$0.208	10.9%
<b>Standalone Retail</b>								
Electricity	\$1.274	\$1.040	\$0.235	18.4%	\$1.264	\$1.033	\$0.231	18.3%
Gas	\$0.040	\$0.045	-\$0.006	-15.0%	\$0.075	\$0.084	-\$0.009	-12.0%
Totals	\$1.314	\$1.085	\$0.229	17.4%	\$1.339	\$1.117	\$0.222	16.6%
<b>Primary School</b>								
Electricity	\$1.243	\$1.015	\$0.228	18.3%	\$1.224	\$1.012	\$0.212	17.3%
Gas	\$0.085	\$0.053	\$0.032	37.6%	\$0.115	\$0.070	\$0.045	39.1%
Totals	\$1.328	\$1.069	\$0.259	19.5%	\$1.339	\$1.082	\$0.257	19.2%
<b>Small Hotel</b>								
Electricity	\$1.043	\$0.921	\$0.123	11.8%	\$1.049	\$0.930	\$0.119	11.3%
Gas	\$0.139	\$0.139	-\$0.001	-0.7%	\$0.151	\$0.152	-\$0.001	-0.7%
Totals	\$1.182	\$1.060	\$0.122	10.3%	\$1.199	\$1.082	\$0.118	9.8%
<b>Mid-rise Apartment</b>								
Electricity	\$1.001	\$0.959	\$0.042	4.2%	\$1.005	\$0.968	\$0.037	3.7%
Gas	\$0.009	\$0.007	\$0.002	22.2%	\$0.043	\$0.030	\$0.012	27.9%
Totals	\$1.010	\$0.966	\$0.044	4.4%	\$1.048	\$0.998	\$0.050	4.8%

**Table 13.A. Energy Use Saving Results for ASHRAE Standard 90.1 in the State of Texas, Energy Use per Square Foot**

Climate Zone:	2A				2B				3A			
Code:	90.1-2007	90.1-2010	Savings		90.1-2007	90.1-2010	Savings		90.1-2007	90.1-2010	Savings	
<b>Small Office</b>												
Electricity, kWh/ft <sup>2</sup>	12.267	10.238	2.029	16.5%	11.655	9.701	1.954	16.8%	11.893	9.872	2.021	17.0%
Gas, therm/ft <sup>2</sup>	0.000	0.000	0.000	-	0.000	0.000	0.000	-	0.001	0.001	0.000	0.0%
Totals, kBtu/ft <sup>2</sup>	41.895	34.975	6.921	16.5%	39.820	33.149	6.671	16.8%	40.716	33.821	6.895	16.9%
<b>Large Office</b>												
Electricity, kWh/ft <sup>2</sup>	24.184	21.235	2.949	12.2%	23.472	21.492	1.980	8.4%	23.333	20.589	2.744	11.8%
Gas, therm/ft <sup>2</sup>	0.031	0.020	0.011	35.5%	0.029	0.019	0.010	34.5%	0.045	0.026	0.018	40.0%
Totals, kBtu/ft <sup>2</sup>	85.605	74.446	11.159	13.0%	82.993	75.228	7.765	9.4%	84.094	72.897	11.198	13.3%
<b>Stand-Alone Retail</b>												
Electricity, kWh/ft <sup>2</sup>	17.609	13.756	3.854	21.9%	17.045	13.721	3.324	19.5%	16.778	13.456	3.322	19.8%
Gas, therm/ft <sup>2</sup>	0.067	0.055	0.012	17.9%	0.064	0.070	-0.006	-9.4%	0.098	0.068	0.030	30.6%
Totals, kBtu/ft <sup>2</sup>	66.828	52.442	14.387	21.5%	64.543	53.819	10.724	16.6%	67.063	52.678	14.385	21.4%
<b>Primary School</b>												
Electricity, kWh/ft <sup>2</sup>	17.711	13.932	3.779	21.3%	16.706	13.656	3.051	18.3%	16.478	13.110	3.368	20.4%
Gas, therm/ft <sup>2</sup>	0.117	0.085	0.033	28.2%	0.118	0.080	0.038	32.2%	0.147	0.098	0.049	33.3%
Totals, kBtu/ft <sup>2</sup>	72.181	56.006	16.175	22.4%	68.770	54.596	14.174	20.6%	70.988	54.561	16.427	23.1%
<b>Small Hotel</b>												
Electricity, kWh/ft <sup>2</sup>	13.780	12.153	1.628	11.8%	13.821	12.163	1.658	12.0%	13.364	11.842	1.522	11.4%
Gas, therm/ft <sup>2</sup>	0.200	0.201	-0.001	-0.5%	0.200	0.201	-0.001	-0.5%	0.211	0.212	-0.001	-0.5%
Totals, kBtu/ft <sup>2</sup>	67.075	61.611	5.464	8.1%	67.201	61.635	5.566	8.3%	66.717	61.659	5.058	7.6%
<b>Mid-rise Apartment</b>												
Electricity, kWh/ft <sup>2</sup>	12.665	12.122	0.544	4.3%	12.849	12.270	0.579	4.5%	12.462	11.893	0.569	4.6%
Gas, therm/ft <sup>2</sup>	0.016	0.012	0.004	25.0%	0.017	0.013	0.004	23.5%	0.036	0.028	0.008	22.2%
Totals, kBtu/ft <sup>2</sup>	44.799	42.589	2.210	4.9%	45.561	43.180	2.381	5.2%	46.182	43.398	2.784	6.0%

**Table 13.B. Energy Use Saving Results for ASHRAE Standard 90.1 in the State of Texas, Energy Use per Square Foot**

Climate Zone:	3B				4B			
Code:	90.1-2007	90.1-2010	Savings		90.1-2007	90.1-2010	Savings	
<b>Small Office</b>								
Electricity, kWh/ft <sup>2</sup>	11.224	9.260	1.964	17.5%	11.635	9.551	2.085	17.9%
Gas, therm/ft <sup>2</sup>	0.000	0.000	0.000	-	0.003	0.002	0.002	66.7%
Totals, kBtu/ft <sup>2</sup>	38.341	31.643	6.698	17.5%	40.048	32.777	7.271	18.2%
<b>Large Office</b>								
Electricity, kWh/ft <sup>2</sup>	23.189	21.075	2.114	9.1%	22.858	20.464	2.395	10.5%
Gas, therm/ft <sup>2</sup>	0.023	0.016	0.007	30.4%	0.059	0.041	0.018	30.5%
Totals, kBtu/ft <sup>2</sup>	81.480	73.528	7.953	9.8%	83.966	73.965	10.001	11.9%
<b>Standalone Retail</b>								
Electricity, kWh/ft <sup>2</sup>	15.597	12.726	2.871	18.4%	15.468	12.640	2.828	18.3%
Gas, therm/ft <sup>2</sup>	0.059	0.068	-0.009	-15.3%	0.112	0.126	-0.014	-12.5%
Totals, kBtu/ft <sup>2</sup>	59.145	50.207	8.938	15.1%	64.007	55.749	8.259	12.9%
<b>Primary School</b>								
Electricity, kWh/ft <sup>2</sup>	15.213	12.429	2.785	18.3%	14.977	12.384	2.593	17.3%
Gas, therm/ft <sup>2</sup>	0.127	0.079	0.047	37.0%	0.172	0.105	0.067	39.0%
Totals, kBtu/ft <sup>2</sup>	64.577	50.348	14.228	22.0%	68.320	52.735	15.585	22.8%
<b>Small Hotel</b>								
Electricity, kWh/ft <sup>2</sup>	12.768	11.267	1.500	11.7%	12.834	11.381	1.453	11.3%
Gas, therm/ft <sup>2</sup>	0.207	0.208	-0.001	-0.5%	0.225	0.227	-0.002	-0.9%
Totals, kBtu/ft <sup>2</sup>	64.276	59.244	5.032	7.8%	66.294	61.495	4.798	7.2%
<b>Mid-rise Apartment</b>								
Electricity, kWh/ft <sup>2</sup>	12.255	11.738	0.517	4.2%	12.304	11.848	0.456	3.7%
Gas, therm/ft <sup>2</sup>	0.013	0.010	0.003	23.1%	0.064	0.045	0.019	29.7%
Totals, kBtu/ft <sup>2</sup>	43.130	41.075	2.055	4.8%	48.369	44.948	3.421	7.1%

**Table 14.A. Annual Energy Usage for Buildings in the State of Texas in Climate Zone 2A**

Energy End-Use	Small Office		Large Office		Stand-Alone Retail		Primary School		Small Hotel		Mid-rise Apartment	
	Electric kWh/ft <sup>2</sup> -yr	Gas therms/ft <sup>2</sup> -yr	Electric kWh/ft <sup>2</sup> -yr	Gas therms/ft <sup>2</sup> -yr	Electric kWh/ft <sup>2</sup> -yr	Gas therms/ft <sup>2</sup> -yr	Electric kWh/ft <sup>2</sup> -yr	Gas therms/ft <sup>2</sup> -yr	Electric kWh/ft <sup>2</sup> -yr	Gas therms/ft <sup>2</sup> -yr	Electric kWh/ft <sup>2</sup> -yr	Gas therms/ft <sup>2</sup> -yr
<b>Base Code: 90.1-2007</b>												
Heating, Humidification	0.078	0.000	0.056	0.022	0.000	0.032	0.000	0.058	0.193	0.002	0.000	0.016
Cooling	2.335	0.000	5.717	0.000	5.000	0.000	5.398	0.000	3.921	0.000	2.312	0.000
Fans, Pumps, Heat Recovery	1.393	0.000	2.244	0.000	3.605	0.000	1.894	0.000	1.982	0.000	1.930	0.000
Lighting, Interior & Exterior	4.882	0.000	3.413	0.000	6.808	0.000	4.864	0.000	3.814	0.000	1.425	0.000
Plugs, Refrigeration, Other	2.666	0.000	12.753	0.000	2.196	0.000	5.449	0.046	3.870	0.092	4.262	0.000
Service Water Heating (SWH)	0.911	0.000	0.000	0.008	0.000	0.035	0.105	0.013	0.000	0.106	2.737	0.000
<b>Total</b>	<b>12.267</b>	<b>0.000</b>	<b>24.184</b>	<b>0.031</b>	<b>17.609</b>	<b>0.067</b>	<b>17.711</b>	<b>0.117</b>	<b>13.780</b>	<b>0.200</b>	<b>12.665</b>	<b>0.016</b>
<b>ASHRAE 90.1-2010</b>												
Heating, Humidification	0.084	0.000	0.020	0.011	0.000	0.021	0.000	0.025	0.201	0.003	0.000	0.012
Cooling	2.124	0.000	4.594	0.000	3.168	0.000	3.685	0.000	3.364	0.000	2.217	0.000
Fans, Pumps, Heat Recovery	1.290	0.000	1.760	0.000	2.744	0.000	1.550	0.000	1.850	0.000	1.769	0.000
Lighting, Interior & Exterior	3.356	0.000	2.534	0.000	5.653	0.000	3.270	0.000	2.938	0.000	1.189	0.000
Plugs, Refrigeration, Other	2.475	0.000	12.326	0.000	2.190	0.000	5.331	0.046	3.799	0.092	4.211	0.000
Service Water Heating (SWH)	0.910	0.000	0.000	0.008	0.000	0.034	0.097	0.013	0.000	0.106	2.736	0.000
<b>Total</b>	<b>10.238</b>	<b>0.000</b>	<b>21.235</b>	<b>0.020</b>	<b>13.756</b>	<b>0.055</b>	<b>13.932</b>	<b>0.085</b>	<b>12.153</b>	<b>0.201</b>	<b>12.122</b>	<b>0.012</b>
<b>Total Savings</b>	<b>2.029</b>	<b>0.000</b>	<b>2.949</b>	<b>0.011</b>	<b>3.854</b>	<b>0.012</b>	<b>3.779</b>	<b>0.033</b>	<b>1.628</b>	<b>-0.001</b>	<b>0.544</b>	<b>0.004</b>

**Table 14.B. Annual Energy Usage for Buildings in the State of Texas in Climate Zone 2B**

Energy End-Use	Small Office		Large Office		Stand-Alone Retail		Primary School		Small Hotel		Mid-rise Apartment	
	Electric kWh/ft <sup>2</sup> -yr	Gas therms/ft <sup>2</sup> -yr	Electric kWh/ft <sup>2</sup> -yr	Gas therms/ft <sup>2</sup> -yr	Electric kWh/ft <sup>2</sup> -yr	Gas therms/ft <sup>2</sup> -yr	Electric kWh/ft <sup>2</sup> -yr	Gas therms/ft <sup>2</sup> -yr	Electric kWh/ft <sup>2</sup> -yr	Gas therms/ft <sup>2</sup> -yr	Electric kWh/ft <sup>2</sup> -yr	Gas therms/ft <sup>2</sup> -yr
<b>Base Code: 90.1-2007</b>												
Heating, Humidification	0.083	0.000	0.037	0.020	0.000	0.029	0.000	0.058	0.205	0.002	0.000	0.017
Cooling	1.801	0.000	5.156	0.000	4.528	0.000	4.588	0.000	3.918	0.000	2.331	0.000
Fans, Pumps, Heat Recovery	1.312	0.000	2.114	0.000	3.513	0.000	1.701	0.000	2.014	0.000	2.095	0.000
Lighting, Interior & Exterior	4.881	0.000	3.412	0.000	6.808	0.000	4.864	0.000	3.814	0.000	1.425	0.000
Plugs, Refrigeration, Other	2.666	0.000	12.753	0.000	2.196	0.000	5.449	0.046	3.870	0.092	4.262	0.000
Service Water Heating (SWH)	0.911	0.000	0.000	0.008	0.000	0.035	0.105	0.013	0.000	0.106	2.735	0.000
<b>Total</b>	<b>11.655</b>	<b>0.000</b>	<b>23.472</b>	<b>0.029</b>	<b>17.045</b>	<b>0.064</b>	<b>16.706</b>	<b>0.118</b>	<b>13.821</b>	<b>0.200</b>	<b>12.849</b>	<b>0.017</b>
<b>ASHRAE 90.1-2010</b>												
Heating, Humidification	0.088	0.000	0.439	0.010	0.000	0.036	0.000	0.021	0.209	0.003	0.000	0.013
Cooling	1.650	0.000	4.443	0.000	3.305	0.000	3.533	0.000	3.339	0.000	2.233	0.000
Fans, Pumps, Heat Recovery	1.225	0.000	1.752	0.000	2.606	0.000	1.430	0.000	1.877	0.000	1.903	0.000
Lighting, Interior & Exterior	3.354	0.000	2.532	0.000	5.620	0.000	3.265	0.000	2.938	0.000	1.189	0.000
Plugs, Refrigeration, Other	2.474	0.000	12.326	0.000	2.190	0.000	5.331	0.046	3.799	0.092	4.211	0.000
Service Water Heating (SWH)	0.910	0.000	0.000	0.008	0.000	0.034	0.097	0.013	0.000	0.106	2.735	0.000
<b>Total</b>	<b>9.701</b>	<b>0.000</b>	<b>21.492</b>	<b>0.019</b>	<b>13.721</b>	<b>0.070</b>	<b>13.656</b>	<b>0.080</b>	<b>12.163</b>	<b>0.201</b>	<b>12.270</b>	<b>0.013</b>
<b>Total Savings</b>	<b>1.954</b>	<b>0.000</b>	<b>1.980</b>	<b>0.010</b>	<b>3.324</b>	<b>-0.006</b>	<b>3.051</b>	<b>0.038</b>	<b>1.658</b>	<b>-0.001</b>	<b>0.579</b>	<b>0.004</b>

**Table 14.C. Annual Energy Usage for Buildings in the State of Texas in Climate Zone 3A**

Energy End-Use	Small Office		Large Office		Stand-Alone Retail		Primary School		Small Hotel		Mid-rise Apartment	
	Electric kWh/ft <sup>2</sup> -yr	Gas therms/ft <sup>2</sup> -yr	Electric kWh/ft <sup>2</sup> -yr	Gas therms/ft <sup>2</sup> -yr	Electric kWh/ft <sup>2</sup> -yr	Gas therms/ft <sup>2</sup> -yr	Electric kWh/ft <sup>2</sup> -yr	Gas therms/ft <sup>2</sup> -yr	Electric kWh/ft <sup>2</sup> -yr	Gas therms/ft <sup>2</sup> -yr	Electric kWh/ft <sup>2</sup> -yr	Gas therms/ft <sup>2</sup> -yr
<b>Base Code: 90.1-2007</b>												
Heating, Humidification	0.180	0.001	0.132	0.036	0.000	0.062	0.000	0.087	0.423	0.005	0.000	0.036
Cooling	1.910	0.000	4.942	0.000	4.074	0.000	4.287	0.000	3.291	0.000	1.893	0.000
Fans, Pumps, Heat Recovery	1.344	0.000	2.093	0.000	3.700	0.000	1.775	0.000	1.967	0.000	1.972	0.000
Lighting, Interior & Exterior	4.881	0.000	3.412	0.000	6.808	0.000	4.864	0.000	3.813	0.000	1.425	0.000
Plugs, Refrigeration, Other	2.666	0.000	12.753	0.000	2.196	0.000	5.447	0.046	3.870	0.092	4.262	0.000
Service Water Heating (SWH)	0.911	0.000	0.000	0.009	0.000	0.035	0.105	0.014	0.000	0.113	2.910	0.000
<b>Total</b>	<b>11.893</b>	<b>0.001</b>	<b>23.333</b>	<b>0.045</b>	<b>16.778</b>	<b>0.098</b>	<b>16.478</b>	<b>0.147</b>	<b>13.364</b>	<b>0.211</b>	<b>12.462</b>	<b>0.036</b>
<b>ASHRAE 90.1-2010</b>												
Heating, Humidification	0.191	0.001	0.043	0.017	0.000	0.033	0.000	0.038	0.433	0.007	0.000	0.028
Cooling	1.721	0.000	4.062	0.000	2.645	0.000	2.915	0.000	2.831	0.000	1.809	0.000
Fans, Pumps, Heat Recovery	1.237	0.000	1.647	0.000	2.912	0.000	1.551	0.000	1.855	0.000	1.776	0.000
Lighting, Interior & Exterior	3.339	0.000	2.510	0.000	5.708	0.000	3.219	0.000	2.924	0.000	1.188	0.000
Plugs, Refrigeration, Other	2.474	0.000	12.326	0.000	2.190	0.000	5.329	0.046	3.799	0.092	4.211	0.000
Service Water Heating (SWH)	0.910	0.000	0.000	0.009	0.000	0.035	0.097	0.014	0.000	0.113	2.909	0.000
<b>Total</b>	<b>9.872</b>	<b>0.001</b>	<b>20.589</b>	<b>0.026</b>	<b>13.456</b>	<b>0.068</b>	<b>13.110</b>	<b>0.098</b>	<b>11.842</b>	<b>0.212</b>	<b>11.893</b>	<b>0.028</b>
<b>Total Savings</b>	<b>2.021</b>	<b>0.000</b>	<b>2.744</b>	<b>0.018</b>	<b>3.322</b>	<b>0.030</b>	<b>3.368</b>	<b>0.049</b>	<b>1.522</b>	<b>-0.001</b>	<b>0.569</b>	<b>0.008</b>

**Table 14.D. Annual Energy Usage for Buildings in the State of Texas in Climate Zone 3B**

Energy End-Use	Small Office		Large Office		Stand-Alone Retail		Primary School		Small Hotel		Mid-rise Apartment	
	Electric kWh/ft <sup>2</sup> -yr	Gas therms/ft <sup>2</sup> -yr	Electric kWh/ft <sup>2</sup> -yr	Gas therms/ft <sup>2</sup> -yr	Electric kWh/ft <sup>2</sup> -yr	Gas therms/ft <sup>2</sup> -yr	Electric kWh/ft <sup>2</sup> -yr	Gas therms/ft <sup>2</sup> -yr	Electric kWh/ft <sup>2</sup> -yr	Gas therms/ft <sup>2</sup> -yr	Electric kWh/ft <sup>2</sup> -yr	Gas therms/ft <sup>2</sup> -yr
<b>Base Code: 90.1-2007</b>												
Heating, Humidification	0.104	0.000	0.787	0.014	0.000	0.024	0.000	0.067	0.184	0.002	0.000	0.013
Cooling	1.329	0.000	4.199	0.000	2.868	0.000	3.066	0.000	2.868	0.000	1.610	0.000
Fans, Pumps, Heat Recovery	1.331	0.000	2.037	0.000	3.725	0.000	1.735	0.000	2.032	0.000	2.066	0.000
Lighting, Interior & Exterior	4.881	0.000	3.413	0.000	6.808	0.000	4.864	0.000	3.814	0.000	1.426	0.000
Plugs, Refrigeration, Other	2.666	0.000	12.753	0.000	2.196	0.000	5.443	0.046	3.870	0.092	4.262	0.000
Service Water Heating (SWH)	0.911	0.000	0.000	0.009	0.000	0.035	0.105	0.014	0.000	0.113	2.891	0.000
<b>Total</b>	<b>11.224</b>	<b>0.000</b>	<b>23.189</b>	<b>0.023</b>	<b>15.597</b>	<b>0.059</b>	<b>15.213</b>	<b>0.127</b>	<b>12.768</b>	<b>0.207</b>	<b>12.255</b>	<b>0.013</b>
<b>ASHRAE 90.1-2010</b>												
Heating, Humidification	0.110	0.000	1.311	0.007	0.000	0.033	0.000	0.019	0.200	0.003	0.000	0.010
Cooling	1.196	0.000	3.168	0.000	2.164	0.000	2.225	0.000	2.438	0.000	1.570	0.000
Fans, Pumps, Heat Recovery	1.237	0.000	1.769	0.000	2.648	0.000	1.579	0.000	1.906	0.000	1.878	0.000
Lighting, Interior & Exterior	3.333	0.000	2.500	0.000	5.725	0.000	3.201	0.000	2.925	0.000	1.189	0.000
Plugs, Refrigeration, Other	2.474	0.000	12.326	0.000	2.190	0.000	5.327	0.046	3.799	0.092	4.211	0.000
Service Water Heating (SWH)	0.910	0.000	0.000	0.009	0.000	0.035	0.097	0.014	0.000	0.113	2.890	0.000
<b>Total</b>	<b>9.260</b>	<b>0.000</b>	<b>21.075</b>	<b>0.016</b>	<b>12.726</b>	<b>0.068</b>	<b>12.429</b>	<b>0.079</b>	<b>11.267</b>	<b>0.208</b>	<b>11.738</b>	<b>0.010</b>
<b>Total Savings</b>	<b>1.964</b>	<b>0.000</b>	<b>2.114</b>	<b>0.007</b>	<b>2.871</b>	<b>-0.009</b>	<b>2.785</b>	<b>0.047</b>	<b>1.500</b>	<b>-0.001</b>	<b>0.517</b>	<b>0.003</b>

**Table 14.E. Annual Energy Usage for Buildings in the State of Texas in Climate Zone 4B**

Energy End-Use	Small Office		Large Office		Stand-Alone Retail		Primary School		Small Hotel		Mid-rise Apartment	
	Electric kWh/ft <sup>2</sup> -yr	Gas therms/ft <sup>2</sup> -yr	Electric kWh/ft <sup>2</sup> -yr	Gas therms/ft <sup>2</sup> -yr	Electric kWh/ft <sup>2</sup> -yr	Gas therms/ft <sup>2</sup> -yr	Electric kWh/ft <sup>2</sup> -yr	Gas therms/ft <sup>2</sup> -yr	Electric kWh/ft <sup>2</sup> -yr	Gas therms/ft <sup>2</sup> -yr	Electric kWh/ft <sup>2</sup> -yr	Gas therms/ft <sup>2</sup> -yr
<b>Base Code: 90.1-2007</b>												
Heating, Humidification	0.321	0.003	0.747	0.050	0.000	0.076	0.000	0.111	0.744	0.007	0.000	0.064
Cooling	1.417	0.000	3.973	0.000	2.464	0.000	2.791	0.000	2.382	0.000	1.308	0.000
Fans, Pumps, Heat Recovery	1.439	0.000	1.972	0.000	4.001	0.000	1.773	0.000	2.025	0.000	2.143	0.000
Lighting, Interior & Exterior	4.880	0.000	3.412	0.000	6.807	0.000	4.864	0.000	3.813	0.000	1.425	0.000
Plugs, Refrigeration, Other	2.666	0.000	12.753	0.000	2.196	0.000	5.443	0.046	3.870	0.092	4.262	0.000
Service Water Heating (SWH)	0.911	0.000	0.000	0.010	0.000	0.037	0.105	0.015	0.000	0.125	3.166	0.000
<b>Total</b>	<b>11.635</b>	<b>0.003</b>	<b>22.858</b>	<b>0.059</b>	<b>15.468</b>	<b>0.112</b>	<b>14.977</b>	<b>0.172</b>	<b>12.834</b>	<b>0.225</b>	<b>12.304</b>	<b>0.064</b>
<b>ASHRAE 90.1-2010</b>												
Heating, Humidification	0.282	0.002	1.181	0.031	0.000	0.090	0.000	0.043	0.705	0.009	0.000	0.045
Cooling	1.262	0.000	2.727	0.000	1.916	0.000	2.183	0.000	2.065	0.000	1.321	0.000
Fans, Pumps, Heat Recovery	1.316	0.000	1.745	0.000	2.848	0.000	1.633	0.000	1.895	0.000	1.962	0.000
Lighting, Interior & Exterior	3.307	0.000	2.485	0.000	5.687	0.000	3.144	0.000	2.917	0.000	1.188	0.000
Plugs, Refrigeration, Other	2.474	0.000	12.326	0.000	2.190	0.000	5.327	0.046	3.799	0.092	4.211	0.000
Service Water Heating (SWH)	0.910	0.000	0.000	0.010	0.000	0.036	0.097	0.015	0.000	0.125	3.165	0.000
<b>Total</b>	<b>9.551</b>	<b>0.002</b>	<b>20.464</b>	<b>0.041</b>	<b>12.640</b>	<b>0.126</b>	<b>12.384</b>	<b>0.105</b>	<b>11.381</b>	<b>0.227</b>	<b>11.848</b>	<b>0.045</b>
<b>Total Savings</b>	<b>2.085</b>	<b>0.002</b>	<b>2.395</b>	<b>0.018</b>	<b>2.828</b>	<b>-0.014</b>	<b>2.593</b>	<b>0.067</b>	<b>1.453</b>	<b>-0.002</b>	<b>0.456</b>	<b>0.019</b>



## References

- (ASHRAE) ANSI/ASHRAE/IESNA – American National Standards Institute, American Society of Heating, Refrigerating and Air-Conditioning Engineers, and Illuminating Engineering Society of North America. 2007. *ANSI/ASHRAE/IESNA 90.1-2007, Energy Standard for Buildings Except Low-Rise Residential Buildings*. American Society of Heating, Refrigerating and Air-Conditioning Engineers, Atlanta, Georgia.
- (ASHRAE) ANSI/ASHRAE/IES. 2010. *ANSI/ASHRAE/IES 90.1-2010, Energy Standard for Buildings Except Low-Rise Residential Buildings*. American Society of Heating, Refrigerating and Air-Conditioning Engineers, Atlanta, Georgia.
- Bureau of Labor Statistics. 2013. “Producer Price Indexes, Table 6.” Washington, D.C. Accessed March 25, 2013 at [www.bls.gov/ppi/tables.htm](http://www.bls.gov/ppi/tables.htm).
- Capital Funders. 2012. “Commercial Mortgage Rates, April 28, 2012, Start Rate, All.” Chicago, Illinois. Accessed March 25, 2013 at [www.capitalfunders.com/CommercialMortgageRates.htm](http://www.capitalfunders.com/CommercialMortgageRates.htm).
- Commercial Loan Direct. 2013. “Commercial Mortgage Interest Rates - Nationwide Lending, Mid Balance - Investor/Owner Occupied.” Atlanta, Georgia. Accessed March 25, 2013 at [www.commercialloandirect.com/commercial-rates.php](http://www.commercialloandirect.com/commercial-rates.php).
- (DOE) United States Department of Energy. 2012. “Residential IECC Cost Effectiveness Analysis and Results”. U.S. Department of Energy, Washington, D.C. Accessed April 4, 2013 at [www.energycodes.gov/development/residential/iecc\\_analysis](http://www.energycodes.gov/development/residential/iecc_analysis).
- (FTA) Federation of Tax Administrators. 2013. “Range of State Corporate Income Tax Rates.” Washington, D.C. Accessed March 25, 2013 at [www.taxadmin.org/Fta/rate/corp\\_inc.pdf](http://www.taxadmin.org/Fta/rate/corp_inc.pdf).
- Fuller, S.K., and S.R. Petersen. 1995. *Life-Cycle Costing Manual for the Federal Energy Management Program*, NIST Handbook 135. U.S. Department of Commerce, Washington, D.C.
- Jarnagin, R.E., and G.K. Bandyopadhyay. 2010. *Weighting Factors for the Commercial Building Prototypes Used in the Development of ANSI/ASHRAE/IESNA 90.1-2010*. PNNL-19116, Pacific Northwest National Laboratory, Richland, Washington.
- McGraw Hill Construction. 2007. McGraw Hill Construction Database (2003-2007), McGraw Hill Construction, New York, New York (available for purchase at <http://dodge.construction.com/>).
- RS Means. 2012a. *RSMeans Mechanical Cost Data*, 35th Ed. Construction Publishers & Consultants. Norwell, Massachusetts.
- RS Means. 2012b. *RSMeans Electrical Cost Data*, 35th Ed. Construction Publishers & Consultants. Norwell, Massachusetts.
- RS Means. 2012c. *RSMeans Construction Cost Data*, 70th Ed. Construction Publishers & Consultants. Norwell, Massachusetts.
- RS Means. 2004. *RSMeans Facilities, Maintenance and Repair Cost Data*. Construction Publishers & Consultants. Norwell, Massachusetts.
- Rushing, A.S., J.D. Kneifel, B.C. Lippiatt. 2011. *Energy Price Indices and Discount Factors for Life-Cycle Cost Analysis – 2011*. NISTIR 85-3273-26, National Institute of Standards and Technology, Gaithersburg, Maryland.
- Steelhead Capital. 2013. “Commercial Loan Rates, Multi-family, large portfolio, 30 years and Office / Industrial / NNN / Retail / Storage Loans, 7 year fixed, larger size.” San Francisco, California. Accessed March 25, 2013 at [www.steelheadcapital.com/rates](http://www.steelheadcapital.com/rates).
- Thornton, B.A., M.I. Rosenberg, E.E. Richman, W. Wang, Y. Xie, J. Zhang, H. Cho, V.V. Mendon and R.A. Athalye. 2011. *Achieving the 30% Goal: Energy and Cost Savings Analysis of ASHRAE Standard 90.1-2010*. PNNL-20405. Pacific Northwest National Laboratory, Richland, Washington. [www.energycodes.gov/sites/default/files/documents/BECP\\_Energy\\_Cost\\_Savings\\_STD2010\\_May2011\\_v00.pdf](http://www.energycodes.gov/sites/default/files/documents/BECP_Energy_Cost_Savings_STD2010_May2011_v00.pdf)
- Thornton, B.A., H. Cho, D.B. Elliot, M.A. Halverson, S.A. Loper, V.V. Mendon, M. Myer, M.I. Rosenberg, and E.E. Richman. 2013. *National Cost-effectiveness of ASHRAE Standard 90.1-2010 Compared to ASHRAE Standard 90.1-2007*. PNNL-22972. Pacific Northwest National Laboratory, Richland, Washington. [www.energycodes.gov/sites/default/files/documents/PNNL-22972.pdf](http://www.energycodes.gov/sites/default/files/documents/PNNL-22972.pdf)
- (EIA) United States Energy Information Administration. 2012. *Annual Energy Outlook 2012*. DOE/EIA-0383(2012). Energy Information Administration, Washington, D.C. Accessed March 27, 2013 at [www.eia.gov/forecasts/aeo/pdf/0383\(2012\).pdf](http://www.eia.gov/forecasts/aeo/pdf/0383(2012).pdf).
- (EIA) 2013. “Energy Prices by Sector and Source, United States.” Energy Information Administration, Washington, D.C. Accessed April 10, 2013 at [www.eia.gov/oiaf/aeo](http://www.eia.gov/oiaf/aeo).

**U.S Department of Energy**  
Energy Efficiency and Renewable Energy  
BUILDING TECHNOLOGIES OFFICE

**EERE Information Center**  
1-877-EERE-INFO (1-877-337-3463)  
[www.eere.energy.gov/informationcenter](http://www.eere.energy.gov/informationcenter)

**Building Energy Codes**  
For information on Building Energy Codes, visit [www.energycodes.gov](http://www.energycodes.gov)