



U.S. DEPARTMENT OF  
**ENERGY**

PNNL-23063

Prepared for the U.S. Department of Energy

under Contract DE-AC05-76RL01830

# Analysis of Federal Agency Facility Energy Reduction Potential and Goal- Setting Approaches for 2025

KS Judd  
DM Anderson  
DB Belzer

JA Dirks  
BE Ford

May 2014



**Pacific Northwest**  
NATIONAL LABORATORY

*Proudly Operated by **Battelle** Since 1965*

## DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor Battelle Memorial Institute, nor any of their employees, makes **any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights.** Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof, or Battelle Memorial Institute. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

PACIFIC NORTHWEST NATIONAL LABORATORY  
*operated by*  
BATTELLE  
*for the*  
UNITED STATES DEPARTMENT OF ENERGY  
*under Contract DE-AC05-76RL01830*

Printed in the United States of America

Available to DOE and DOE contractors from the  
Office of Scientific and Technical Information,  
P.O. Box 62, Oak Ridge, TN 37831-0062;  
ph: (865) 576-8401  
fax: (865) 576-5728  
email: [reports@adonis.osti.gov](mailto:reports@adonis.osti.gov)

Available to the public from the National Technical Information Service  
5301 Shawnee Rd., Alexandria, VA 22312  
ph: (800) 553-NTIS (6847)  
email: [orders@ntis.gov](mailto:orders@ntis.gov) <<http://www.ntis.gov/about/form.aspx>>  
Online ordering: <http://www.ntis.gov>



This document was printed on recycled paper.

(8/2010)

# **Analysis of Federal Agency Facility Energy Reduction Potential and Goal-Setting Approaches for 2025**

KS Judd  
DM Anderson  
DB Belzer

JA Dirks  
BE Ford

May 2014

Prepared for  
the U.S. Department of Energy  
under Department of Energy Contract DE-AC05-76RL01830  
with Battelle Memorial Institute

Pacific Northwest National Laboratory  
Richland, Washington 99352



## Acronyms and Abbreviations

ARRA	American Recovery and Reinvestment Act
Btu	British thermal units
BBtu	billion British thermal units
CBECS	Commercial Building Energy Consumption Survey
CDD	cooling degree days
DHS	Department of Homeland Security
DOC	Department of Commerce
DOD	Department of Defense
DOE	Department of Energy
DOI	Department of the Interior
DOJ	Department of Justice
DOL	Department of Labor
DOT	Department of Transportation
ECM	energy conservation measure
EISA	Energy Independence and Security Act
EPA	Environmental Protection Agency
EUI	energy use intensity
FEDS	Facility Energy Decision System
FEMP	Federal Energy Management Program
FY	fiscal year
GSA	General Services Administration
GSF	gross square footage
HDD	heating degree days
HHS	Department of Health and Human Services
HUD	Department of Housing and Urban Development
HVAC	heating, ventilating and air conditioning
LCC	life-cycle cost
LPG	liquefied petroleum gas
NARA	National Archives and Records Administration
NASA	National Aeronautics and Space Administration
OMB	Office of Management and Budget
OPM	Office of Personnel Management
PNNL	Pacific Northwest National Laboratory
SF	square foot
SI	Smithsonian Institution
SIR	savings-to-investment ratio

SSA	Social Security Administration
State	Department of State
TMY	typical meteorological year
TRSY	Department of the Treasury
TVA	Tennessee Valley Authority
USACE	Army Corps of Engineers
USDA	Department of Agriculture
USPS	United States Postal Service
VA	Department of Veterans Affairs

# Contents

1.0	Introduction .....	1
2.0	Past Energy Use Reduction Performance .....	1
2.1	Government-wide performance.....	2
2.1.1	Federal progress toward EUI reduction goal with projection out to 2015 .....	2
2.1.2	Observations on Government-wide Trends.....	4
2.1.3	Changes in Energy Use by Fuel Type .....	6
2.2	Agency-specific performance.....	8
2.2.1	Department of Defense.....	10
2.2.2	Department of Energy .....	11
2.2.3	Department of Health and Human Services .....	13
2.2.4	Department of Justice.....	15
2.2.5	Department of Veterans Affairs .....	17
2.2.6	General Services Administration.....	19
2.2.7	United States Postal Service.....	21
3.0	Future Energy Savings Potential in Federal Buildings .....	23
3.1	Existing Building Retrofits.....	23
3.1.1	Modeling Prototype Federal Buildings .....	23
3.1.2	EUIs for Prototype Buildings .....	25
3.1.3	Estimated Energy Savings Potential from Energy Conservation and Efficiency ..	26
3.1.4	Estimated Renewable Energy Production Potential .....	27
3.1.5	Estimated Cost of Implementation.....	28
3.2	Construction of New Buildings.....	30
3.2.1	Newly Constructed Floor Space.....	31
3.2.2	Impact of ASHRAE Standards and Other Factors on Newly Constructed Building EUIs.....	32
3.2.3	Impact on 2025 EUI of Federal Building Stock.....	34
3.3	Combined Impact of Retrofits and New Construction on Federal Building Stock EUI ..	35
4.0	Alternative Energy Performance Evaluation Approaches .....	36
4.1	Site vs. Source EUI .....	37
4.1.1	Description of Source Energy Calculations .....	37
4.1.2	Benefits and Drawbacks.....	38
4.1.3	Impact on Past Performance.....	41
4.1.4	Impact on Future Energy Savings .....	41
4.2	Goal-Subject vs. All Buildings.....	43
4.3	FY 2003 vs. Alternative Baseline Years .....	45
4.3.1	Weather .....	45
4.3.2	Other Factors .....	47

4.4	Single vs. Distinct or Tiered Performance Goals .....	48
4.5	Intensity vs. Absolute Reduction Goals .....	49
4.6	Other Goal-Setting Approaches .....	50
5.0	Conclusions and Recommendations .....	51
6.0	References .....	54
Appendix A. Methodology for Estimating Existing Building Retrofits .....		1
Appendix B. Estimating Impact of New Construction on the 2025 Federal Energy Goal: Detailed Methodology.....		A-1
Appendix C. Data Sources to Estimate Recent Additions of Federal Floor Space.....		B-1
Appendix D. Heat Map of Fossil Energy Intensity based on eGRID 2012 .....		C-1

## Figures

1.	Energy use, floor space, and energy intensity for the federal government, FY 2003-2012.....	3
2.	Overall government progress toward facility energy efficiency goals, FY 2003-2012, with projections to FY 2015 .....	4
3.	Energy use (billion Btus) and floor space (million SF) by agency in FY 2012 .....	5
4.	Energy use intensity (Btu/SF) of Federal agencies in FY 2012.....	5
5.	Total energy use (BBtu) by federal agencies in goal-subject buildings, FY 2003-2012 .....	6
6.	Change in energy use by fuel type, FY 2003-2012.....	7
7.	Agency contribution to total energy savings by fuel type, FY 2003-2012 .....	9
8.	DOD energy use intensity, energy use, and floor space for FY 2003-2012 .....	10
9.	Change in DOD energy use by fuel type, FY 2003-2012.....	11
10.	DOE energy use intensity, energy use, and floor space for FY 2003-2012 .....	12
11.	Change in DOE energy use by fuel type, FY 2003-2012 .....	13
12.	HHS energy use intensity, energy use, and floor space for FY 2003-2012 .....	14
13.	Change in HHS energy use by fuel type, FY 2003-2012.....	15
14.	DOJ energy use intensity, energy use, and floor space for FY 2003-2012.....	16
15.	Change in DOJ energy use by fuel type, FY 2003-2012 .....	17
16.	VA Energy Use Intensity, Energy Use, and Floor Space for FY 2003-2012 .....	18
17.	Change in VA energy use by fuel type, FY 2003-2012.....	19
18.	GSA energy use intensity, energy use, and floor space for FY 2003-2012 .....	20
19.	Change in GSA energy use by fuel type, FY 2003-2012.....	21
20.	USPS energy use intensity, energy use, and floor space for FY 2003-2012.....	22
21.	Change in USPS energy use by fuel type, FY 2003-2012 .....	22
22.	Proportion of total cost vs. proportion of total energy use by fuel source using the DOE FY 2012 data.....	39
23.	Percentage of EUI reduction by agency, FY 2008-2012 .....	41
24.	Reduction in site EUI for goal-subject buildings and all buildings, FY 2008-2012 .....	45



## Tables

1. Energy use intensity reduction schedule in EISA .....	2
2. Reductions in energy use (BBtu) by fuel type, FY 2003-2012 .....	7
3. Percent changes in EUI, total energy use, and floor space from FY 2003-2012 .....	8
4. Estimated EUI impact of cost-effective energy conservation measures (site energy basis) .....	26
5. Differences in progress toward current federal reduction targets for DOD and civilian agencies	27
6. Potential 2015-2025 EUI reduction from implementing <i>technically feasible</i> onsite renewable energy (site energy basis).....	28
7. Nominal installed costs and associated energy cost savings impacts from efficiency measures (current dollars).....	29
8. Technology retrofit energy savings opportunities at the end use level (Percent of aggregate savings) .....	30
9. Floor space and new construction projections, FY 2016-2025 (millions of square feet) .....	32
10. Impact of new construction meeting ASHRAE Standard 90.1-2010 and a hypothetical future Standard 90.1-2016 on average building stock EUI in 2025 .....	34
11. Impact of new building construction on 2025 civilian stock EUI.....	34
12. Estimated EUI impact from both cost-effective retrofits to existing buildings and federal energy standards for new construction (site energy basis) .....	35
13. Fossil-source energy using regional eGRID factors .....	38
14. Benefits and drawbacks of using site energy versus source energy to calculate EUI reductions	39
15. Benefits and drawbacks of using national versus regional source energy factors to calculate EUI reductions .....	40
16. Estimated EUI impact of both cost-effective retrofits to existing buildings and federal energy standards for new construction (on a source energy basis).....	42
17. Illustration of the impact using of site energy vs. source energy on percent of energy savings.	43
18. Benefits and drawbacks of basing energy reduction goals on goal-subject vs. all buildings.....	44
19. Total heating degree days and cooling degree days for 12 U.S. cities.....	46
20. Possible baseline years and an evaluation of how each year rates against different criteria; green is a comparatively good year, yellow is neutral, and red is comparatively bad .....	48
21. Benefits and drawbacks of setting energy intensity vs. absolute reduction goals.....	49
22. Estimated EUI impact from both cost-effective retrofits to existing buildings and federal energy standards for new construction (site energy basis) .....	52



## 1.0 Introduction

For more than three decades, federal agencies have been working to drive down energy use in federal buildings in support of several energy intensity reduction targets established by legislative mandates and executive orders. The federal government has made significant progress since the initial targets, reducing energy use by more than 28 percent from a 1985 baseline and by more than 46 percent from a 1975 baseline.

Currently, federal agencies are working to reduce their energy consumption per gross square foot 30 percent by fiscal year (FY) 2015 compared to a 2003 baseline, as is required by Section 431 of the Energy Independence and Security Act (EISA 2007). As the performance period of the EISA goal draws near, the U.S. Department of Energy (DOE) has been charged with evaluating federal agency progress toward that goal and recommending new energy reduction targets out to 2025.<sup>1</sup>

This study, led by DOE's Federal Energy Management Program (FEMP) with support from Pacific Northwest National Laboratory (PNNL), is intended to inform those recommendations for future energy reduction goals. It includes analyses of

1. past performance toward the current energy intensity reduction goal (Section 2)
2. future energy savings potential from retrofits to existing federal buildings and the addition of newly constructed facilities to the federal building stock (Section 3)
3. alternative approaches to setting future targets and establishing baseline years (Section 4).

It is recognized that various factors will influence the ability of federal agencies to achieve the energy savings potential established in this study. Budget availability, energy security requirements, staffing availability for maintenance and operations, site specific characteristics, and other factors can all influence whether energy conservation measures are feasible and practical to implement. The focus of this study is on establishing what is cost-effective to implement to help inform policymakers responsible for setting future federal energy performance goals.

## 2.0 Past Energy Use Reduction Performance

The research team first assessed government-wide and individual progress toward meeting the 30 percent energy use intensity (EUI) reduction targets through 2012 and projected performance out to the 2015 target year. The results presented in this section of the report are based on energy consumption in buildings subject to the energy performance requirements outlined in EISA. Reduction targets are compared to a FY 2003 baseline and were to be reached according to the schedule outlined in Table 1.

---

<sup>1</sup> Per 42 USC § 8253(a)(1)(3), the Secretary of Energy must review the results of the implementation of this energy performance requirement for federal buildings by December 31, 2014, and submit to Congress recommendations concerning energy performance requirements for FY 2016 through FY 2025.

**Table 1.** Energy use intensity reduction schedule in EISA

<b>Fiscal Year</b>	<b>Reduction Target</b>
<b>2006</b>	2%
<b>2007</b>	4%
<b>2008</b>	9%
<b>2009</b>	12%
<b>2010</b>	15%
<b>2011</b>	18%
<b>2012</b>	21%
<b>2013</b>	24%
<b>2014</b>	27%
<b>2015</b>	30%


Data to support the past-performance analysis came from agency annual energy data reports submitted to FEMP for the years 2003 through 2012. Because the EUI reduction goal applies only to “goal-subject” buildings, the results presented below reflect energy savings in those buildings only.

To project compliance with the 30 percent reduction requirement out to 2015, the team estimated average annual savings over the entire period by agency and applied that annual savings rate to the years 2013-2015. The entire period was used rather than limiting the analysis to recent years in order to control for recent spikes in energy savings that may have resulted from short-term American Recovery and Restoration Act (ARRA 2009) investments in building energy efficiency.

## **2.1 Government-wide performance**

### **2.1.1 Federal progress toward EUI reduction goal with projection out to 2015**


As of FY 2012, the federal government reported an overall energy intensity of 101,139 British thermal units (Btu) per square foot (SF). This represented a 21 percent reduction in energy intensity relative to the FY 2003 baseline of 127,398 Btu/SF. The federal government achieved this reduction in energy intensity through an 18 percent reduction in total site-delivered energy use and a 3 percent increase in goal-subject floor space (Figure 1). This indicates that the federal government as a whole is on track to meet the annual reduction targets established in EISA.



**Figure 1.** Energy use, floor space, and energy intensity for the federal government, FY 2003-2012

It is useful to consider whether the federal government is likely to meet the current 30 percent reduction target by 2015 when setting targets for future energy reduction potential. Without a perfect view into the future, three alternative scenarios with different assumptions are presented to portray government-wide energy performance out to 2015 (Figure 2):

- Future savings reflect annual EISA-mandated targets – As outlined in Table 1, Section 431 of EISA 2007 establishes an average annual reduction target of percent per year. Assuming agencies meet this 3 percent annual reduction in energy intensity for the next three years, the federal government will be on track to meet the 30 percent reduction goal.
- Future savings reflect savings in most recent years – A second scenario is based on the premise that efficiency gains in the last three years are a good indicator of energy savings potential in the next three years. The average annual EUI reduction rate from the three preceding fiscal years has been 3.6 percent. If the federal government as a whole continues achieving this rate for the next three years, it will slightly exceed the 2015 target, with a 31 percent total reduction in energy intensity.
- Future savings reflect average savings over goal period – Under the most conservative assumption, if EUI follows a simple linear trend for the entire period 2003-2012. In this scenario, the federal government is projected to achieve just a 27 percent reduction in energy intensity by 2015, falling short of the reduction target.




**Figure 2.** Overall government progress toward facility energy efficiency goals, FY 2003-2012, with projections to FY 2015

A fourth scenario was also evaluated but produced unrealistic savings projections and was dismissed. This scenario attempted to account for the impact of the almost \$9 billion in facility energy efficiency improvements made from 2010 to 2012, driven to a large degree by ARRA funding. Many of those investments require several years to produce benefits in reduced energy consumption, so it is possible that agencies will achieve further large reductions through FY 2015. A previous study on the impact of EISA federal projects estimated that on average, the annual energy and water savings per dollar invested in projects in which a single energy conservation measure is implemented is 5,340 Btu per dollar.<sup>2</sup> If that savings rate is applied to the \$9 billion in recent the investments made government-wide in the past three years, the projected government-wide savings would be 31 percent. While this may be realistic, agency-specific savings projections varied widely with some achieving unrealistic projected EUI reductions over the next three years. Because of these unrealistic agency-level savings estimates and a number of other variables that can affect energy use, including changes in square footage, building stock, weather, and tempo of operations, it was assumed that investment levels alone were not an adequate predictor of performance.


### 2.1.2 Observations on Government-wide Trends

In FY 2012, seven agencies accounted for 90 percent of total federal energy use and floor space, with the Department of Defense (DOD) alone accounting for roughly 60 percent of energy use and floor space. Overall federal performance against the energy intensity reduction goal depends heavily upon the performance of the largest energy consuming agencies. Figure 3 shows agencies' energy consumption and floor space for FY 2012. As illustrated in Figure 4, there is significant variability the EUI overall EUI of federal agencies, which range from 51,000 to nearly 300,000 Btu/SF. The most energy-intensive are agencies with significant laboratory operations to support a research mission.

<sup>2</sup> Judd, KS, et. al. Evaluation of the Impact of EISA Federal Project Investments. PNNL-22074, December 2012.




**Figure 3.** Energy use (billion Btus) and floor space (million SF) by agency in FY 2012



**Figure 4.** Energy use intensity (Btu/SF) of Federal agencies in FY 2012


### 2.1.3 Changes in Energy Use by Fuel Type

Over the period of FY 2003-2012, the federal government reduced total site-delivered energy consumption in goal-subject buildings by 18 percent, from 376,199 billion British thermal units (BBtu) in FY 2003 to 306,721 BBtu in FY 2012. The largest absolute reductions came in the use of fuel oil (decrease of 20,257 BBtu, or 52 percent) and natural gas (decrease of 20,193 BBtu, or 16 percent). In relative terms, the federal government also achieved substantial reductions in the use of liquefied petroleum gas (LPG, 50 percent decrease) and coal (39 percent decrease). The majority of these reductions were achieved during the period FY 2007-2012, with the largest reductions occurring in the most recent two fiscal years (see Figure 5 and Figure 6).



**Figure 5.** Total energy use (BBtu) by federal agencies in goal-subject buildings, FY 2003-2012





**Figure 6.** Change in energy use by fuel type, FY 2003-2012

Federal agencies reduced their use of fossil fuels to a greater extent than other fuels, with fossil fuels accounting for 74 percent of the overall reduction in energy use (Table 2). Electricity accounted for 17 percent of the overall reduction.

**Table 2.** Reductions in energy use (BBtu) by fuel type, FY 2003-2012<sup>3</sup>

Fuel	Reduction in BBtu, 2003-2012	Percent of total reduction
Electricity	-10,874	17%
Natural Gas	-20,193	31%
Fuel Oil	-20,258	31%
Coal	-6,699	10%
Purchased Steam	-4,699	7%
Other	-1,158	2%
LPG	-1,559	2%

Purchased renewable energy was only tracked beginning in FY 2008, so direct comparisons with the FY 2003 baseline are not possible. Agencies reported modest use of purchased renewable energy in FY 2012, consuming 2,881 BBtu, or 1 percent of total site-delivered energy. This excludes renewable energy generated on site, which is already accounted for as a reduction in energy demand.

<sup>3</sup> Note that the overall reduction in energy use reported above exceeds the sum of the reductions in energy use by fuel type because the overall calculation includes the source energy savings credit.

## 2.2 Agency-specific performance

As of FY 2012, 18 of 24 Office of Management and Budget (OMB) scorecard agencies<sup>4</sup> had achieved a reduction in energy intensity of 21 percent or greater. As shown in Table 3, three agencies—Department of Justice (DOJ), Housing and Urban Development (HUD), and United States Postal Service (USPS)—had already exceeded the 30 percent reduction goal. Four of the top five energy consuming agencies (based on Figure 2) are on track to meet the 30 percent reduction goal in FY 2015 based on the 3 percent annual reduction schedule outlined in Table 1, with DOD being the exception.

**Table 3.** Percent changes in EUI, total energy use, and floor space from FY 2003-2012

Agency	% Change in Energy Intensity (Btu/SF)	% Change in Energy Use (BBtu)	% Change in Floor Space (kSF)	On Track?*
DHS	-20.1%	-5.9%	+17.8%	No
DOC	-21.0%	+43.9%	+82.1%	Yes
DOD	-17.7%	-15.2%	+3.0%	No
DOE	-23.5%	-28.9%	-7.1%	Yes
DOI	-28.5%	-13.4%	+21.2%	Yes
DOJ	-44.6%	-31.6%	+23.5%	Yes
DOL	-28.1%	-22.5%	+7.8%	Yes
DOT	-23.9%	-24.1%	-0.2%	Yes
EPA	-23.7%	-20.8%	+3.8%	Yes
GSA	-24.5%	-26.2%	-2.2%	Yes
HHS	-22.4%	-13.9%	+10.9%	Yes
HUD	-33.1%	-32.7%	+0.6%	Yes
NARA	-27.3%	+10.6%	+52.0%	Yes
NASA	-23.9%	-21.3%	+3.4%	Yes
OPM	-2.7%	-2.0%	+0.7%	No
SI	-27.1%	-0.5%	+36.4%	Yes
SSA	-21.6%	-29.6%	-10.3%	Yes
State	-8.2%	+11.0%	+21.0%	No
TRSY	-11.8%	-21.9%	-11.4%	No
TVA	-21.2%	-21.2%	+0.0%	Yes
USACE	-11.4%	-8.6%	+3.2%	No
USDA	-21.3%	-26.6%	-6.7%	Yes
USPS	-32.4%	-40.0%	-11.4%	Yes
VA	-21.4%	-7.6%	+17.5%	Yes
<b>Total Gov't</b>	<b>-20.6%</b>	<b>-18.6%</b>	<b>+2.6%</b>	<b>Yes</b>

\*To meet 30% energy intensity reduction goal, according to FY 2012 OMB Sustainability/Energy Scorecard.


<sup>4</sup> Note that the energy performance requirement in 42 U.S.C. § 8253 applies specifically to agencies, not the federal government as a whole.

In terms of overall energy consumption, floor space, and fuel mix, there were no clear trends distinguishing agencies considered to be on track from those considered not on track. Agencies achieved reductions in various ways. Among on-track agencies, the greatest reductions were achieved by agencies whose total floor space increased while energy consumption decreased. DOJ, Department of the Interior (DOI), VA, and Health and Human Services (HHS) demonstrated this trend. A notable exception is USPS, which achieved the third-greatest reduction in energy intensity among all scorecard agencies, decreasing floor space by 11 percent and energy use by 40 percent.

A majority of the agencies not on track also demonstrated reductions in energy consumption accompanied by increased floor space. Among the scorecard agencies, State, Department of Commerce (DOC), and National Archives and Records Administration (NARA) were the only three agencies whose consumption increased, but in each case their square footage increased by a greater percentage, resulting in an overall reduction in EUI.

When considering energy savings by fuel type, most agencies made large reductions in the use of fuel oil. A majority of agencies also reduced their consumption of natural gas, and a similar number reduced their electricity use. These trends were observed for agencies that are on-track to meet their EUI reduction targets as well as those that are not on track.

Figure 7 illustrates the net reductions and increases in energy use by fuel type and by agency. Observations on agency-level performance are presented below for several of the largest energy-consuming agencies, including: DOD, DOE, HHS, DOJ, VA, GSA, and USPS.




**Figure 7.** Agency contribution to total energy savings by fuel type, FY 2003-2012

## 2.2.1 Department of Defense


In FY 2012, DOD used 96,593 Btu/SF in its goal-subject buildings. This represented a 17.7 percent decrease in energy intensity compared to 117,334 Btu/SF in FY 2003. DOD is considered not on track to meet the 30 percent reduction goal by OMB.

DOD's total floor space has remained roughly constant since FY 2007, such that reductions in energy use have resulted in corresponding reductions in energy intensity. DOD has only seen major reductions in energy use over the most recent three fiscal years. Between FY 2003 and FY 2009, energy use decreased by only 2.8 percent, setting DOD behind most other agencies (Figure 8).



**Figure 8.** DOD energy use intensity, energy use, and floor space for FY 2003-2012

Reductions have been achieved almost exclusively through decreased use of fossil fuels, which accounts for 96 percent of the 32,539 BBtu of the decrease in all fuels since FY 2003. Use of fuel oil has decreased most, both in relative and absolute terms, by 15,598 BBtu (a 50 percent decrease). Natural gas use has also decreased substantially in absolute terms, by 9,797 BBtu (a 14 percent decrease). Coal and LPG use have each decreased by more than one third. Because DOD's energy use is so much higher than the other agencies, these reductions have driven trends observed for the federal government as a whole. For example, DOD accounted for 77 percent of the overall federal reduction in fuel oil use, and 80 percent of the overall reduction in coal use. DOD's electricity use—its single largest source of energy consumption—increased by 3 percent between FY 2003 and FY 2012, to 92,007 BBtu (Figure 9).




**Figure 9.** Change in DOD energy use by fuel type, FY 2003-2012

### 2.2.2 Department of Energy


In FY 2012, DOE used 170,301 Btu/SF in its goal-subject buildings. This represented a 24 percent decrease in energy intensity compared to 222,472 Btu/SF used in FY 2003.

DOE's floor space decreased by 20,292 thousand SF (kSF) between FY 2003 and FY 2008, but began to increase again beginning in FY 2009. DOE's energy use decreased relatively steadily each year over the entire FY 2003-2012 period. At the end of the period, DOE's floor space had decreased by only 7 percent, while energy use had declined by 29 percent (Figure 10).



**Figure 10.** DOE energy use intensity, energy use, and floor space for FY 2003-2012

DOE's performance in energy intensity reduction so far suggests that the agency will meet the 30 percent reduction target in or potentially before FY 2015. DOE achieved its reductions through substantial decreases in the use of several fuels, including coal (1,176 BBtu, or 59 percent) and fuel oil (1,046 BBtu, or 71 percent). DOE achieved the most dramatic reductions in energy use through a 28 percent decrease in electricity use, amounting to 3,668 BBtu. In addition, DOE reduced its use of purchased steam by 96 percent (Figure 11).




**Figure 11.** Change in DOE energy use by fuel type, FY 2003-2012

### 2.2.3 Department of Health and Human Services

In FY 2012, HHS used 269,363 Btu/SF in its goal-subject buildings. This represented a 22 percent decrease in energy intensity compared to 347,040 Btu/SF in FY 2003.


HHS's floor space increased by 11 percent between FY 2003 and FY 2007, but has remained relatively unchanged since then. After an initial decrease in energy use in FY 2004, HHS's consumption rose fairly steadily through FY 2009 before dropping dramatically in FY 2010, by 18 percent. With total floor space remaining essentially unchanged, this reduction brought HHS below the energy intensity target for FY 2010, after two years of exceeding the target. HHS has continued to meet the target and is considered on track to meet the 30 percent target by FY 2015 (Figure 12).



**Figure 12.** HHS energy use intensity, energy use, and floor space for FY 2003-2012

HHS achieved its largest reductions in energy use through decreases in purchased steam of 1,216 BBtu (90 percent) and in fuel oil of 542 BBtu (70 percent). HHS reduced electricity use by 393 BBtu (11 percent). In addition, HHS completely eliminated its use of coal; however, this reduction did not have a large impact on HHS’s overall energy use, as coal accounted for less than 1 percent of total energy use throughout the FY 2003-2012 period. Unlike the other large scorecard agencies, all of which reduced their use of natural gas, HHS’ use of natural gas actually increased substantially, by 2,235 BBtu, or 61 percent (Figure 13).





**Figure 13.** Change in HHS energy use by fuel type, FY 2003-2012


Since HHS’s reductions in energy use were largely offset by its increased use of natural gas, the agency’s large reductions in energy intensity in the past three years were achieved primarily through the application of the “renewable energy credit” and the “source energy credit” toward the Btu/SF requirement.<sup>5</sup> The credits amounted to 1,508 BBTu in FY 2010, or 82 percent of the total reduction in energy reported for that year.

#### 2.2.4 Department of Justice

In FY 2012, DOJ used 160,122 Btu/SF in its goal-subject buildings. This represented a 45 percent decrease in energy intensity compared to 289,056 Btu/SF used in FY 2003.


DOJ’s floor space increased at a regular pace between FY 2003 and FY 2007, but has remained relatively unchanged since FY 2008. Since FY 2007, its energy use dropped steadily each year, decreasing by a total of 36 percent. That decrease resulted in a 33 percent drop in energy intensity over the same period (Figure 14).

<sup>5</sup> U.S. Department of Energy, Federal Energy Management Program. November 2012. Reporting Guidance for Federal Agency Annual Report on Energy Management (per 42 U.S.C. 8258).



**Figure 14.** DOJ energy use intensity, energy use, and floor space for FY 2003-2012

In FY 2012, DOJ led all agencies in overall energy intensity reduction performance. DOJ was one of three agencies to exceed the 30 percent reduction goal in advance of FY 2015. Its 45 percent reduction was achieved almost completely through decreases in the use of natural gas and electricity. DOJ reduced its natural gas consumption by 2,879 BBtu (a 34 percent decrease) and electricity use by 1,742 BBtu (a 25 percent decrease). In addition, DOJ reduced its use of purchased steam by 75 percent, or 515 BBtu (Figure 15).




**Figure 15.** Change in DOJ energy use by fuel type, FY 2003-2012

### 2.2.5 Department of Veterans Affairs


In FY 2012, the VA used 154,085 Btu/SF in its goal-subject buildings. This represented a 21 percent decrease in energy intensity compared to 196,025 Btu/SF used in FY 2003.

VA's floor space decreased to a low of 142,271 kSF in FY 2006, and has increased each year since then. The agency's energy use has fluctuated on an annual basis but has trended downward overall over the period FY 2003-2012, decreasing by 8 percent. The increase in floor space had a larger effect on VA's energy intensity than the decrease in energy use (Figure 16).



**Figure 16.** VA Energy Use Intensity, Energy Use, and Floor Space for FY 2003-2012

VA has met the energy intensity target for the past two years, and is considered on track to meet the 30 percent reduction target by FY 2015. VA achieved its largest energy use reductions in natural gas (1,382 BBtu, or 9 percent) and fuel oil (964 BBtu, or 58 percent). VA also reduced its consumption of LPG by 45 percent and coal by 34 percent, although these reductions had only a small effect on overall energy use. These reductions were partially offset by an increase in electricity use of 1,042 BBtu, or 10 percent (Figure 17).




**Figure 17.** Change in VA energy use by fuel type, FY 2003-2012

Like HHS and GSA, VA made use of the Goal-Building Renewable Energy Credit and the Source Energy Savings Credit to reduce its total calculated energy use. Energy use actually increased from FY 2011 to FY 2012, but after applying the Source Energy Savings Credit, VA’s total calculated energy use in FY 2012 was 480 BBtu lower than the previous year.

### 2.2.6 General Services Administration


In FY 2012, GSA used 58,100 Btu/SF in its goal-subject buildings. This represented a 24 percent decrease in energy intensity compared to 76,921 Btu/SF used in FY 2003.

GSA’s floor space and energy use increased dramatically between FY 2003-2004 and then fell back to roughly FY 2003 levels in FY 2006. Between FY 2006 and FY 2009, floor space and energy use remained essentially constant. Floor space has continued to stay fairly unchanged, while energy use began to drop in FY 2010, falling 22 percent since FY 2009. The decreases in the previous three years account for nearly all of GSA’s reduction against the FY 2003 baseline (Figure 18).



**Figure 18.** GSA energy use intensity, energy use, and floor space for FY 2003-2012

Given the reductions in energy use over the past three years, GSA is considered on track to meet the 30 percent energy intensity reduction target by FY 2015. GSA’s reductions were achieved primarily through decreases in the use of electricity by 1,288 BBtu (14 percent) and natural gas by 1,234 BBtu (38 percent). GSA also reduced its use of purchased steam by 606 BBtu (39 percent) and fuel oil by 62 BBtu (44 percent). Unlike most other scorecard agencies, GSA did not use any coal or liquefied petroleum gas over the period FY 2003-2012 (Figure 19).




**Figure 19.** Change in GSA energy use by fuel type, FY 2003-2012

Like HHS and VA, GSA made use of the Goal-Building Renewable Energy Credit and the Source Energy Savings Credit to reduce its total calculated energy use. Energy use actually increased from FY 2011 to FY 2012, but after applying the Source Energy Savings Credit, GSA’s total calculated energy use in FY 2012 was 674 BBtu lower than the previous year.

### 2.2.7 United States Postal Service


In FY 2012, USPS used 70,217 Btu/SF in its goal-subject buildings. This represented a 32 percent decrease in energy intensity compared to 103,819 Btu/SF used in FY 2003.

USPS’s floor space was essentially constant until FY 2009, when it dropped sharply—by 33 million SF in one year. Between FY 2009 and FY 2012, floor space decreased at a much slower pace. Beginning in FY 2007, energy use also began to fall each year, resulting in corresponding reductions in energy intensity (Figure 20).



**Figure 20.** USPS energy use intensity, energy use, and floor space for FY 2003-2012

USPS was one of three agencies to exceed the 30 percent energy intensity reduction goal in advance of FY 2015. Like DOJ, USPS achieved its reductions almost completely through decreases in the use of natural gas and electricity. USPS reduced its natural gas consumption by 6,239 BBtu (a 60 percent decrease) and electricity use by 5,479 BBtu (a 27 percent decrease). In addition, USPS reduced its use of fuel oil by 61 percent, or 610 BBtu (Figure 21).



**Figure 21.** Change in USPS energy use by fuel type, FY 2003-2012



## 3.0 Future Energy Savings Potential in Federal Buildings

Future energy savings in federal buildings will be realized as a result of retrofits to existing buildings as well as the retirement of old buildings and addition of newly constructed buildings that are designed to much more efficient standards. This section examines the energy savings potential from both of these sources. Section 3.1 presents the results of an analysis of potential energy savings that could be achieved through investments in additional energy efficiency and renewable measures, while Section 3.2 presents estimates of savings that would result from incorporating more energy efficient, newly constructed buildings into the federal building stock.

This analysis is intended to convey the *technical potential* of investments in cost-effective energy conservation measures (ECMs) and provides an estimated cost of implementing those measures in existing buildings. The analysis is not intended to address policy, institutional, or other barriers to implementing these ECMs, and makes no assumptions or projections about likely future funding levels. However, the estimated costs of implementing these ECMs in different sectors and facilities described in Section 3.1.4 may help inform budgetary requirements to realize the full energy savings potential.

The approach to estimating future savings potential is discussed briefly below and more detail on the methodologies, modeling assumptions, and supporting calculations can be found in Appendices A, B, and C.

### 3.1 Existing Building Retrofits

The objective of the building retrofit analysis was to estimate the potential energy savings that could be achieved through further investments in lifecycle cost-effective energy efficiency measures in existing federal buildings between 2016 and 2025, as well as the reduction potential from implementation of renewable energy projects on federal buildings or sites. This analysis involved defining a set of prototype buildings for the federal sector, modeling the impacts of energy efficiency retrofit and renewable energy measures on these buildings, extrapolating results to the federal sector as a whole, and establishing savings estimates, as is described below.

#### 3.1.1 Modeling Prototype Federal Buildings

Prototype buildings were established to make sure that a representative sample of federal buildings was modeled. Because of key differences in building characteristics and operations in DOD buildings and civilian buildings, many of which are managed by the GSA, separate prototypes were established for the civilian sector and for the DOD.

For the civilian sector, four building types were modeled: offices, warehouses, laboratories, and hospitals. These represent the most common federal civilian building types in the U.S. as reported in the Federal Real Property Profile (FRPP) database, and together these building types represent 66 percent of civilian domestic floor area. Five building locations were also selected to reflect where the majority of federal facilities are located based on the FRPP and to cover a mix of representative geographic and climate regions (i.e., Washington, DC, Los Angeles, CA, Jacksonville, FL, New York, NY, and Dallas, TX). Finally, different combinations of large/small and old/new buildings were established to represent the current federal civilian building stock. Thirty variants of these civilian buildings were modeled in five locations for a total of 150 model runs.

Characteristics for modeled civilian buildings were statistically derived prototypes based on building data and end use consumption patterns from the Commercial Building Energy Consumption Survey (CBECS). All end use characteristics data, with the exception of lighting, have been inferred statistically using the CBECS micro data. For lighting, existing PNNL models of the DOD sector were utilized to extract the lighting characteristics of the stock, based on numerous on-site facility audits. Buildings of the same type were used to infer lighting characteristics of their civilian counterparts (e.g., DOD administrative and office building for civilian office buildings, DOD hospitals and medical facilities for civilian medical types).

Results presented in the report further disaggregate the four commercial building types for which models were developed. Results for five additional building types – service, schools, prisons, industrial, and other – were not modeled but estimated based on composites of the modeled building types. Composite weights were based on the segmentation of EUIs by building type and by end use developed in a PNNL study<sup>6</sup> for FEMP. Table A.15 in Appendix A presents the composite proportions used to extend the civilian building type results from the modeled building types to the additional building types presented in the report.

For DOD buildings, prototypes were developed for sets of “integrated facilities” that are commonly found on DOD installations. Five prototypes were defined for different DOD building locations, using the same geographic locations established for civilian buildings.

This regional differentiation for both civilian and DOD buildings is important because utility prices and climate vary widely across the country, and therefore the cost-effectiveness of energy conservation measures will vary significantly by location. Actual utility rate structures for each modeled geographic location were assumed to be representative for the civilian and DOD sectors. Thus, the roll-up from individual regionally varied models will provide a more representative national assessment. The utility rate assumptions provided in Appendix A (Tables A.17, A.18, and A.19) were used to model lifecycle cost-effective ECMs in both DOD and the civilian sector.

The prototype buildings were modeled using a 2013 release of the Facility Energy Decision System (FEDS) – a tool for simulating building energy performance and analyzing the impact of ECMs. The FEDS model used building type, location, size, and vintage to infer technology retirement and estimate what technologies still exist in the building stock.

The intent of using the FEDS model is to calculate estimates of the minimum life-cycle cost (LCC) configuration of the energy generation and consumption infrastructure for both federal civilian buildings and integrated military installations. The model has no fuel or technology bias; it simply selects the technologies that will provide an equivalent or superior level of service (e.g., heating, cooling, illumination) at the minimum LCC.

As part of estimating the minimum LCC configuration of generation and end-use technologies, all interactive effects between energy systems are modeled. The value or cost of these interactive effects varies by building type (level of internal gain), building size (portion of heating, ventilation, and air conditioning loads attributable to internal gains versus envelope gains/losses), climate (whether a

---

<sup>6</sup> Judd KS, AR Kora, JW Henderson, BJ Russo, J Katz, M Hummon, and EM Rauch. 2010. Roadmap to a Climate Neutral Federal Government. PNNL-19643, Pacific Northwest National Laboratory, Richland, WA.

particular building is cooling- or heating-dominated), occupancy schedule, and a number of other factors. Thus, there is no simple solution, and detailed simulation modeling is the best way to provide a credible estimate of the impact. For example, when considering a lighting retrofit, the model evaluates the change in energy consumption in all building energy systems rather than just the change in the lighting energy. In addition, it was conservatively assumed that both sectors could achieve an additional 5 percent savings through improved operations and continuous commissioning activities. See Appendix A for more detail on the FEDS model assumptions.

The analyses yielded a life-cycle-cost-effective mix of ECMs, which resulted in estimated EUIs for each of the prototype buildings and locations if all of the retrofits were implemented.

### **3.1.2 EUIs for Prototype Buildings**

The federal building prototypes that were modeled produced target EUI estimates, which were extrapolated to all floor area of a similar type in the civilian and DOD sectors. No distinction between goal-subject and excluded buildings was made in the model, as there would be no reliable basis for establishing prototypes that would exclude floor area not subject to efficiency goals. For building types in the civilian sector that were not modeled, weighted-average EUIs were established using federal EUI estimates by building type and location. The approach for developing all weighting and scaling of model results to national estimates is discussed in Appendix A.

The results of the FEDS modeling were weighted and scaled such that the baseline EUI values were consistent with relative values estimated using floor area based on the FRPP data. Regional weights were developed also based on summarization of gross floor area from the FRPP data. The research team assumed that the regional distribution of floor area or the distribution of floor area by building type would not vary significantly during the 2016-2025 period.

Modeled EUI and total energy consumption estimates for civilian prototype buildings were based on prototypes that PNNL has developed for related assessments. PNNL has completed site-specific energy efficiency audits and analyses using FEDS for numerous military installations, which were used to represent the DOD stock. The building-level data utilized in the FEDS model have been calibrated based on the detailed facility audits of actual buildings. The estimates for the civilian sector buildings have been developed based on representative composite buildings developed to provide statistically representative average conditions based on segmentation by size, vintage, type, and technology mix. Auditing a set of typical federal civilian buildings was beyond the scope of this study.

Model results were vetted with FEMP and agency personnel, and compared to actual federal building energy performance data when available. Baseline EUIs were based on current reported civilian and DOD values of 109 kBtu/SF for civilian buildings and 97 kBtu/SF for DOD buildings. These values were adjusted to their 2015 starting values by extending the current trend of EUI goal progress over the 2003-2012 period to the 2011-2015 period to bring the FEDS model starting EUIs in line with published values. This resulted in 2015 starting values of 97.3 kBtu/SF for civilian buildings and 91.0 kBtu/SF for DOD buildings.

### 3.1.3 Estimated Energy Savings Potential from Energy Conservation and Efficiency

The estimated EUI impact results for existing buildings appear in Table 4. Results are presented in site energy terms, which reflect the amount of energy use at the building meter.

**Table 4.** Estimated EUI impact of cost-effective energy conservation measures (site energy basis)

Sector and Building Type	2015 EUI	2025 EUI Reduction with Efficiency Only		2025 EUI
	kBtu/SF	kBtu/SF	Pct.	kBtu/SF
All Civilian	97.3	10.9	11.2%	86.3
Civ: Healthcare	151.9	15.9	10.5%	135.9
Civ: Industrial	98.7	10.5	10.6%	88.2
Civ: Laboratory	145.0	13.6	9.4%	131.5
Civ: Office	92.0	10.6	11.5%	81.4
Civ: Prison	129.1	13.5	10.5%	115.5
Civ: School	73.8	9.2	12.5%	64.6
Civ: Service	68.3	8.8	12.8%	59.5
Civ: Warehouse	27.1	5.6	20.7%	21.5
Civ: Other	84.1	10.0	11.9%	74.1
All DOD	91.0	20.4	22.5%	70.6
All Federal	93.1	18.5	19.9%	74.5

The results suggest that if all cost-effective ECMs were deployed into the existing stock, then by 2025, a 20 percent reduction in EUI would be possible for the federal government as a whole from 2015. Most of this potential arises from DOD facilities, which have an estimated EUI reduction potential of 22 percent, whereas the civilian sector has an estimated EUI improvement of 11 percent, based on implementation of cost-effective ECMs. The actual savings potential could vary widely by agency, as indicated by the variability in actual savings achieved to date and demonstrated in the analysis of past performance.

Based on the information available for the modeling and analysis included in this report, the larger energy-savings potential in DOD facilities compared to the civilian sector may be attributed to the age of the DOD building stock and the progress toward the EUI reduction goal to date. The DOD sector has achieved a 17.7 percent reduction from its 2003 baseline, while the civilian sector has reduced energy use intensity 24.5 percent below its baseline (Table 5). One reason for the higher civilian EUI reductions may be that the civilian sector as a whole has invested comparatively more into building efficiency than DOD during the goal period. Between 2005 and 2013 DOD’s ratio of efficiency investment-to-energy costs (18 percent) is somewhat lower than the civilian sector’s ratio (33 percent including GSA, and 22 percent excluding GSA, which has had higher than usual investment levels due to ARRA funding).

Furthermore, much more floor area in DOD is significantly less energy efficient than the floor area in the federal civilian buildings when comparing a similar mix of building types. The DOD stock is older and was not, until the last decade or so, built to the same standards. For example, uninsulated metal-sided and metal-roofed buildings constructed for unoccupied and unconditioned storage have been repurposed to heated, occupied warehousing. Wood-framed unconditioned office space (1940’s era) has since been adapted with window-mount air conditioning and space heaters. This may explain in part the lower starting EUIs and challenge associated with reducing them further. Such examples lead to significant

retrofit opportunities for envelope measures that increase insulation and reduce heating and cooling loads. Other factors driving the comparatively lower rate of EUI reduction in DOD could be that DOD space has become more highly utilized with the increased mission tempo and troops redeploying from overseas missions to U.S facilities.

**Table 5.** Differences in progress toward current federal reduction targets for DOD and civilian agencies

Sector	2003 Baseline EUI (kBtu/SF)	2012 Reported EUI (kBtu/SF)	Percent Reduction as of 2012	Projected 2015 EUI if 30% Goal is Met (kBtu/SF)	Estimated 2015 EUI per Model (kBtu/SF)
DOD	117.3	96.6	17.7%	82.1	91.0
Civilian	144.0	108.7	24.5%	100.8	97.3

### 3.1.4 Estimated Renewable Energy Production Potential

In addition to the modeling of cost-effective ECMs, this study also considers the additional impact that developing *technically feasible* onsite renewable energy supplies would have on the building’s overall EUI. Assessment of lifecycle cost-effectiveness of renewable energy requires site-level analysis and was not feasible for this study of government-wide renewable energy potential. Furthermore, the economics of future investments in renewable energy are largely driven by future pricing of renewables and availability of tax credits and incentives, both of which pose a great deal of uncertainty. Therefore the estimates presented in this section represent an upper limit of government-wide renewable production potential.

To establish the technically feasible capacity of renewable energy on civilian buildings, renewable capacity was sized such that for every hour of the year the output from the installed wind and PV would not exceed the building energy demand that occurred during that hour. Thus, there is no hour during the year that the building or installation would sell power back to the grid. This is a conservative assumption and was used to deal with uncertainty around the potential for net metering at federal locations. It represents capacity well below technical production potential. For DOD facilities, alternative configurations of onsite wind and PV were modeled for optimum electricity output, also subject to the constraint that renewable output would not exceed the facility energy demand in any hour. See Appendix A for more discussion.

Based on this analysis, renewable energy production has the potential to further reduce EUIs in civilian buildings by up to 4.1 percent over the proposed 2015 to 2025 goal period, as illustrated in Table 6. It is estimated that renewable energy production in DOD facilities has the potential to further reduce facility EUI by up to 8.9 percent over the ten-year goal period. This appears to be roughly consistent with estimates described in the DOD’s *Sustainability Performance Report FY 2013*, which states that DOD is currently acquiring 9.6 percent of its energy from renewable sources and expects to achieve a target of 25 percent renewable energy by 2025, as required by Title 10, United States Code §2911(e)(2).<sup>7</sup>

As noted above, when setting government-wide reduction goals it should be considered that some of this potential may not be cost-effective or practical to implement upon further analysis. For example, the in the DOD’s Sustainability Performance report it is noted that, “One factor dampening the amount of renewable energy the Department can report is its mission-driven decision to focus more resources on

<sup>7</sup> Department of Defense Sustainability Performance Report FY 2013. Aug 13, 2013. Pp. 33.

increasing renewable energy capacity on DOD property, and fewer on purchasing renewable energy credits.”<sup>8</sup>

**Table 6.** Potential 2015-2025 EUI reduction from implementing *technically feasible* onsite renewable energy (site energy basis)

Sector and Building Type	Potential 2015- 2025 EUI Reduction with Onsite Renewables	
	kBtu/SF	Pct.
All Civilian	4.0	4.1%
Civ: Healthcare	3.8	2.5%
Civ: Industrial	5.2	5.3%
Civ: Laboratory	7.8	5.4%
Civ: Office	4.0	4.3%
Civ: Prison	3.2	2.5%
Civ: School	3.2	4.3%
Civ: Service	2.9	4.3%
Civ: Warehouse	1.2	4.3%
Civ: Other	3.6	4.3%
All DOD	8.1	8.9%
All Federal	6.5	6.9%

DOD has double the capacity to install onsite renewables compared to the civilian sector for a few reasons. DOD sites have larger land area available for onsite renewables than do civilian buildings, which were assumed to be constrained by the building roof area for PV. In its FY 2013 Sustainability Performance Report, DOD states that it intends to accelerate the development of large-scale renewable projects on their lands, and that each of the three Military Departments set a goal to install one gigawatt of renewable energy on their installations: Air Force by 2016, Navy by 2020, and Army by 2025.<sup>9</sup> Also, DOD renewable potential considered both wind and PV whereas only PV was considered for civilian buildings. Finally, the shape of the DOD profile with more evening and weekend loads from barracks and family housing is more conducive to renewables under the “no net generation constraint” that the model applied (i.e. sites were assumed to produce no more than their demand in light of net metering uncertainties).

### 3.1.5 Estimated Cost of Implementation

Using the FEDS database of ECMs, the model selected for implementation in the existing stock those measures that would be life-cycle cost-effective under the established FEDS methodology. Appendix A discusses the specific measures considered in the model. Table 7 summarizes the costs in simple nominal payback terms by building type. Civilian agencies would see slightly shorter paybacks, depending on the type of building, while DOD facilities would see slightly longer paybacks. This difference is driven largely by the differential in electricity and gas rates between the two sectors.

<sup>8</sup> Ibid.

<sup>9</sup> Department of Defense Sustainability Performance Report. Aug 14, 2013. Pp. ES-8.

Table 7 does not account for the impacts of onsite renewables. Given the variety of factors that affect the installed costs of renewables, including existing rate structures, incentive programs, and configurations, no attempt was made to assess cost-effectiveness. It is likely that the costs for onsite renewables would be relatively higher per kilowatt-hour (kWh) of electricity and thus would extend the paybacks reported for efficiency ECMs alone. In addition, due to the complexities mentioned, it is not likely that all technically feasible onsite renewables would be cost-effective to develop.

**Table 7.** Nominal installed costs and associated energy cost savings impacts from efficiency measures (current dollars)

Building Type	Installed Cost (\$/SF)	Annual Savings (\$/SF)	Simple Payback (Yrs)
All Civilian	2.68	0.42	6.4
Civ: Healthcare	3.56	0.63	5.7
Civ: Industrial	1.78	0.44	4.1
Civ: Laboratory	2.38	0.63	3.8
Civ: Office	2.36	0.34	6.8
Civ: Prison	3.02	0.53	5.7
Civ: School	1.93	0.29	6.7
Civ: Service	1.81	0.27	6.7
Civ: Warehouse	0.85	0.14	6.1
Civ: Other	2.18	0.32	6.8
All DOD	2.59	0.36	7.1
All Federal	2.62	0.38	6.8

The total investment required when the installed cost per square foot of \$2.62 is applied to the total federal floor area of 3,167 million square feet would be approximately \$8.3 billion for all federal agencies. Over \$5.0 billion would be required for DOD investment and over \$3.3 billion would be required for all other federal civilian agencies. Considering the current floor area distribution by space type and installation cost per square foot, about \$1.2 billion of the \$3.3 billion of the civilian federal investment would be directed toward office retrofits and over \$340 million would go to healthcare facility retrofits.

This \$8.3 billion total investment equates to an average annual investment in energy efficiency of roughly \$830 million for all agencies over the ten-year goal period. Looking at historic average annual investment might suggest this is feasible, however it should be considered that these were heavily influenced by ARRA funding which will not be sustained into the future. Government-wide from FY 2005 through 2013 was \$1.6 billion per year (\$943 million for civilian agencies and \$671 million for DOD), with GSA's ARRA funding contributing to the significantly higher average on the civilian side. Prior to the first year of ARRA funding in FY 2009, funding levels were under \$1 billion per year.

The total investment required assumes projects are funded directly by the agency and does not account for third-party financing costs. An estimated 72 percent of energy efficiency and renewable investments funded by agencies between 2005 and 2013 were funded directly by agencies; the remaining projects were third-party financed through energy savings performance contracts (ESPCs) or utility energy service contracts (UESCs). Use of third party financing varies significantly by agency so was not built into this analysis. It should be assumed however, that due to different payback thresholds and higher financing costs, some of the long-payback items that are cost-effective with direct appropriations, may not

occur under a third-party financing scenario, therefore the total investment and savings potential would be somewhat lower.

This level of investment is expected to yield roughly \$1.2 billion in annual savings, with \$700 million per year for DOD and \$520 million per year for civilian agencies. The majority of annual savings in the civilian sector would come from investments in offices (\$180 million per year), laboratories (\$63 million), and healthcare (\$60 million). Note that these investment and savings values by building type are approximations based on the proportion of total domestic floor area that each of these building types represent, as reported in the FRPP database.

The mix of savings by class of end use technology varies significantly between civilian and DOD buildings. Table 8 illustrates the expected allocation of savings to end use technologies. In the civilian sector, lighting dominates the projected savings from retrofit opportunities, followed by space heating and windows. As noted in the model assumptions tables A.4 through A.7 in Appendix A, there are assumed to be opportunities to upgrade some remaining T12 lighting, as well as T8 lighting, with Super T8 technology for improved efficiency, as well as opportunities to upgrade some incandescent lamps with compact fluorescent lamps. Space heating efficiencies are expected to come from upgrading conventional natural gas boilers with automatic electric dampers or upgrading conventional electric furnaces with higher efficiency gas furnaces in some locations (e.g. 80 or 84 percent efficiency). Window upgrade opportunities include adding film as well as replacing single pane windows with double pane argon/super low-e windows in some locations.

In the DOD sector, basic envelope retrofits dominate the savings opportunities, as simply adding insulation in roofs and walls greatly diminishes space-conditioning loads. Shell retrofits appear large in DOD because of the overall age of the stock still in active use. There are more small, 1-story and 2-story buildings compared to the civilian stock – thus much greater roof area subject to retrofit. The age is indicative of poorly insulated buildings, where simply adding roof and wall insulation where none has been provides significant savings in cold climates.

**Table 8.** Technology retrofit energy savings opportunities at the end use level (Percent of aggregate savings)

End Use	Civilian	DOD
Lighting	39.8%	8.4%
Space Heating	22.5%	17.7%
Windows	17.8%	3.0%
Water Heating	12.9%	7.2%
Walls (insulation)	4.5%	21.2%
Floors (insulation)	1.8%	2.7%
Roof	0.7%	39.6%
Cooling and Heating/Cooling (heat pumps)	0.0%	0.2%

### 3.2 Construction of New Buildings

The federal inventory will experience some turn over between 2016 and 2025, as old buildings are retired and new buildings are constructed. It is important to consider separately the impact that new



buildings will have on the efficiency of the federal building stock because new federal buildings are subject to more stringent design standards aimed at improving their energy performance. Specifically, the 2005 Energy Policy Act (EPAct 2005) requires that newly constructed federal buildings achieve 30 percent energy savings relative to the most recently published ASHRAE Standard 90.1.<sup>10</sup>

The objective of this analysis was to establish how requirements to adhere to new building efficiency standards might impact energy performance of newly constructed federal buildings.

In the absence of data showing the impact that the current efficiency standards have had on new building EUI performance to date, the methodology to estimate the impact of new building construction on future EUI of federal buildings relies heavily on analyst judgment, but uses empirical data where it is available. This involved first establishing the percentage of new building floor space that was likely to comprise the federal building stock at the end of the goal-setting period (2025). Then, the difference in the average EUIs of new buildings constructed during the goal period (2016-2025) was compared to the expected EUI of the building stock at the beginning of the goal-setting period (2015). This approach is described briefly below and in more detail in Appendix B.

### **3.2.1 Newly Constructed Floor Space**

A simple model was developed to project the newly constructed floor space by considering the amount of floor area that might be replaced (e.g., due to demolition, sale, or transfer) and an annual growth of floor area that may be required to meet each agency's mission. Annual disposal rates were established for each major agency using disposal data reported in the FRPP for fiscal years 2006 through 2012 for civilian agencies. Data reported to FEMP was used to estimate USPS disposals as USPS does not report its facilities in the FRPP. DOD floor area disposal estimates came from the DOD's Base Structure Report. These rates – along with an implied growth in total floor space projected to be the same as the U.S. population growth rate – were used to establish future disposals and potential new construction estimates. These assumptions were vetted, and in a few cases modified, by the agencies.

The result of this analysis was an estimated amount of newly constructed floor area that would be added between 2016 and 2025, and the percentage of the total federal building stock that the new construction would represent in 2025. This was done for both goal-subject buildings as well as the entire building stock (see “All Floor Area” in Table 9).

The columns highlighted in Table 9 are used to measure the impact of new energy-efficient buildings on the EUIs of the total floor space stock in the year 2025. Based on the assumptions used, the civilian sector (excluding USPS) is expected to see more new construction than the DOD. The much slower growth rates in the overall stock for the USPS and the DOD will minimize the influence of new energy-efficient buildings on the overall intensity change over the next goal period of FY 2016-2025.

---

<sup>10</sup> American Society of Heating, Refrigerating, and Air-Conditioning Engineers (ASHRAE). Major editions of non-residential energy standards issued by ASHRAE were published in 1989, 1999, 2004, 2007, and 2010. The standards are referenced as 90.1-year, where 90.1 is the standing ASHRAE committee dealing with energy efficiency standards for nonresidential buildings.

**Table 9.** Floor space and new construction projections, FY 2016-2025 (millions of square feet)

Agency	2015 SF in Inventory (millions)		2025 SF in Inventory (millions)		Projected New Construction Additions to Inventory			
	Goal-Subject Only	All Floor Area	Goal-Subject Only	All Floor Area	Goal-Subject SF Added 2016-2025	Pct. of Goal-Subject SF in 2025	All SF Added 2016-2025	Pct. of All SF in 2025
Civilian	880	989	940	1,056	149.0	16%	169.7	16%
DOE	102	118	106	122	16.1	15%	18.6	15%
GSA	181	213	196	231	36.2	18%	42.6	18%
DOJ	72	72	78	78	8.9	11%	8.9	11%
VA	183	183	197	197	19.5	10%	19.5	10%
USDA	59	59	62	62	13.0	21%	13.0	21%
DHS	48	49	52	53	11.8	23%	12.0	23%
DOI	60	60	63	63	11.3	18%	11.3	18%
NASA	33	40	35	42	3.8	11%	4.6	11%
All Other	142	196	151	209	28.3	19%	39.1	19%
USPS	271	271	265	265	4.0	1.5%	4.0	1.5%
<b>Civilian &amp; USPS</b>	<b>1,151</b>	<b>1,260</b>	<b>1,205</b>	<b>1,321</b>	<b>153.0</b>	<b>13%</b>	<b>174</b>	<b>13%</b>
<b>DOD</b>	<b>1,804</b>	<b>1,833</b>	<b>1,847</b>	<b>1,877</b>	<b>81.0</b>	<b>4%</b>	<b>82.3</b>	<b>4%</b>
<b>All Federal</b>	<b>2,955</b>	<b>3,093</b>	<b>3,051</b>	<b>3,198</b>	<b>234.0</b>	<b>7.7%</b>	<b>256.0</b>	<b>8.0%</b>

### 3.2.2 Impact of ASHRAE Standards and Other Factors on Newly Constructed Building EUIs

To project what contribution the new, more efficient federal buildings constructed over the period 2016-2025 would have on the overall EUI of the federal building stock, the research team attempted to quantify the influence of several individual factors that would influence the performance of newly constructed buildings. These included:

1. The average EUI of the stock of buildings in the starting year of the goal setting period (2015)
2. The impact of the current ASHRAE Standard 90.1-2010 on new construction
3. The impact of a hypothetical future ASHRAE Standard 90.1-2016 on new construction
4. Requirements that new federal buildings must exceed energy efficiency improvements called for in the ASHRAE 90.1 standards by 30 percent
5. Increased energy use in new buildings that results from greater utilization and higher electric plug loads as compared to existing buildings.

First, to establish the baseline stock EUI, it was assumed that the current stock of buildings (and those in 2015) could be characterized relative to buildings built to meet ASHRAE Standard 90.1-2004. A recent DOE study to characterize the energy intensities of various vintages of all commercial buildings was used to establish the EUI of the current stock of federal buildings. It was assumed that recently constructed federal buildings built to ASHRAE 90.1-2004 would have an average EUI of about 10 percent below the

existing stock of buildings, as is shown in the first column of Table 10. (See Appendix B for further discussion underlying this assumption.)

Second, the research team estimated the impact that the subsequent ASHRAE Standard 90.1-2010 would have on the EUIs of new federal buildings constructed to this standard. ASHRAE Standard 90.1-2010 is the currently pending federal energy standard for new federal construction after July 9, 2014, so will provide the basis for new construction at the beginning of the goal period. Based on a recent study by PNNL (Thornton et al., 2011) on reductions in energy use between buildings built to the 90.1-2004 and the 90.1-2010 editions of ASHRAE, it was assumed that buildings designed to ASHRAE Standard 90.1-2010 will use about 24 percent less energy than those designed to ASHRAE Standard 90.1-2004. (See “New Standard 90.1 Relative to 90.1-2004”, row 1 in Table 10.)

Third, the impact of future ASHRAE standards was considered. ASHRAE standards are typically issued on a three-year cycle, therefore it is expected that at least one new standard will be issued between 2016 and 2025. While it is difficult to predict the stringency of the 90.1 Standard for each future cycle, the research team attempted to account for the impact of future standards by positing a single step increase in the federal building standard during the goal period. It was assumed a new standard issued by the end of 2016 would become the baseline for federal new construction and begin having an impact on buildings built after 2020, therefore would affect construction in the second half of the goal period.

A recent PNNL report suggests reductions of 7 percent over each three-year cycle of the Standard 90.1 based on historically observed efficiency improvements in the standard and expert judgment. This would indicate a reduction of 14 percent in the overall EUI between the current standard 90.1-2010 and a hypothetical 90.1-2016 standard.<sup>11</sup> In light of the speculative nature of future standards, this analysis takes a conservative position and assumes the 2016 standard might reflect a 10 percent improvement over the 90.1-2010 Standard. This 10 percent increase in the percentage savings results in a total estimated savings of 34 percent compared to the 2015 base year stock EUI. (See “New Standard 90.1 Relative to 90.1-2004”, row 2 in Table 10.)

Fourth, the research team considered the impact of the 2005 EAct requirement that newly constructed federal buildings achieve an energy savings of 30 percent greater than the most recently published ASHRAE Standard 90.1. The 30 percent target, however, is contingent on the additional energy efficiency design features to be cost effective therefore that not all buildings will achieve this. Furthermore, the energy standard for new federal building construction based on Standard 90.1-2010 will start during 2014 which could make it more challenging to achieve the additional 30 percent improvement in 2015. Because there is no basis for establishing compliance with the beyond ASHRAE requirement, this analysis has taken a conservative position and assumes the average improvement beyond ASHRAE will be only 10 percent. (See “Federal Design over Relevant Standard” in Table 10).

The fifth factor considered works in an opposing fashion to the previously discussed factors. There is reason to believe that new commercial buildings could have a greater EUI on average than the existing stock as new buildings will likely have higher utilization (hours of operation per week), higher occupant density, and higher plug loads from growing density of computer equipment and servers in new buildings

---

<sup>11</sup> This activity is part of PNNL’s support of DOE’s Building Energy Codes Program. PNNL is developing a cost-effectiveness analysis of proposed changes in the 90.1 Standards, to be presented to ASHRAE and DOE by the end of calendar 2013. When completed, this analysis will likely provide a more defensible basis for projecting additional stringency in 90.1 over the next several cycles.

compared to existing buildings. The 2003 Commercial Building Energy Consumption Survey (CBECS) provides some validation of this assumption. (See more detailed discussion in Appendix B). As a result, the analysis here assumes that these factors might offset the increases in design efficiency by an average 15 percent. (See “Greater Energy Demand” in Table 10.)

**Table 10.** Impact of new construction meeting ASHRAE Standard 90.1-2010 and a hypothetical future Standard 90.1-2016 on average building stock EUI in 2025

<b>Standard</b>	<b>90.1-2004 Relative to 2015 Stock</b> (Reduction)	<b>New Standard 90.1 Relative to 90.1-2004</b> (Reduction)	<b>Federal Design over Relevant Standard</b> (Reduction)	<b>Greater Energy Demand</b> (Increase)	<b>Average EUI Compared to 2015 Stock EUI</b> (Reduction)
90.1-2010	10%	24%	10%	15%	29%
90.1-2016	10%	34%	10%	15%	39%

Considering the collective impact of the five factors discussed above, the percentage difference between the average EUI in new federal buildings built to the new ASHRAE standards and the EUI of the 2015 stock is estimated to be 29 percent for those built to 90.1-2010 and 39 percent for those built to 90.1-2016. This overall impact is calculated as a sum of the percentage changes in first four columns, and by subtracting the increase in demand. (See last column of Table 10).

### 3.2.3 Impact on 2025 EUI of Federal Building Stock

The final step involved estimating the impact that new building construction has on the average EUI of the 2025 federal building stock. First, the relative amount of floor space built under the two efficiency standards discussed above was established. It was assumed that half of the new floor space constructed between 2016 and 2025 is effectively built to meet the baseline ASHRAE Standard 90.1-2010 and the other half meets the more stringent ASHRAE Standard 90.1-2016. The average reduction in EUI is then assumed to be 34 percent (i.e., an average of values in the last column of Table 10).

The average expected reduction in EUI was then applied to the 13.1 percent of all newly constructed floor space that civilian federal agencies were estimated to add to their building stock by 2015 (see “All Civilian” in Table 9). The product of these two percentages (13.1% x 34%) yields a value of 4.5 percent over the ten-year period. This reduction translates into an annual average reduction of approximately 0.4 percent (Table 11).

**Table 11.** Impact of new building construction on 2025 civilian stock EUI

	<b>Impact on Stock EUI in 2025 (total % reduction)</b>	<b>Average Annual Impact on EUI (% reduction/year)</b>
All Civilian	4.5%	0.4%
DOD	1.5%	0.2%
All Federal Agencies	2.7%	0.3%

The same type of calculation was performed for the military sector and for the total of all federal buildings. As shown in Table 11, the smaller projected percentage of new construction for all military

buildings (4.4%) yields a lower impact on the overall EUI, estimated to be 1.5 percent. For the combination of federal civilian and military categories, the new building impact is calculated to be 2.7 percent.

The values in Table 11 are shown as reflecting best judgment point estimates. Appendix B includes estimates of “high” and “low” values that incorporate some informal uncertainty analysis pertaining to the underlying elements of EUI reductions for new buildings.

The incremental impact for the new stock contribution reflects the assumed higher energy efficiencies required by building codes and standards applicable to new construction. With time, as post-2015 construction becomes a larger share of the stock, natural improvement in the overall stock EUI will continue. The values shown in Table 11 reflect the contribution of these factors in the terminal year of this analysis, 2025.

### 3.3 Combined Impact of Retrofits and New Construction on Federal Building Stock EUI

By the end of the goal period in 2025, the estimated federal stock total EUI reduction potential is 22.6 percent (see Table 12). That is the weighted average of the civilian improvement potential (15.7%) and the potential in DOD facilities (24.0%).

**Table 12.** Estimated EUI impact from both cost-effective retrofits to existing buildings and federal energy standards for new construction (site energy basis)

Building Type	Existing Buildings				New Buildings	Total Stock	
	2015 EUI	2025 EUI Reduction (Efficiency Only)		2025 EUI	2025 EUI Reduction	2025 EUI	
	kBtu/SF	kBtu/SF	Pct.	kBtu /SF	kBtu/SF	kBtu/SF	Pct. Change
All Civilian	97.3	10.9	11.2%	86.3	4.3	82.0	15.7%
Civ: Health Care	151.9	15.9	10.5%	135.9			
Civ: Industrial	98.7	10.5	10.6%	88.2			
Civ: Laboratory	145.0	13.6	9.4%	131.5			
Civ: Office	92.0	10.6	11.5%	81.4			
Civ: Prison	129.1	13.5	10.5%	115.5			
Civ: School	73.8	9.2	12.5%	64.6			
Civ: Service	68.3	8.8	12.8%	59.5			
Civ: Warehouse	27.1	5.6	20.7%	21.5			
Civ: Other	84.1	10.0	11.9%	74.1			
DOD	91.0	20.4	22.5%	70.6	1.4	69.2	24.0%
Total Federal	93.1	18.5	19.9%	74.5	2.5	72.0	22.6%

As discussed in Section 3.1.4, some additional EUI reduction potential is likely feasible through implementation of onsite renewable energy projects. Up to 4 percent and 9 percent is estimated to be technically feasible in civilian and DOD buildings, respectively, over the ten-year goal period. Because

cost-effectiveness of renewable production projects can only be understood through site-level evaluations and the economics are largely influenced by factors such as future technology pricing and availability of state and federal incentives, there is a fair amount of uncertainty around the ability to exploit this potential ten years from now. However this may provide an upper limit to what is feasible.

Finally, it should be emphasized that the EUI reduction potential presented in this study does not represent a recommended reduction goal. These reflect a combined estimate of lifecycle cost-effective retrofit measures, estimated reductions from replacing a relatively small amount of old floor space with new, more efficient floor space, and a high-level estimate of technically feasible renewable projects. These aim to provide a much more informed estimate of reduction potential, however it is recognized that not all of the projects underlying these estimates may be practical or feasible to implement. Budgetary constraints, organizational limitations, and operational preferences will all influence what can ultimately be implemented. The cost estimates in section 3.1.5 are intended to illustrate the levels of funding that would be required to achieve these EUI values. The influence of other agency factors, such as availability of staffing resources for maintenance and operations of these systems, cannot be anticipated as part of this study, but should be considered when setting specific goals.

## 4.0 Alternative Energy Performance Evaluation Approaches

Defining the best performance evaluation approach ultimately depends on what policymakers and the federal government want to accomplish with energy management. The National Energy Conservation Policy Act (NECPA), which serves as the underlying authority for current federal energy management goals, states the purpose of federal energy management as broadly promoting “the conservation and the efficient use of energy and water, and the use of renewable energy sources, by the Federal Government.”<sup>12</sup> The NECPA also cites benefits of increased energy efficiency as reducing the cost to government, reducing dependence on foreign energy sources, and demonstrating the benefits of energy efficiency to the nation. This suggests that energy use reduction, operational efficiency, cost savings, energy supply security, and technology demonstration are all important outcomes from this policy.

The current metric established in the NECPA (as amended by EISA 2007) and adopted by the federal government is EUI using site-delivered energy and a 2003 baseline year. While not perfect, EUI is reasonable measure of the energy management goal outlined in the NECPA. It can be implemented in many different ways however. In the section below, different approaches to setting EUI targets and baseline years are considered. In addition, some alternative approaches are presented that may offer more accurate measures of energy performance, environmental impacts, and/or ancillary benefits, such as cost savings.

The primary options evaluated included:

- Using site versus source EUI as the performance metric
- Including only goal-subject versus all federal buildings
- Using 2003 and alternative baseline years

---

<sup>12</sup> 42 USC § 8251.

- Establishing a single federal target versus agency- or sector-specific targets
- Establishing intensity versus absolute reduction goals

## 4.1 Site vs. Source EUI

### 4.1.1 Description of Source Energy Calculations

Agencies currently report EUI performance using site energy as a basis for the calculation. *Site energy* refers to the amount of heat input and electricity delivered to a building and consumed as reflected at the meter. In contrast, *source energy* refers to the total amount of raw fuel that is required to operate the building, including all transmission, delivery, and losses associated with the production of secondary energy products, such as purchased electricity and heat from district steam. In the 1980s, energy reduction goals were established as source energy,<sup>13</sup> but since then agency energy performance has been evaluated on a site energy basis.

FEMP is considering using a modified source energy factor—referred to here as fossil-source energy—as a basis for evaluating agency energy performance in the future. Whereas source energy considers the heat input of all fuels (renewable and non-renewable), *fossil-source energy* accounts for the heat input of only the raw fossil fuels required to operate a building and excludes the heat input from non-greenhouse gas emitting energy resources including hydropower, nuclear power, and non-combustible renewables. The benefits and drawbacks of each approach are discussed below, followed by an illustration of the impact these factors would have on past and projected future energy performance.

Fossil-source energy EUI is calculated the same as site energy except that the amounts of purchased electricity and steam are increased to reflect total primary energy use at the generation plant.<sup>14</sup> Because the total primary energy consumed is greater than the energy consumed on site, EUI calculated using source energy is always larger than EUI calculated using site energy. Furthermore, the amount of primary fossil energy required varies from site to site based on the fuel mix of the eGRID subregion that the building draws from. By dividing heat input at the generation plant by net generation, a set of primary energy conversion factors can be calculated for each subregion and applied to on-site electricity consumption to determine total source energy. Alternatively, a national primary energy conversion factor can also be derived.

$$\text{Fossil Source Energy Factor} = \frac{\text{Heat Input from Fossil Fuels}}{\text{Net Generation}}$$

The national fossil energy factor applied to all electricity consumed by federal agencies is 1.98 using the most recent eGRID summary data for the U.S. Table 13 below shows fossil-source energy factors by eGRID subregion. Variation in fossil-intensity by eGRID region can be viewed in the heat map in Appendix D.

<sup>13</sup> In the Annual Report to Congress on Federal Government Energy Management for FY 1989, electricity was reported as total source energy using a conversion factor of 11,600 Btu/kWh. Starting in FY 1990, electricity use was reported to Congress as site energy, using a conversion factor of 3412 Btu/kWh.

<sup>14</sup> For simplicity, a transmission and distribution loss factor is not included in the calculation of the fossil source energy factor, because such a factor would have no impact on the final calculation of percent change in EUI.

**Table 13.** Fossil-source energy using regional eGRID factors

Subregion	FY 2008	FY 2012	Subregion	FY 2008	FY 2012
AKGD	2.81	2.77	NYLI	2.98	2.97
AKMS	1.02	0.98	NYUP	1.18	0.92
AZNM	2.15	2.04	RFCE	1.67	1.55
CAMX	1.57	1.53	RFCM	2.56	2.48
ERCT	2.25	2.11	RFCW	2.27	2.19
FRCC	2.26	2.26	RMPA	2.98	2.80
HIMS	2.48	2.47	SPNO	2.68	2.64
HIOA	2.78	2.75	SPSO	2.75	2.64
MROE	2.59	2.34	SRMV	2.02	1.94
MROW	2.53	2.32	SRMW	2.6	2.46
NEWE	1.78	1.60	SRSO	2.34	2.15
NWPP	1.38	1.32	SRTV	2.31	2.02
NYCW	1.67	1.46	SRVC	1.72	1.62

Note that, using the eGRID source calculation methodology, electricity generated using geothermal, hydropower, nuclear, wind, or solar sources is assigned a heat input of zero. As a consequence, regions such as upstate New York (NYUP), where hydropower and nuclear comprise more than 60 percent of generating capacity, have comparatively low fossil-source energy factors.

#### 4.1.2 Benefits and Drawbacks

Table 14 summarizes some of the trade-offs between using site and source energy as the basis for measuring EUI reduction performance.


Site energy has the benefit of being consistent with the current approach to performance evaluation. Site energy also provides a more useful gauge of the impact of ECMs implemented at the site level to save energy, as it isolates site energy use from changes in the generation mix at the regional or national level. Since changes in the fossil-fuel intensity of the generation mix can drive total source energy consumption (and therefore source EUI) up or down independently of facility energy management decisions, using source energy to calculate EUI may obscure the effects of agency actions to improve building energy efficiency. However, it should be noted that agencies would likely continue reporting energy use in site-delivered terms, so both factors could be derived and used for different purposes. Furthermore, other sources of federal energy data reporting (i.e., the Compliance Tracking System) are available to provide a measure of the impact of ECMs implemented at the facility level.



**Table 14.** Benefits and drawbacks of using site energy versus source energy to calculate EUI reductions

	<b>Benefits</b>	<b>Drawbacks</b>
<b>Site Energy</b>	<ul style="list-style-type: none"> <li>• Consistent with current reporting approach</li> <li>• Isolates the impact of actions taken by agency to improve efficiency from changes to grid</li> </ul>	<ul style="list-style-type: none"> <li>• Amount of Btu from electricity in a building’s fuel mix is underrepresented in terms of the cost paid for those fuels</li> <li>• Underrepresents the benefit of projects that save electricity</li> <li>• Necessitates an accounting credit for certain types of projects (combined heat and power)</li> </ul>
<b>Fossil-Source Energy</b>	<ul style="list-style-type: none"> <li>• Increases the amount of Btu from electricity in the fuel mix to more closely reflect the cost of that energy</li> <li>• More accurately characterizes the benefit of electricity-saving projects</li> <li>• Building performance is not credited or penalized for using a particular fuel type</li> <li>• Addresses Congressional interest in fossil energy reduction</li> <li>• Purchased renewable energy would count toward energy reduction goal</li> </ul>	<ul style="list-style-type: none"> <li>• Impact of agency actions to improve building efficiency may be masked by changes in the grid</li> <li>• Improvements in EUI performance will be the result of both agency actions and grid improvements, making it difficult to isolate the impact of agency actions.</li> <li>• Agencies could show progress through renewable energy purchases without making any reductions to energy use at the building level</li> </ul>

The primary driver for using a fossil-source energy factor is to provide a more complete accounting of the full energy impacts from electricity use, including production and transmission and distribution (T&D) losses. Using site energy underestimates the total energy use attributable to purchased electricity and steam, as well as the relative costs of those fuel sources, as shown in Figure 22. Source EUI more closely aligns the proportion of total energy use of each fuel source with the proportion of total cost of that fuel source. Consequently, using source energy to calculate EUI removes the credit that buildings currently receive for using more purchased electricity and steam relative to other fuels.



**Figure 22.** Proportion of total cost vs. proportion of total energy use by fuel source using the DOE FY 2012 data

Another benefit to using source energy to calculate EUI would be to more closely align reporting on progress against the energy performance requirement with reporting on progress against the greenhouse gas goals mandated by Executive Order 13514. Greenhouse gas emissions are also calculated based on

the fossil-intensity of the grid using eGRID factors. As the overall fossil intensity of the grid decreases, agencies would benefit from this as well.

Finally, the use of a fossil-source energy scenario would change the rules regarding accounting for purchased renewable energy. While purchased renewable energy (i.e., Renewable Energy Certificates) does not currently count toward the EUI reduction goal using site energy, these purchases would count toward the EUI goal under the fossil-source energy scenario. If the electricity purchased by the agency is not coming from a fossil source, its source energy would have a factor of zero. The drawback to this approach is that an agency could actually increase electricity consumption significantly at the building level and still show an EUI reduction through purchases of renewable electricity.

As noted above, a fossil-source energy factor can be derived using a national average factor or using regional factors specific to the fuel mix in each eGRID subregion. Use of each of these approaches has its own advantages and disadvantages as summarized in Table 15. Use of a national factor offers the benefit of simplicity; a single factor is used regardless of the location of the agency’s facilities. On the other hand, using a national factor may provide less incentive for agencies to direct energy-saving investments into the most fossil-intensive regions (although in theory greenhouse gas emission goals would still provide this incentive). Using a regional factor may provide an additional incentive to make efficiency investments where it matters most (i.e., in the most fossil-fuel intensive regions) and provides a more accurate estimate of each building’s energy use based on the predominant fuels used to generate electricity in the building’s region. While EUI using regional factors will be slightly more complex for agencies to calculate, at the federal level the current energy reporting structure for greenhouse gas emissions calculations already maps to eGRID subregions, so there would be additional reporting requirements.


**Table 15.** Benefits and drawbacks of using national versus regional source energy factors to calculate EUI reductions

	<b>Benefits</b>	<b>Drawbacks</b>
<b>National Factors</b>	<ul style="list-style-type: none"> <li>• Provides a single, consistent factor for all agencies and locations</li> <li>• Similar to the U.S. Environmental Protection Agency’s (EPA’s) Energy Star Portfolio Manager methodology, which uses a national non-fossil source factor for benchmarking</li> </ul>	<ul style="list-style-type: none"> <li>• No additional benefit from reductions in more fossil-fuel-intensive regions</li> <li>• Improvements in energy performance are determined in part by factors outside of the agency’s control</li> </ul>
<b>Regional Factors</b>	<ul style="list-style-type: none"> <li>• Rewards agencies for reductions in more fossil-energy-intensive locations</li> <li>• More accurately reflects total fossil energy use based in the building’s region</li> </ul>	<ul style="list-style-type: none"> <li>• More complex to calculate</li> <li>• Each agency will have a unique factor based on building locations, which will vary over time</li> <li>• Improvements in energy performance are determined in part by factors outside of the agency’s control</li> </ul>

To establish how using site versus fossil-source energy might influence agency goals, the research team examined the impact that using a source energy factor percentage would have had on past federal building energy performance as well as the savings potential from future retrofits, as discussed below.

### 4.1.3 Impact on Past Performance

Past EUI reduction performance was compared using fossil-source energy versus site energy for five of the largest energy-using agencies: VA, USPS, DOE, GSA, and DOD (Figure 23). This was done using both a national average factor (based on eGRID estimates of source energy production) and using regional factors for each eGRID subregion. Only the years 2008-2012 were examined because agency electricity consumption data was not reported by eGRID subregion prior to 2008. EPA published two versions of eGRID during this period; therefore the factors vary over time and the appropriate versions are referenced in each data year. For example eGRID 2010 is based on the 2007 fuel mix, and was applied to the agency's FY 2008 baseline data. The next version of eGRID (2012, which is based on 2009 fuel mix) was applied to agency data reported for FY 2009-2012.



**Figure 23.** Percentage of EUI reduction by agency, FY 2008-2012

While source EUIs are always higher than site EUIs, the impact on EUI reduction will vary based on the source of the savings. Agencies with energy savings from electricity reduction measures will see greater benefit from use of source energy than agencies that save more energy from fossil-fuel reduction measures. For example, between FY 2008 and FY 2012, DOE reduced its use of electricity by 11.8 percent, while VA's use of electricity increased by 6.8 percent. As a consequence, DOE's percentage EUI reduction is larger using source EUI rather than site EUI, while VA's percentage EUI reduction is smaller using source EUI rather than site EUI.

### 4.1.4 Impact on Future Energy Savings

The EUI reduction potential reported on a site-energy basis in Table 4 was also estimated on a source-energy basis, as shown in Table 16. Source energy impacts are driven by changes in electricity use

induced by the types of ECMs and by the replacement of grid power with onsite renewable power from a combination of wind and solar PV technologies.

**Table 16.** Estimated EUI impact of both cost-effective retrofits to existing buildings and federal energy standards for new construction (on a source energy basis)

Building Type	Existing Buildings				New Buildings	Total Stock	
	2015 EUI	Estimated 2025 EUI Reduction (Efficiency Only)		Estimated 2025 EUI	Estimated 2025 EUI Reduction	Estimated 2025 EUI	
	kBtu/SF	kBtu/SF	Pct.	kBtu /SF	kBtu/SF	kBtu/SF	Pct. Change
All Civilian	179.4	23.2	12.9	156.2	7.2	149.0	16.9%
Civ: Health Care	276.0	36.3	13.2	239.7			
Civ: Industrial	193.2	24.6	12.7	168.6			
Civ: Laboratory	290.1	36.2	12.5	253.9			
Civ: Office	164.8	21.0	12.8	143.8			
Civ: Prison	234.6	30.9	13.2	203.8			
Civ: School	130.7	17.0	13.0	113.8			
Civ: Service	120.5	15.8	13.1	104.8			
Civ: Warehouse	43.6	6.6	15.2	36.9			
Civ: Other	150.1	19.3	12.8	130.8			
DOD	230.4	59.6	25.9	170.8	3.1	167.7	27.2%
Total Federal	218.1	49.1	22.5	169.0	5.3	163.7	24.9%

Considering the reduction potential using site versus source energy overall, there does not appear to be much difference in the energy savings potential from 2015 to 2025. The total federal reduction potential with source energy is 25 percent compared to about 23 percent for site energy. The DOD sector has a slightly increased savings potential of 3 percent when using source instead of site energy because it is projected that relatively less direct fossil fuel energy would be displaced by the ECMs modeled than source electricity. Thus the site-to-source factor applied to electricity has more effect in the calculations.

The civilian sector shows a total savings potential (including efficiency, renewables and new construction) of about 16.9 percent when using source energy compared to 15.7 percent when using site energy. It is likely that the civilian stock is more heavily weighted to electricity and therefore the site-to-source multiplier has relatively more effect on savings in these buildings.

It is generally difficult to predict how use of site versus source energy will affect EUI savings by agency. Whether source savings are greater than site savings depends on the agency’s baseline energy use, fuel mix, and the types of retrofits being implemented. The generic scenarios in Table 17 help to illustrate how these factors would influence the percent savings an agency might achieve based on their current fuel mix. In general, the fossil source metric results in greater reductions for projects that save electricity, which is often what ECMs target as a source of greater opportunity and cost savings.

**Table 17.** Illustration of the impact using of site energy vs. source energy on percent of energy savings

	Site				Source		
	Electricity (Btu)	Gas (Btu)	Pct. Savings		Electricity (Btu)	Gas (Btu)	Pct. Savings
<b>Scenario 1: Equal site electricity and gas</b>							
Baseline 1	100	100		Baseline 1	211	100	
Retrofit 1	70	100	15%	Retrofit 1	148	100	20%
Retrofit 2	100	70	15%	Retrofit 2	211	70	10%
Retrofit 3	70	70	30%	Retrofit 3	148	70	30%
<b>Scenario 2: Heavy electricity and light gas</b>							
Baseline 2	150	50		Baseline 2	317	50	
Retrofit 1	105	50	23%	Retrofit 1	222	50	26%
Retrofit 2	150	35	8%	Retrofit 2	317	35	4%
Retrofit 3	105	35	30%	Retrofit 3	222	35	30%
<b>Scenario 3: Light electricity and heavy gas</b>							
Baseline 3	50	150		Baseline 3	106	150	
Retrofit 1	35	150	8%	Retrofit 1	74	150	12%
Retrofit 2	50	105	23%	Retrofit 2	106	105	18%
Retrofit 3	35	105	30%	Retrofit 3	74	105	30%

## 4.2 Goal-Subject vs. All Buildings

Another alternative considered for the next goal-setting period was the inclusion of all federal buildings. Currently energy reduction goals apply to a subset of federal facilities (i.e., goal-subject facilities) and allow agencies to exclude facilities from these goals if they meet specific exclusion criteria outlined by DOE, including

1. Energy requirements are impracticable;
2. All federally required energy management reports have been completed and submitted;
3. Agency has achieved compliance with all energy efficiency requirements; and
4. All practicable life-cycle cost-effective projects are implemented at the excluded building(s).<sup>15</sup>

Agencies currently report on energy use and the square footage in goal-subject and excluded buildings separately. In FY 2012 goal-subject buildings comprised about 95 percent of floor area and 88 percent of total reported energy use. Benefits and drawbacks of continuing to exclude these buildings in the next goal period are summarized in Table 18.

<sup>15</sup> U.S. Department of Energy – Federal Energy Management Program. 27 Jan., 2006. “Guidelines Establishing Criteria for Excluding Buildings from the Energy Performance Requirements of Sec. 543 of the NECPA as amended by the Energy Policy Act of 2005.”


**Table 18.** Benefits and drawbacks of basing energy reduction goals on goal-subject vs. all buildings

	<b>Benefits</b>	<b>Drawbacks</b>
<b>Goal-Subject Buildings Only</b>	<ul style="list-style-type: none"> <li>• Consistent with current approach</li> <li>• Focuses on buildings in which energy may be most effectively managed (high-energy, mission-critical exempted)</li> </ul>	<ul style="list-style-type: none"> <li>• Reporting two sets of numbers is more complicated</li> <li>• No credit for cost-effective projects saving energy in excluded facilities</li> <li>• Process operations within excluded facilities often present enormous opportunities for energy savings relative to the rest of the building inventory</li> </ul>
<b>All Buildings</b>	<ul style="list-style-type: none"> <li>• Simplifies reporting by establishing same boundaries as those used for greenhouse gas (GHG) reporting, requiring a single energy use number</li> <li>• Provides more accurate assessment of actual federal EUI</li> </ul>	<ul style="list-style-type: none"> <li>• Goal-excluded facilities often have lower energy efficiency reduction potential</li> <li>• Certain process loads may still need to be reported separately</li> <li>• Does not account for changes in agency mission requirements that lead to significant changes in energy use (e.g. supercomputer deployment)</li> </ul>

Maintaining the option to exclude energy intensive buildings from the calculation of EUI would be consistent with the current reporting approach. This approach may be more favorable to agencies because many excluded buildings are mission-critical facilities hosting energy-intensive process loads. While ECMs such as lighting retrofit measures should be implemented in these facilities, the ability to affect total building EUI *may* be limited by the magnitude of the process loads. Including these buildings in the overall calculation may constrain agencies’ ability to meet the energy performance requirement, by reducing the relative impact of energy efficiency and conservation measures implemented in goal-subject buildings on overall energy use. At the same time, the current approach does not award agencies credit for energy-saving measures that are taken in excluded buildings, which have led to sizeable savings in some buildings.

Eliminating the exclusion of certain facilities from the EUI performance goals would simplify the reporting process, as agencies would only need to provide a single set of energy use numbers by eGRID subregion. Eliminating the exclusion would more closely align energy performance reporting requirements with GHG reporting requirements, which does not distinguish between goal-subject and goal-excluded facilities. However, these may not align perfectly as certain structures and processes not qualified as federal buildings that are covered by GHG reporting would still be exempt from energy performance (e.g. federal ships that consume “Cold Iron Energy”, which supplies power and heat to ships docked in port). It would also provide a more accurate assessment of actual federal energy intensity.

To illustrate the impact of including goal-subject buildings in the EUI reduction goals, the energy use and associated building square footage of excluded buildings was added back into the federal building inventory (Figure 24).



**Figure 24.** Reduction in site EUI for goal-subject buildings and all buildings, FY 2008-2012

The analysis of the impact of future retrofit measures on overall EUI was based on total floor area in the federal sector. The modeling approach did not allow for separate model runs in goal-subject and goal-excluded buildings. Similarly, no distinction between goal-subject and goal-excluded buildings was made for the impact of new buildings, as there is no reliable basis for establishing prototypes that would exclude floor area not subject to efficiency goals. Any impact would be negligible, as the overall percentage of new building floor space that might be excluded under current high-intensity criteria would likely be less than one percent of the total 2025 stock.

### 4.3 FY 2003 vs. Alternative Baseline Years

A number of criteria should be considered when establishing the baseline year for the next federal energy reduction goal. Weather is one of the most important considerations when establishing a baseline year for energy performance goals, but other factors, including data quality and availability, consistency with other baseline year requirements, agency mission tempo, public perception around savings, and the diverse starting points of agencies should also be considered.

This section evaluates the advantages and disadvantages of maintaining the current baseline year of FY 2003 versus using alternative years for the 2025 energy reduction goal. Alternative years evaluated included FY 2008 (for consistency with greenhouse gas reporting) and either FY 2013 or FY 2015 to represent current baseline performance at the beginning of the goal period. Yet another alternative is to use a three-year average baseline to normalize for some of the factors described above.

#### 4.3.1 Weather

Ideally the baseline year would represent a fairly typical weather year in terms of the demand for heating and cooling of buildings. A simplistic analysis of heating degree days (HDD) and cooling degree

days (CDD) days in recent fiscal years provides some insight into how typical or anomalous different fiscal years have been and therefore which may provide an appropriate baseline year for a 2025 reduction target. The research team examined HDD and CDD data for 12 geographic locations with a significant portion of the federal building stock and compared those to historical averages over a 14-year period between FY 2000 and FY 2013. Data were derived using a simple online weather station reporting tool from EnergyCAP, Inc., ([www.weatherdatadepot.com](http://www.weatherdatadepot.com)) (Table 19). Conditional formatting was used to illustrate outlier years of either warmer- or colder-than-normal weather, based on degree days. Thus, the lighter the shades of coloring, the closer to the period average that year was for the specific location. To identify the best weather-neutral year across the wide geography of the United States, we would select a year that is reasonably lightly shaded at the USA (sum) line for both HDD and CDD.

The current baseline year of FY 2003 appears to be one of the colder years of the period examined (implying higher than average heating loads, and lower than average cooling loads). Visual inspection suggests either FY 2008 or FY 2013 as the most weather-neutral year, despite some geographic variation in those years. Alternatively, FY 2004 appears to be closest to the period average for HDD, while FY 2008 appears to be closest to the period average for CDD.

**Table 19.** Total heating degree days and cooling degree days for 12 U.S. cities

Heating Degree Day Summary (FY Basis and 65°F Basis)

Year	2000	2001	2002	2003	2004	2005	2006	2007	2008	2009	2010	2011	2012	2013
Atlanta	2413	3062	2363	2863	2657	2527	2638	2444	2530	2713	3203	2790	1977	2517
Chicago	5047	6068	5239	6373	5964	5712	5767	5945	6263	6419	5768	6424	4939	6163
Dallas	1541	2647	2063	2303	1861	1762	1606	2064	1966	1898	2470	2003	1823	1819
DC	3630	4315	3300	4565	4026	4021	3710	3954	3454	4216	3828	4002	3119	3759
Denver	5237	6359	5988	6100	5735	5780	5566	6074	6123	5619	6337	5796	5599	6014
Houston	835	1554	1124	1344	1085	953	923	1180	932	1000	1621	1126	891	972
LA	941	1335	1060	923	1002	1052	1090	764	1148	826	822	1134	1404	949
Memphis	2486	3411	2675	3164	2803	2405	2658	2765	2750	2967	3244	2945	2226	2929
New York	4479	4954	3853	5301	4800	4707	4287	4458	4466	4843	4343	4750	3818	4614
Phoenix	803	1175	871	664	903	861	745	949	958	708	914	893	968	881
Seattle	4783	5073	5021	4458	4474	4452	4400	4752	5152	4867	4642	4999	4941	4191
St. Louis	4056	5246	4145	4947	4333	4230	4297	4423	4823	4767	4874	4912	3563	4658
USA (sum)	36251	45199	37702	43005	39643	38462	37687	39772	40565	40843	42066	41774	35268	39466

Cooling Degree Day Summary (FY Basis and 65°F Basis)

Year	2000	2001	2002	2003	2004	2005	2006	2007	2008	2009	2010	2011	2012	2013
Atlanta	1870	1691	1989	1664	1811	1835	2048	2225	1949	1895	2382	2242	2074	1727
Chicago	1017	974	1260	700	687	1197	936	997	873	587	1132	1001	1269	816
Dallas	3255	2983	2907	2838	2819	3276	3563	2846	3128	2981	3223	3741	3275	3334
DC	1228	1401	1844	1338	1565	1666	1545	1702	1815	1461	2095	1913	1864	1679
Denver	962	974	917	758	511	913	961	975	828	533	862	871	1119	997
Houston	3451	3122	3176	3092	3182	3534	3349	3328	3575	3482	3316	3851	3398	3356
LA	1335	981	974	1166	1388	950	1590	1376	1447	1565	1206	980	992	1310
Memphis	2468	2366	2329	1938	2148	2600	2532	2784	2342	2154	2753	2538	2611	2191
New York	899	1195	1386	1031	1061	1440	1150	1139	1248	876	1541	1273	1193	1240
Phoenix	4973	4793	5139	4791	4977	4554	4824	5091	4845	5010	4589	4884	4824	5186
Seattle	109	72	162	273	273	162	270	192	193	314	162	100	154	385
St. Louis	1345	1510	1667	1273	1144	1555	1474	1711	1301	1204	1570	1603	1802	1368
USA (sum)	22912	22062	23750	20862	21566	23682	24242	24366	23544	22062	24831	24997	24575	23589

Warmer than average  
Colder than average



### 4.3.2 Other Factors

Factors other than weather that might influence baseline year selection include

- **Data quality** – The quality of energy use and building area data reported should be considered. As metering of facilities and reporting have become more commonplace across the federal sector, driven in part by the EAct 2005 advanced metering requirements, data quality has improved. While there may be site-specific exceptions, more recent baseline years are believed to be much more accurate for this reason. This suggests that FY 2013, which was also a typical weather year, may be a very good option. Alternatively, establishing a future year as the baseline year at the beginning of the goal period (2015) would give agencies an opportunity for advance preparation for data collection and potential adjustments for mission tempo and other factors.
- **Consistency with other baseline years** – Currently agencies have an FY 2003 baseline for EUI reduction goals and a FY 2008 baseline for facility greenhouse gas reduction goals. Both the EUI and greenhouse gas goals rely on the same data inputs. Tracking progress could be simplified if the baseline years for both goals were aligned and FY 2008 was used moving forward.
- **Mission tempo** – Mission tempo, or the rate of operations relative to a typical year for the agency, can have a big impact on energy use, particularly for the DOD. Mission tempo will vary across agencies year to year, and it is unlikely that a single year will be typical for all agencies. While FY 2003, FY 2008, and FY 2013 do not appear to be anomalous in terms of unusual spikes in agency energy use reporting, agencies should be consulted on these options to verify that assumption.
- **Perceived savings** – The baseline year selected will influence the percent reduction in EUI that is feasible. Maintaining the current FY 2003 baseline year would result in an additive goal; for example, the current 30 percent through 2015 plus another 20 percent of savings from 2015-2025 results in a total goal of 50 percent. This would convey the cumulative progress made by the federal government over two decades. Using a more recent baseline year—and a setting a lower percent reduction goal—may give the impression that the federal government is not doing enough to reduce energy use, when in fact significant reductions have already been made.
- **Accounting for diverse starting points** – Individual agencies have shown a wide range of progress toward the EUI reduction goals between 2003 and 2012, from a modest 3 percent up to 45 percent savings. The amount of future savings potential ultimately depends on the starting point of each agency, including the nature of their buildings, operations, and types of ECMs that have already been implemented. Maintaining the current baseline year of FY 2003 would allow agencies that have done more already to do less in the future, as they likely have lower savings potential. Those agencies would not be penalized for having already made substantial reductions. In contrast, agencies that have fallen well short of the 30 percent goal to date would be expected to catch up by FY 2025. If a more recent goal year were used, such as FY 2013, agencies would be starting with a clean slate.
- **Availability of electricity data by region** – Federal agencies did not begin reporting electricity data by eGRID subregion until FY 2008, when it was required to support greenhouse gas

reporting. If the federal government were to move toward a fossil-source energy accounting approach based on regional factors, the only feasible baseline years would be FY 2008 and after.

Table 20 summarizes these variables and the baseline years considered, and provides a simplistic evaluation of how each year rates against the criteria discussed above. For example, FY 2013 and FY 2008 appear to be good potential baseline years considering the impacts of weather on energy use, whereas the current FY 2003 baseline year was not a typical weather year. A limitation of using FY 2015 is that weather and other factors that may influence energy performance are unknown at this point.

**Table 20.** Possible baseline years and an evaluation of how each year rates against different criteria; green is a comparatively good year, yellow is neutral, and red is comparatively bad

Baseline Year Selection Factor	FY 2003	FY 2008	FY 2013	FY 2015
Weather	red	green	green	unknown
Data quality	red	yellow	green	likely
Consistency with other baseline years	yellow	green	unknown	unknown
Mission tempo	green	green	green	unknown
Perceived savings	green	yellow	red	red
Account for diverse starting points	green	yellow	red	red
Availability of electricity data by region	red	green	green	green

#### 4.4 Single vs. Distinct or Tiered Performance Goals

Currently, all federal agencies are working toward a single EUI reduction goal. An alternative approach is to establish unique targets based on each agency’s future savings potential, or two to three tiers of targets (e.g. 30%, 20%, and 10%) that would apply to different agencies. Establishing a single goal for all agencies is the simplest approach and would facilitate tracking. A single federal goal has been established for almost all federal energy requirements with the exception of the greenhouse gas emissions management, which allowed each agency to evaluate their reduction potential and negotiate a goal with the Offices of the White House.

Setting agency-specific or tiered goals would provide an opportunity to better align goals with each agency’s potential to reduce energy. Agencies that have already made substantial EUI reductions would not be penalized by having to achieve a goal that is beyond their potential, and agencies that have lagged on progress would be pushed to do more. Rather than setting a conservative goal that works for all agencies, unique goals that are based on each agency’s true potential may allow for greater government-wide savings. For this approach to be effective, however, goals must be based on well-informed estimates of savings potential. These might be based on a combination of prior EUI reduction performance, current EUIs, and modeled estimated of future savings potential.

The analysis of savings achieved by each major agency to date illustrates that agencies have achieved a wide range of savings since the FY 2003 baseline. These EUI reductions from 2003-2012 range from 3 percent to 45 percent as illustrated in Table 3. However, only five scorecard agencies appear to be significantly lagging; most are on track to achieving their goals with savings in the 20 to 30 percent range.

This suggests that with the exception of a few high and low outliers, most agencies are reducing building EUI at a similar rate. Analysis of the average EUIs by agency also shows a wide performance range from 50,000 kBtu/SF to 300,000 kBtu/SF (see Figure 4), and about eight agencies with extremely high average EUIs. Agencies with both high EUIs and limited EUI reduction progress may be candidates for higher EUI reduction goals and vice-versa.

The forward-looking analyses of potential savings from existing building retrofits and new construction examined the potential savings from civilian agencies and the DOD separately to account for significant differences in utilization and performance of those facilities, but did not examine the savings potential of each agency. Further disaggregation by agency would have required several additional model runs and specific assumptions for each agency, and was beyond the scope of this effort.

## 4.5 Intensity vs. Absolute Reduction Goals

The benefits and drawbacks of using of an absolute energy (Btu) reduction target rather than an energy-intensity target are summarized in Table 21.

Currently Btu per square foot is used as the intensity metric and remains the most practical normalizing metric in light of data federal reporting and availability. However the limitations of this intensity Btu/SF metric to normalize energy performance should be considered. While private entities may normalize energy use using business metrics (e.g. energy use per million \$ of sales), such metrics are not practical for the federal sector. Furthermore, average occupant density, computer density, and other factors can also have a significant influence on building performance. In the case of occupant density, increased occupant density can be environmentally beneficial if it reduces the need for additional building area.

**Table 21.** Benefits and drawbacks of setting energy intensity vs. absolute reduction goals

	<b>Benefits</b>	<b>Drawbacks</b>
<b>Energy Intensity (Btu/SF) Reduction Goals</b>	<ul style="list-style-type: none"> <li>• Reflects performance improvements independent of increases and decreases in floor area</li> <li>• Enables performance comparison across agencies</li> </ul>	<ul style="list-style-type: none"> <li>• No guarantee that total energy consumption (and environmental impact) is reduced, even if intensity decreases</li> <li>• If normalization is the intent, EUI only partially normalizes energy use, as factors other than floor area can have a significant influence on performance (e.g. occupant density)</li> </ul>
<b>Absolute Energy Reduction Goals</b>	<ul style="list-style-type: none"> <li>• Environmental impact of reduction measures is easier to ascertain</li> <li>• Energy savings are more transparent to stakeholders</li> </ul>	<ul style="list-style-type: none"> <li>• Evolving mission requirements may lead to increases in energy demand that cannot be managed</li> <li>• Accurate targets require more accurate baseline year characterization by agency</li> <li>• Does not allow for direct performance comparison of efficiency improvement across agencies</li> </ul>

While not a tradeoff of selecting an intensity versus absolute target, an additional consideration may be that the current GHG emissions reduction goal required under Executive Order 13514 is an absolute reduction goal and currently includes all aspects of facility energy use, as well as non-building fuel uses. An absolute facility energy goal would be in some respects redundant with the absolute GHG reduction target. On the other hand, an absolute energy reduction goal codified under law out to 2025 would have a longer term impact than the current 2020 GHG reduction goal.

## 4.6 Other Goal-Setting Approaches

Several other goal-setting approaches were considered as part of this study but were not evaluated in detail due to current data constraints. These may be revisited in the future as federal building performance data quality improves.

- **Set EUI reduction targets by building type and location** – This approach would account for the current building performance and unique building stock characteristics of each federal agency, and therefore result in more realistic reduction targets by agency. Building type and location both have a significant influence on energy performance and the types of ECMs that are appropriate. Under this scenario, each agency would have different overall energy reduction potential based on the current efficiency and characteristics of its building inventory. The building type disaggregation presented in Table 4 of this study could inform such an approach for the civilian sector, but a more robust analysis of both DOD and civilian buildings would be required for target-setting. This was beyond the scope and resources available for this study. If EUI targets are to be set by building type and location, it is recommended that they are based on actual federal audit results from a cross-section of common federal building types and locations/climate zones across multiple federal agencies. Modeling of federal agency specific data would be much more labor intensive but estimates of building energy performance would be more accurate. This type of analysis may be more feasible as a larger portion of the federal building stock is entered into Energy Star Portfolio Manager.
- **Require Energy Star score of 75 or higher for some percent of the agency’s buildings** – This approach would be useful if the objective were ensuring that federal building were high-performing compared to the general building stock and enabling normalization to account for the many variables other than square footage that influence building performance. For example, occupancy, computers density, operating hours, space conditioning and location-specific climate impacts on energy use are all accounted for when arriving at a normalized Energy Star score. The primary drawback of this approach is that there is a significant reporting burden. While it is already a federal requirement to enter metered buildings into Energy Star Portfolio Manager (which will generate a performance score), only a small percentage of all federal buildings are currently entered into Portfolio Manager.
- **Set energy cost reduction targets** – If cost savings are the primary driver, energy cost reduction targets could be established. The risk of this approach is that rising utility rates and variability of utility rates by region could result in investments that are uneven geographically as an unintended consequence, leaving many buildings under-performing.

## 5.0 Conclusions and Recommendations

This study aims to inform policymakers in setting future energy reduction goals by establishing past performance toward the current energy intensity reduction goal and future energy savings potential from a combination of retrofits to existing federal buildings and the addition of newly constructed facilities to the federal building stock. It also evaluates the benefits and drawbacks of alternative goal-setting approaches and baseline years.

When setting future energy reduction goals, policymakers should consider that factors other than past EUI reduction performance and estimated savings from future investments in cost-effective energy conservation measures will also influence what targets are feasible, and furthermore that there is always uncertainty in projecting the future. Budgetary constraints, operational preferences, and organizational limitations, such as mission requirements for energy security or availability of staffing for ongoing O&M of new technologies, will all influence what is practical and feasible to implement. Anticipating these factors was outside the scope of this study, however cost estimates were provided in section 3.1.5 to illustrate general levels of funding that would be required to achieve these EUI values. As a result, it should be emphasized that the EUI reduction estimates presented in this study represent key inputs to the goal-setting process but not actual reduction goals.

The analysis of past performance suggests that the federal government as a whole is on track to just meet the 30 percent reduction target by 2015. As of FY 2012, the federal government reported a 21 percent decrease from the FY 2003 baseline with 18 of 24 OMB scorecard agencies achieving at least a 21 percent reduction in energy intensity, which is the OMB target for “on track”. DOD alone is responsible for about 60 percent of all federal energy use and building area, so its performance will significantly influence whether the federal government achieves a 30 percent reduction in energy intensity target.

This past EUI reduction was driven by an 18 percent decrease in site-delivered energy use and a 3 percent increase in goal-subject floor space. While electricity represents the largest source of site-delivered energy use in the federal government, at 50 percent, the majority of federal energy savings came from primary fossil sources. The largest absolute reductions came from fuel oil and natural gas savings, which each represented 31 percent of total energy savings; in comparison, 17 percent of savings were from electricity. The majority energy saved by DOD was from fuel oil, natural gas, and coal sources. ECMs in the USPS contributed to half of the total electricity savings, while DOE contributed 34 percent of government-wide electricity savings.

Modeled estimates of future savings potential from the implementation of lifecycle cost-effective ECMs in existing buildings suggest that civilian agencies could reduce energy intensity by 11 percent between 2015 and 2025, while DOD could reduce its energy intensity by 22 percent. The combined total estimated savings potential from retrofits in all federal buildings is 20 percent from 2015-2025. The greatest savings opportunities in civilian agency buildings come from lighting ECMs. In DOD, envelope improvements, such as adding insulation in roofs and walls, are expected to contribute the most to savings. By building type, the greatest savings in the civilian sector are expected to come from ECMs implemented in office buildings.

The federal inventory will also experience some turnover between 2016 and 2025, as old buildings are retired and new buildings are constructed. These new federal buildings will be subject to more stringent design standards aimed at improving their energy performance. This is expected to support another 2.7 percent reduction in all federal facilities, with 1.5 percent in the military sector and 4.5 percent in the civilian sector. The comparatively larger impact on the civilian sector is due to projections that DOD will be turning over less floor area in the next decade —perhaps due to a recent spike in DOD construction— compared to projected turnover in the civilian building stock.

The combined impact of implementing cost-effective retrofit measures and new construction is presented in Table 22 below.

**Table 22.** Estimated EUI impact from both cost-effective retrofits to existing buildings and federal energy standards for new construction (site energy basis)

Building Type	Existing Buildings				New Buildings	Total Stock	
	2015 EUI	2025 EUI Reduction (Efficiency Only)		2025 EUI	2025 EUI Reduction	2025 EUI	
	kBtu/SF	kBtu/SF	Pct.	kBtu /SF	kBtu/SF	kBtu/SF	Pct. Change
All Civilian	97.3	10.9	11.2%	86.3	4.3	82.0	15.7%
Civ: Health Care	151.9	15.9	10.5%	135.9			
Civ: Industrial	98.7	10.5	10.6%	88.2			
Civ: Laboratory	145.0	13.6	9.4%	131.5			
Civ: Office	92.0	10.6	11.5%	81.4			
Civ: Prison	129.1	13.5	10.5%	115.5			
Civ: School	73.8	9.2	12.5%	64.6			
Civ: Service	68.3	8.8	12.8%	59.5			
Civ: Warehouse	27.1	5.6	20.7%	21.5			
Civ: Other	84.1	10.0	11.9%	74.1			
DOD	91.0	20.4	22.5%	70.6	1.4	69.2	24.0%
Total Federal	93.1	18.5	19.9%	74.5	2.5	72.0	22.6%

The addition of onsite renewable energy could support up to another 4 percent reduction in site-delivered energy intensity in civilian agencies and an additional 9 percent for the DOD. It should be noted, however, that renewable energy savings are based on technical feasibility and do not reflect lifecycle cost-effectiveness, which would require additional information on state policies and incentives and site-level characteristics. As a result, it is recommended that the renewable savings estimates might be considered an upper limit for goal-setting purposes considering the lower level of certainty around these estimates.

Based on the information available for the modeling and analysis included in this report, the larger energy-savings potential in DOD facilities compared to the civilian sector may be attributed to the age of the DOD building stock and the progress toward the EUI reduction goal to date. The DOD stock is older and was not, until the last decade or so, built to the same standards. For example, uninsulated metal-sided and metal-roofed buildings constructed for unoccupied and unconditioned storage have been repurposed to heated, occupied warehousing. Such examples may explain in part the lower starting EUIs and challenge associated with reducing them further. The nature of the DOD stock also results in significant

retrofit opportunities for envelope measures that increase insulation and reduce heating and cooling loads. Further, the DOD sector has achieved a 17.7 percent reduction from its 2003 baseline, while the civilian sector has reduced energy use intensity 24.5 percent below its baseline. One reason for the higher civilian EUI reductions may be that the civilian sector as a whole has invested comparatively more into building efficiency than DOD during the goal period. Finally, the fact that DOD space has become more highly utilized in recent years may also be influencing DOD slower EUI reduction rates.

The total estimated investment required to achieve these savings through energy efficiency retrofits only (excludes renewable energy) is \$8.3 billion, approximately \$5.0 billion of which would be required to fund DOD retrofits. This would equate to an annual investment in retrofits of roughly \$830 million over the ten-year goal period. The estimated annual savings from the combined cost-effective measures totals \$1.2 billion per year, \$700 million of which would come from DOD investments in ECMs and \$520 million per year would come from civilian sector investments. This suggests that all cost-effective ECMs in federal buildings would produce a simple payback of around seven years, assuming funding through direct appropriations. It should be considered that some portion will likely be funded through third-party mechanisms, such as ESPCs, although this will vary by agency. Due to different payback thresholds and higher financing costs, some of the long-payback items that are cost-effective with direct appropriations, may not occur under a third-party financing scenario, therefore the total investment and savings potential would be somewhat lower.

Defining the optimal goal-setting approach ultimately depends on what policymakers and the government seeks to accomplish through energy management. Several approaches to establishing goals and baseline years for the 2015 to 2025 goal-period were considered, including using site versus source energy factors, removing the exclusion of certain energy-intensive buildings, setting agency-or sector-specific goals versus a single federal sector goal, and establishing alternative baseline years. Based on the analysis of the benefits and drawbacks of each of these approaches, the following recommendations are made:

- Fossil-source energy, using national eGRID factors, should provide the basis for 2025 goals that better reflect total energy use impacts and savings. The impact on savings by agency is expected to be nominal overall.
- All buildings should be subject to goals, to simplify reporting and provide opportunities for additional savings in these buildings, assuming that process operating loads not attributed to a building function (e.g. docked ships) can be reported separately.
- Separate goals should be established for DOD and the civilian sector to account for the different savings potential in each sector.
- A tiered approach should be established with three levels of goals, to account for variability in civilian sector EUIs and EUI reduction potential.
- A new baseline year should be established that is closer to the beginning of the goal period. Fiscal year 2013 represents a good weather year and is close to the basis used for modeled results. Furthermore, data quality is probably better than previous years considering the recent push to increase building-level metering quality.

## 6.0 References

111 USC Sec. 405. 2009. The American Recovery and Reinvestment Act of 2009. Public Law 111-5. Available at <http://www.gpo.gov/fdsys/pkg/BILLS-111hr1enr/pdf/BILLS-111hr1enr.pdf>. (undated webpage).

American Society of Heating, Refrigerating and Air-Conditioning Engineers (ASHRAE) and Illuminating Engineering Society of North America (IESNA). 1975. Energy Conservation in New Building Design. ASHRAE Standard 90-75, Atlanta, Georgia.

American Society of Heating, Refrigerating, and Air-Conditioning Engineers (ASHRAE) and Illuminating Engineering Society of North America (IESNA). 1980. Energy Conservation in New Building Design, ANSI/ASHRAE/IES 90A-1980, New York.

American Society of Heating, Refrigerating, and Air-Conditioning Engineers (ASHRAE) and Illuminating Engineering Society of North America (IESNA). 1990. Energy Efficient Design of New Buildings Except Low-Rise Residential Buildings, ANSI/ASHRAE/IES 90.1-1989, Atlanta, Georgia.

American Society of Heating, Refrigerating, and Air-Conditioning Engineers (ASHRAE) and Illuminating Engineering Society of North America (IESNA). 2004. Energy Standard for Buildings Except Low-Rise Residential Buildings. ANSI/ASHRAE/IESNA Standard 90.1-2004, Atlanta, Georgia.

American Society of Heating, Refrigerating, and Air-Conditioning Engineers (ASHRAE) and Illuminating Engineering Society of North America (IESNA). 2007. Energy Standard for Buildings Except Low-Rise Residential Buildings. ANSI/ASHRAE/IESNA Standard 90.1-2007, Atlanta, Georgia.

American Society of Heating, Refrigerating, and Air-Conditioning Engineers (ASHRAE) and Illuminating Engineering Society of North America (IESNA). 2010. Energy Standard for Buildings Except Low-Rise Residential Buildings. ANSI/ASHRAE/IESNA Standard 90.1-2010, Atlanta, Georgia

EISA 2007 – Energy Independence and Security Act of 2007. 42 USC 17001. Public Law No. 110-140.

EPAct – Energy Policy Act of 2005. 2005. 42 USC 15801 et seq. Public Law No. 109-58, as amended.

Judd KS, AR Kora, JW Henderson, BJ Russo, J Katz, M Hummon, and EM Rauch. 2010. Roadmap to a Climate Neutral Federal Government. PNNL-19643, Pacific Northwest National Laboratory, Richland, WA.

NECPA – National Energy Conservation Policy Act. 42 USC 8251. Public Law 95–619.

Rushing, AS, JD Kneifel, BC Lippiatt. 2013. Energy Price Indices and Discount Factors for Life-Cycle Cost Analysis - April 2010: Annual Supplement to NIST Handbook 135 and NBS Special Publication 709. NIST Interagency/Internal Report (NISTIR) - 85-3273-25.

Thornton BA et al. 2011. Achieving the 30% Goal: Energy and Cost Savings Analysis of ASHRAE Standard 90.1-2010. PNNL-20407, Richland, WA.



U.S. Department of Energy. 2011. U.S. Department of Energy Commercial Reference Building Models of the National Building Stock.

# Appendix A. Methodology for Estimating Existing Building Retrofits

The prototype buildings were modeled using the 2013 release of the [Facility Energy Decision System \(FEDS\)](#) – a tool for simulating building energy performance and analyzing the impact of energy conservation measures (ECMs). The FEDS inference engine uses building type, location, size, and vintage to statistically infer technology retirement and estimate what technologies still exist in the building stock and their performance.

The intent of the FEDS model is to provide information needed to determine the minimum life-cycle cost (LCC) configuration of the energy generation and consumption infrastructure for both federal civilian buildings and integrated military installations. The model has no fuel or technology bias; it selects the technologies that will provide an equivalent or superior level of service (e.g., heating, cooling, illumination) at the minimum LCC.

The FEDS models use the FEMP-prescribed (NIST 2013) utility escalation rates for gas and electricity. Discount rates and calculation methodologies used in the analysis also follow guidelines established in NIST guidance: <http://www1.eere.energy.gov/femp/pdfs/ashb13.pdf>.

As part of estimating the minimum LCC configuration of generation and end-use technologies, all interactive effects between energy systems are explicitly modeled. The value or cost of these interactive effects varies by building type (level of internal gain), building size (portion of heating, ventilation, and air conditioning loads attributable to internal gains versus envelope gains/losses), climate (whether a particular building is cooling- or heating-dominated), occupancy schedule, and a number of other factors. Thus, there is no simple solution, and detailed simulation modeling is the best way to provide a credible estimate of the impact. For example, when considering a lighting retrofit, the model evaluates the change in energy consumption in all building energy systems rather than just the change in the lighting energy.

The analyses yielded a life-cycle-cost-effective mix of energy conservation measures, which resulted in Energy Use Intensities (EUIs) for each of the prototype buildings and locations. The specific analysis assumptions are described below.

## A.1 Selecting Building Types and Locations to Model

### A.1.1 Civilian Buildings

Prototype buildings modeled for the civilian stock, and their basic operating characteristics, are summarized in Table A.1. Each variant was weighted based on region and proportion of the stock. All simulations were based on 2011 prototype buildings and starting EUI values were adjusted to 2015 based on perpetuating current goal compliance trends over the 2011-2015 period. (See Section 3.1.2 of the report.)

Prototype buildings were constructed for simulation in FEDS based on statistical analysis of stock average characteristics including floor area, vintage, size, operating schedules, and predominant heating, ventilating and air conditioning (HVAC) system types. More details on baseline heating and cooling technologies can be found in Section A.2.

**Table A.1.** Characteristics of civilian sector buildings modeled in FEDS and operation assumptions

<b>Building Type</b>	<b>Vintage</b>	<b>Size (SF)</b>	<b>Operation Hours</b>	<b>Ventilation</b>
Healthcare	1994	200,000	24/7	Constant operation
Healthcare	1994	30,000	6:00am to 6:00pm Mon-Fri 11:00am to 1:00pm Sat-Sun	Constant operation
Healthcare	1957	200,000	24/7	Constant operation
Healthcare	1957	30,000	6:00am to 6:00pm Mon-Fri 11:00am to 1:00pm Sat-Sun	Constant operation
Laboratory	1994	200,000	7:00am-6:00pm Mon-Fri	Constant during occupied hours, cycle during unoccupied hours
Laboratory	1994	30,000	7:00am-6:00pm Mon-Fri	Constant during occupied hours, cycle during unoccupied hours
Laboratory	1957	200,000	7:00am-6:00pm Mon-Fri	Constant during occupied hours, cycle during unoccupied hours
Laboratory	1957	30,000	7:00am-6:00pm Mon-Fri	Constant during occupied hours, cycle during unoccupied hours
Office	1994	340,000	7:00am-6:00pm Mon-Fri	Constant operation
Office	1994	90,000	7:00am-6:00pm Mon-Fri 7:00am-6:00pm Mon-Fri	Constant during occupied hours, cycle during unoccupied hours
Office	1994	5,000	7:00am-6:00pm Mon-Fri	Constant during occupied hours, cycle during unoccupied hours
Office	1957	340,000	7:00am-6:00pm Mon-Fri	Constant operation
Office	1957	90,000	7:00am-6:00pm Mon-Fri 7:00am-6:00pm Mon-Fri	Constant during occupied hours, cycle during unoccupied hours
Office	1957	5,000	7:00am-6:00pm Mon-Fri	Constant during occupied hours, cycle during unoccupied hours
Warehouse	1994	200,000	7:00am-5:00pm Mon-Fri 11:00am-2:00p Sat 11:00am-1:00pm Sun	Cycle with cooling and linked heating systems
Warehouse	1994	30,000	7:00am-5:00pm Mon-Fri 11:00am-2:00p Sat 11:00am-1:00pm Sun	Cycle with cooling and linked heating systems
Warehouse	1957	200,000	7:00am-5:00pm Mon-Fri 11:00am-2:00p Sat 11:00am-1:00pm Sun	Cycle with cooling and linked heating systems
Warehouse	1957	30,000	7:00am-5:00pm Mon-Fri 11:00am-2:00p Sat 11:00am-1:00pm Sun	Cycle with cooling and linked heating systems

The set of 30 prototypes in Table A.1 as modeled for each region using the applicable TMY weather data for a representative city in the region (Table A.2).

**Table A.2.** Region specifications for civilian stock

<b>Region</b>	<b>TMY City</b>
CA	Los Angeles, CA
DC/MD/VA	Washington, DC
FL/GA	Jacksonville, FL
NY	New York, NY
TX	Dallas, TX

In some cases, multiple prototypes were simulated to capture variation in the stock. For example, the office type represents a very large fraction of the civilian building stock. To better represent offices, the population of buildings was split into three size categories, rather than the two size categories used for the other building types. Additionally, some building types represent a very diverse collection of buildings, and as such, the buildings within the type have a large variety of HVAC systems. The research team selected the predominant HVAC system types within each building type and modeled them as separate prototypes.

FEDS performs retrofit simulations based on an extensive and continuously updated library of ECMs. For each building prototype simulated, FEDS identifies the package of ECMs that minimizes total LCC, given the prototype's end-use load profile, current mix of technologies, baseline expenditures for electricity, gas and all other fuels, electricity and gas rate structures, and applicable demand charges.

ECMs include the potential for technically achievable onsite renewable technologies to be employed to contribute to EUI reductions. For civilian buildings, solar photovoltaic (PV) systems were sized for the prototype buildings such that system production would not exceed the electric energy demand of the building in any concurrent hour. This constraint prevents consideration of cases where onsite renewables could supply power back to the grid – distorting the impact on the buildings' EUI. Additionally, the size of the PV array was constrained to be no greater than that which would fit on the roof of the modeled building.

In addition to ECMs and onsite renewables modeled in FEDS, the research team conservatively assumed that civilian buildings could achieve an additional 5 percent savings through improved operations and continuous commissioning activities at a cost equivalent of a three-year simple payback.

### **A.1.2 DOD Buildings**

In determining the optimal retrofit for each technology within the military sector, the interactions at the installation level are considered by determining the impact on the installation's electric energy and demand cost, as well as the interactive effects among end-uses. This is important because the peak electric demand in any individual building may not occur at the same time as the installation's peak demand. Since the buildings on large federal installations typically are not individually metered, the installation is billed based on the combined demand of all buildings. Thus, proper valuation of the changes in an individual building's electric demand must be done in the context of the impact on the installation's demand profile—including time-of-day pricing and demand ratchets.

For DOD locations, alternative configurations of wind and PV were modeled under the same constraint as the civilian buildings with the exception of the rooftop requirement as it was assumed that DOD installations have sufficient land area that roof-mounted PV is not a requirement. Systems were sized such that renewable output would not exceed aggregate building energy demand in any hour and were evaluated in alternative configurations such as 25% wind/75% PV, 75% wind/25% PV, 50% wind/50% PV, 100% wind/0% PV, and 0% wind/100% PV, to select the renewable annual output-maximizing alternative.

As with civilian buildings, the research team conservatively assumed that DOD installations could achieve an additional 5 percent savings through improved operations and continuous commissioning activities, beyond the modeled savings from ECMs and renewables. These activities reduce any savings

degradation that occurs without regular maintenance and help avoid the emergence of new system inefficiencies.

Five locations similar to those chosen for the civilian stock were chosen to be regionally representative of DOD's footprint. Table A.3 indicates the specific facilities and weather locations for each installation modeled.

**Table A.3.** Region specifications for DOD stock

<b>Region</b>	<b>Installation</b>	<b>TMY Location</b>
CA	Fort Hood <sup>16</sup>	Edwards Air Force Base, CA
DC/MD/VA	Fort Belvoir	Richmond, VA
FL/GA	Fort Benning	Jacksonville, FL
NY	Fort Drum	Watertown, NY
TX	Fort Hood	Dallas, TX

## **A.2 Baseline Building Assumptions**

The tables that follow highlight some of the key baseline conditions of the modeled buildings in the civilian and DOD sectors, as well as the general types of retrofit opportunities that were applied.

---

<sup>16</sup> Because PNNL did not have an installation modeled in California, Edwards Air Force Base was used for weather data and a California rate structure was applied to that site, however the buildings and technologies modeled were based on Fort Hood.

**Table A.4.** Key civilian sector model inputs: office space

Office - Small/New		Office - Small/Old		Office - Medium/New		Office - Medium/Old	
Baseline	Retrofit	Baseline	Retrofit				
<b>Lighting<sup>17</sup></b>		<b>Lighting</b>		<b>Lighting</b>		<b>Lighting</b>	
CFL	No change	CFL	No change	CFL	No change	CFL	No change
INC	CFL	INC	CFL	INC	CFL	INC	CFL
FL: T12, T8*	FL: Super T8 or No change	FL: T12, T8*	FL: Super T8 or No change	FL: T12, T8*	FL: Super T8 or No change	FL: T12, T8*	FL: Super T8 or No change
HPS	No change	HPS	No change	HPS	No change	HS	No change
MH	MH or No change	MH	MH or No change	MH	MH or No change	MH	MH or No change
Exit: INC or LED Exit: Self Luminous	Electroluminescent No change	Exit: INC or LED Exit: Self Luminous	Electroluminescent No change	Exit: INC or LED Exit: Self Luminous	Electroluminescent No change	Exit: INC or LED Exit: Self Luminous	Electroluminescent No change
<b>Hot Water</b>		<b>Hot Water</b>		<b>Hot Water</b>		<b>Hot Water</b>	
Electric water heater	No change	Electric water heater	Aerators, Lower Tank Temperature (All), Insulate Tank (CA, NY), Insulate Pipe (FL, DC)	Nat Gas Central Boiler	Conventional Gas Boiler - 84% Combustion Efficiency (TX, NY, DC), Central Heat Pump Hot Water System (CA), Wrap Tank (All)	75% Nat Gas Central Boiler  25% Electric Water Heater	Conventional Gas Boiler - 84% Combustion Efficiency (TX, NY, CA, FL) or Central Heat Pump Hot Water System (DC), Wrap tank, Aerators (All)  Aerators, Lower Tank Temperature (All) Insulate Tank (CA, NY), Insulate Pipe (FL, DC)
<b>Heating</b>		<b>Heating</b>		<b>Heating</b>		<b>Heating</b>	
Nat Gas Conventional Furnace	No change	Nat Gas Conventional Furnace	No change	75% Nat Gas Conventional Boiler  25% Nat Gas Conventional Furnace	Add Automatic Electric Damper  No change	75% Nat Gas Conventional Boiler  25% Nat Gas Conventional Furnace	Add Automatic Electric Damper  No change
<b>Cooling</b>		<b>Cooling</b>		<b>Cooling</b>		<b>Cooling</b>	
Electric Packaged Unit	No change	Electric Packaged Unit	No change	75% Electric Water-Cooled	No change (TX, DC, FL), Water-Cooled	75% Electric Water-Cooled	No change (TX, DC, NY, FL),

<sup>17</sup> CFL = Compact Fluorescent; INC = Incandescent; FL = Fluorescent; HPS = High Pressure Sodium; MH = Metal-Halide

Office - Small/New		Office - Small/Old		Office - Medium/New		Office - Medium/Old	
Baseline	Retrofit	Baseline	Retrofit				
				Reciprocating Chiller (CA, DC, NY), Electric Water-Cooled Centrifugal Chiller (TX, FL)  25% Electric packaged unit	Gas Engine-Driven Chiller (standard efficiency) (CA), Nat Gas Double-Effect Absorption Chiller (NY)  No change (All)	Centrifugal Chiller  25% Electric Packaged Unit	Water-Cooled Gas Engine-Driven Chiller (standard efficiency) (CA)  No change (All)
Envelope		Envelope		Envelope		Envelope	
Roof Insulation R-Value 11.13 (DC, NY, TX, FL), 30.00 (CA)	Blow in attic insulation: Increase by R-19 (CA), Suspended Ceiling: Increase Insulation by R-19 (TX, FL) or R-38 (DC, NY)	Roof Insulation R-Value 8.90	No change	Roof Insulation R-Value 11.13	Suspended Ceiling: Increase Insulation to R 19 (CA, NY)	Roof Insulation R-Value 8.90	No change
Wall Insulation R-Value 19.00	No change	Wall Insulation R-Value 7.00 AND 19.00	No change	Wall Insulation R-Value 19.00	No change	Wall Insulation R-Value 7.00 (CA, DC, NY) and 0.00 (FL, TX)	Blow-in Wall Insulation to Fill Available Space (FL, TX)
Crawlspace Floor Insulation R-Value 11.00 (TX, FL, CA) and R 15.00 (DC, NY)	No change	Crawlspace Floor Insulation R-Value 11.00	No change	Crawlspace Floor Insulation R-Value 11.00 (CA, TX, FL) and 15.00 (NY, DC)	No change	Crawlspace Floor Insulation R-Value 0.00 (TX, FL) and 11.00 (CA, DC, NY)	No change
Window		Window		Window		Window	
Wood Frame Single Pane (TX, FL), Wood Frame Double Pane (DC, NY, CA)	Add film (NY), No change (DC, CA, TX, FL)	Wood Frame Single Pane	Double Pane Argon/Super Low-e Window (DC, NY, CA), Add Film (FL), No change (TX)	Wood Frame Single Pane (FL, TX), Wood Double Pane (NY, DC, CA)	No change	Wood Frame Single Pane	No change (FL, TX), Wood or Vinyl Frame Double Pane Argon/Super Low-e (CA, NY, DC)

Office - Large/New		Office - Large/Old	
Baseline	Retrofit	Baseline	Retrofit
	<b>Lighting</b>		<b>Lighting</b>
CFL	No change	CFL	No change
INC	CFL	INC	CFL
FL: T12, T8*	FL: Super T8 or No change	FL: T12, T8*	FL: Super T8 or No change

Office - Large/New		Office - Large/Old	
Baseline	Retrofit	Baseline	Retrofit
HPS	No change	HPS	No change
MH	MH or No change	MH	MH or No change
Exit: INC or LED	Electroluminescent	Exit: INC or LED	Electroluminescent
Exit: Self Luminous	No change	Exit: Self Luminous	No change
<b>Hot Water</b>		<b>Hot Water</b>	
Nat Gas Central Boiler	Conventional Gas Boiler - 84% Efficiency (TX, FL, DC, CA), Condensing Gas Boiler - 91% Efficiency (NY), Wrap Tank (All)	Nat Gas Central Boiler	Conventional Gas Boiler - 84% Combustion Efficiency, Wrap Tank, Aerators
<b>Heating</b>		<b>Heating</b>	
Nat Gas Conventional Boiler	No change (NY, FL, DC), Feedwater Economizers (TX), Automatic Electric Damper (CA)	Nat Gas Conventional Boiler	No change (TX), Feedwater Economizers (NY), Automatic Electric Damper (CA, FL), Conventional Gas Boiler - 84% Combustion Efficiency (DC)
<b>Cooling</b>		<b>Cooling</b>	
Electric Water-Cooled Centrifugal Chiller	No change	Electric Water-Cooled Centrifugal Chiller	No change
<b>Envelope</b>		<b>Envelope</b>	
Roof Insulation R-Value 13.35	No change	Roof Insulation R-Value 8.90	No change
Wall Insulation R-Value 11.00	No change	Wall Insulation R-Value 0.00	Blow-in Wall Insulation
Slab on grade with perimeter insulation (DC, NY, CA) and with no perimeter insulation (FL, TX)	No change	Slab on grade with no perimeter insulation	No change (TX, NY, CA, FL), Insulate Perimeter of Slab on Grade: Increase Insulation by R-15 (DC)
<b>Window</b>		<b>Window</b>	
Metal or Wood Frame Single Pane (All), Metal Frame Double Pane (NY, DC, CA)	No change	Wood or Metal Frame Single Pane	No change (FL, NY, DC, CA), Thermal Break Aluminum Frame Double Pane Argon/Super Low-e (DC)

**Table A.5.** Key civilian sector model inputs: healthcare space

Healthcare - Small/New		Healthcare - Small/Old		Healthcare - Large/New		Healthcare - Large/Old	
Baseline	Retrofit	Baseline	Retrofit	Baseline	Retrofit	Baseline	Retrofit
<b>Lighting</b>		<b>Lighting</b>		<b>Lighting</b>		<b>Lighting</b>	
CFL	No change	CFL	No change	CFL	No change	CFL	No change
INC	CFL	INC	CFL	INC	CFL	INC	CFL
FL: T12, T8*	FL: Super T8 or No change (all T12s removed)	FL: T12, T8*	FL: Super T8 or No change (all T12s removed)	FL: T8*	FL: Super T8 or No change (all T12s removed)	FL: T8*	FL: Super T8 or No change (all T12s removed)
HPS	No change	HPS	No change	HPS	No change or HPS	HPS	No change or HPS
MH	No change	MH	No change	MH	No change	MH	No change
Exit: INC or LED	Electroluminescent	Exit: INC or LED	Electroluminescent	Exit: LED	Electroluminescent	Exit: LED	Electroluminescent



Healthcare - Small/New		Healthcare - Small/Old		Healthcare - Large/New		Healthcare - Large/Old	
Baseline	Retrofit	Baseline	Retrofit	Baseline	Retrofit	Baseline	Retrofit
Exit: Self Luminous		Exit: Self Luminous					
<b>Hot Water</b>		<b>Hot Water</b>		<b>Hot Water</b>		<b>Hot Water</b>	
Nat Gas Central Boiler	Wrap Tank with Insulation, LFSHs (All) Conventional Gas Boiler - 84% Combustion Efficiency (DC, FL, TX)	Electric Water Heater	Replace Existing Water Heater with 0.78 Gas Water Heater (Com) (CA, NY) Wrap Tank with Insulation (DC, FL) Insulate Pipe Near Tank (DC, FL, TX); LFSHS, Aerators (All)	Nat Gas Central Boiler	Condensing Gas Boiler - 91% Combustion Efficiency, Wrap Tank, LFSHs	Electric Water Heater	Replace with 0.94 Gas Water Heater (CA, NY), Insulate Tank and Pipe (DC), Heat Pump Water Heater (TX, FL), LFSHS and Aerators (All)
<b>Heating</b>		<b>Heating</b>		<b>Heating</b>		<b>Heating</b>	
Nat Gas Conventional Boiler	Add Automatic Electric Damper (CA, FL, NY, TX) Condensing Gas Boiler - 91% Combustion Efficiency (DC)	Nat Gas Conventional Boiler	Add Automatic Electric Damper (CA, FL, TX) Condensing Gas Boiler - 91% Combustion Efficiency (DC, NY)	Nat Gas Conventional Boiler	No change (TX, FL, CA), Feedwater Economizers (DC, NY)	Nat Gas Conventional Boiler	No change (TX, FL, CA, NY), Feedwater Economizers (DC)
<b>Cooling</b>		<b>Cooling</b>		<b>Cooling</b>		<b>Cooling</b>	
Electric Water-Cooled Reciprocating Chiller	No change	Electric Water-Cooled Reciprocating Chiller	No change	Electric Water-Cooled Centrifugal Chiller	No change	Electric Water-Cooled Centrifugal Chiller	No change
<b>Envelope</b>		<b>Envelope</b>		<b>Envelope</b>		<b>Envelope</b>	
Roof Insulation R-Value 11.13	R-11.13: Suspended Ceiling: Increase Insulation by R-38 (DC) Suspended Ceiling: Increase Insulation by R-19 (FL, NY, TX) No Change (CA)	Roof Insulation R-Value 8.90	No change	Roof Insulation R-Value 11.13	Suspended Ceiling: Increase Insulation by R-38 (DC) and by R-19 (TX)	Roof Insulation R-Value 8.90	No change
Wall Insulation R-Value 19.00	No change	Wall Insulation R-Value 0.00 (FL, TX), R-7.00 (CA,	Blow-in Wall Insulation to Fill Available Space	Wall Insulation R-Value 19.00	No change	Wall Insulation R-Value 7.00 (CA, NY, DC) or 0.00	No change (CA, NY, DC), Blow In to Fill Available

Healthcare - Small/New		Healthcare - Small/Old		Healthcare - Large/New		Healthcare - Large/Old	
Baseline	Retrofit	Baseline	Retrofit	Baseline	Retrofit	Baseline	Retrofit
		NY, DC),	(FL, TX)			(FL, TX)	Space (FL, TX)
Slab on grade with perimeter insulation (CA, NY, DC) and with no perimeter insulation (TX, FL)	Insulate Perimeter of Slab on Grade: Increase Insulation by R-15 (FL, TX) No change (CA, DC, NY)	Slab on grade with no perimeter insulation	Insulate Perimeter of Slab on Grade: Increase Insulation by R-15	Slab on grade with perimeter insulation (CA, NY, DC) and with no perimeter insulation (TX, FL)	No change (DC, CA, NY), Insulate Perimeter: Increase Insulation by R-15 (TX, FL)	Slab on grade with no perimeter insulation	Insulate Perimeter of Slab on Grade: Increase Insulation by R-15
Window		Window		Window		Window	
Wood Frame Single Pane Window (FL, TX) Wood Frame Double Pane Window (CA, DC, NY)	Wood or Vinyl Frame Double Pane Argon/Super Low-e Window (TX) No change (CA, DC, FL, NY)	Wood Frame Single Pane Window	Wood or Vinyl Frame Double Pane Argon/Super Low-e Window (CA, DC, NY, TX) No change (FL)	Double Pane (NY, DC, CA), Single Pane (FL, TX)	No change (CA, DC, NY, FL ), Double Pane Argon/Super Low-e (TX)	Wood Frame Single Pane	No change (FL, TX, CA), Wood or Vinyl Frame Double Pane Argon/Super Low-e (DC, NY)

**Table A.6.** Key civilian sector model inputs: laboratory space

Laboratory - Small/New		Laboratory - Small/Old		Laboratory - Large/New		Laboratory --Large/Old	
Baseline	Retrofit	Baseline	Retrofit	Baseline	Retrofit	Baseline	Retrofit
Lighting		Lighting		Lighting		Lighting	
CFL	No change	CFL	No change	CFL	No change	CFL	No change
INC	CFL	INC	CFL, T8	INC	CFL, T5	INC	CFL, T5
FL: T12, T8*, T5HO	FL: Super T8 or No change (all T12s removed)	FL: T12, T8*, T5HO	FL: Super T8 or No change (all T12s removed)	FL: T12, T8*, T5HO	FL: Super T8 or No change (all T12s removed)	FL: T12, T8*, T5HO	FL: Super T8 or No change (all T12s removed)
HPS	No change	HPS	No change	HPS	No change	HPS	No change
MH	MH or No change	MH	MH or No change	MH	MH or No change	MH	MH or No change
Exit: INC or LED	Electroluminescent	Exit: INC or LED	Electroluminescent	Exit: INC or LED	Electroluminescent	Exit: INC or LED	Electroluminescent
Hot Water		Hot Water		Hot Water		Hot Water	
60%-Nat Gas Water Heater	Wrap Tank with Insulation (DC, FL)	20%-Nat Gas Water Heater	Wrap Tank with Insulation, Aerators (All), Insulate Pipe Near Tank (FL, DC, TX)	Electric Water Heater	Replace Existing Water Heater with 0.78 Gas Water Heater (CA) No change (DC, FL, NY, TX)	Nat Gas Water Heater	Wrap Tank with Insulation, Aerators (All) Insulate Pipe Near Tank (DC, FL, TX)
40%-Electric Water Heater	Replace Existing Water Heater with 0.78 Gas Water Heater (Com) (CA)  No change (NY, TX)	80%-Electric Water Heater	Wrap Tank with Insulation (CA, DC, FL, NY) Aerators, Insulate Pipe Near Tank				

Laboratory - Small/New		Laboratory - Small/Old		Laboratory - Large/New		Laboratory --Large/Old	
Baseline	Retrofit	Baseline	Retrofit	Baseline	Retrofit	Baseline	Retrofit
		(All)					
<b>Heating</b>		<b>Heating</b>		<b>Heating</b>		<b>Heating</b>	
20%-Nat Gas Conventional Furnace	20% - No change (All)	20%-Nat Gas Conventional Furnace	No change (All)	Nat Gas Conventional Boiler	Add Automatic Electric Damper (TX) No change (CA, DC, FL, NY)	Nat Gas Conventional Boiler	Add Automatic Electric Damper (CA, DC, TX) No change (FL, NY)
20%-Electric Conventional Furnace	20%-Conventional Gas Furnace - 80% Efficient (CA, FL) 84% Efficient (DC, NY) or No change (TX)	20%-Electric Conventional Furnace	Conventional Gas Furnace - 80% Efficient (DC, FL, NY) or No change (CA, TX)				
60%-Nat Gas Conventional Boiler	60%-Add Automatic Electric Damper (DC, FL, NY, TX) or No change (CA)	60%-Nat Gas Conventional Boiler	Add Automatic Electric Damper (All)				
<b>Cooling</b>		<b>Cooling</b>		<b>Cooling</b>		<b>Cooling</b>	
20%-Electric Package Unit	No change	20%-Electric Water-Cooled Centrifugal Chiller	No change	Electric Water-Cooled Centrifugal Chiller	No change	Electric Water-Cooled Centrifugal Chiller	No change
20%-Electric Water-Cooled Centrifugal Chiller (TX, CA) or Electric Water-Cooled Reciprocating Chiller (NY, DC, FL)		20%-Electric Package Unit					
60%-Electric Air-Cooled Reciprocating Chiller (FL, NY, DC, CA) or Electric Water-Cooled Centrifugal (TX)		60%-Electric Air-Cooled Reciprocating Chiller (DC, CA) or Water-Cooled Centrifugal Chiller (NY, TX, FL) Reciprocating Chiller					
<b>Envelope</b>		<b>Envelope</b>		<b>Envelope</b>		<b>Envelope</b>	
Roof Insulation R-	No change (CA,	Roof Insulation R-	No change	Roof Insulation R-	No change (CA, FL,	Roof Insulation R-	No change

Laboratory - Small/New		Laboratory - Small/Old		Laboratory - Large/New		Laboratory --Large/Old	
Baseline	Retrofit	Baseline	Retrofit	Baseline	Retrofit	Baseline	Retrofit
Value 8.90 (All) AND 11.13 (All)	FL, TX) Suspended Ceiling: Increase Insulation by R-19 (DC, NY)	Value 8.90		Value 8.90 (All) OR 11.13 (All)	NY, TX) Suspended Ceiling: Increase Insulation by R-19 (DC)	Value 8.90	
Wall Insulation R- Value 19.00	No change	Wall Insulation R- Value 0.00 (FL, TX), R-Value 7.00 (CA, NY, DC)	Blow-in Wall Insulation to Fill Available Space (FL, TX)	Wall Insulation R- Value 19.00	No change	Wall Insulation R- Value 0.00 (FL, TX), R-7.00 (CA, NY, DC)	Blow-in Wall Insulation to Fill Available Space (FL, TX)
Slab on grade with no perimeter insulation Crawlspace Floor Insulation R-Value 11.00	Insulate Perimeter of Slab on Grade: Increase Insulation by R-15 (FL, TX) No change (CA, DC, NY)	Slab on grade with no perimeter insulation Crawlspace Floor Insulation R-Value 11.00	Insulate Perimeter of Slab on Grade: Increase Insulation by R-15	Slab on grade with no perimeter insulation Crawlspace Floor Insulation R-Value 11.00	Insulate Perimeter of Slab on Grade: Increase Insulation by R-15 (FL, TX) No change (CA, DC, NY)	Slab on grade with no perimeter insulation Crawlspace Floor Insulation R-Value 11.00	Insulate Perimeter of Slab on Grade: Increase Insulation by R-15 (DC, FL, NY, TX) No change (CA)
Window		Window		Window		Window	
Wood Frame Double Pane (NY, DC, CA) AND Wood Frame Single Pane (All)	No change	Wood Frame Single Pane Window	Add Retrofit Film (CA) Wood or Vinyl Frame Double Pane Argon/Super Low-e (CA, DC, NY, TX) or No change (FL)	Wood Frame Single Pane Window (All) AND Wood Frame Double Pane Window (CA, DC, NY)	No change	Wood Frame Single Pane Window	No change (CA, DC, FL, TX), Wood or Vinyl Frame Double Pane Argon/Low-e (NY)

**Table A.7.** Key civilian sector model inputs: warehouse space

Warehouse - Small/New		Warehouse - Small/Old		Warehouse - Large/New		Warehouse - Large/Old	
Baseline	Retrofit	Baseline	Retrofit	Baseline	Retrofit	Baseline	Retrofit
Lighting		Lighting		Lighting		Lighting	
CFL	No change	CFL	No change	CFL	No change	CFL	No change
INC	CFL	INC	CFL	INC	CFL	INC	CFL
FL: T12*	FL: Super T8	FL: T12*	FL: Super T8	FL: T12*	FL: Super T8	FL: T12*	FL: Super T8
HPS	No change or Super T8	HPS	No change or Super T8	HPS	No change or Super T8	HPS	No change or Super T8
MH	Super T8, T5HO, HPS, FL 40BX, or No change	MH	Super T8, T5HO, FL 40BX, HPS, or No change	MH	Super T8, T5HO, HPS, FL 40BX, or No change	MH	Super T8, T5HO, HPS, FL 40BX, or No change
Exit: INC or FL	Electroluminescent	Exit: INC or FL	Electroluminescent	Exit: INC or FL	Electroluminescent	Exit: INC or FL	Electroluminescent
Hot Water		Hot Water		Hot Water		Hot Water	
50%-Electric Water Heater	No change	50%-Electric Water Heater	50%-Insulate Pipe Near Tank, Aerators, Lower	60%-Electric Water heater	No change	60%-Electric Water heater	60%-Aerators, Lower Tank Temperature (All), Insulate Pipe

Warehouse - Small/New		Warehouse - Small/Old		Warehouse - Large/New		Warehouse - Large/Old	
Baseline	Retrofit	Baseline	Retrofit	Baseline	Retrofit	Baseline	Retrofit
50%-No Hot Water	No change		Tank Temperature (CA, DC, FL, NY) 50%-Wrap tank (CA, NY) 50%-Aerators, Lower Tank Temperature (TX)	25%-No Hot Water  15%-Nat Gas Water Heater	No change  15%-Wrap Tank with Insulation (DC, FL) or No change (CA, NY, TX)		Near Tank (CA, DC, FL, NY), Wrap Tank (CA, NY)  15%-(Gas)Wrap Tank with Insulation, Aerators, Lower Tank Temperature (All)
		50%-No Hot Water	No change			25%-No Hot Water	No change
<b>Heating</b>		<b>Heating</b>		<b>Heating</b>		<b>Heating</b>	
50%-Nat Gas Conventional Furnace	50%-Nat Gas Infrared Heating System - High Efficiency (DC, NY) Nat Gas Infrared Heating System - Standard Efficiency (FL), Electric Infrared Heating System (TX), No change (CA)	50%-Nat Gas Conventional Furnace	Nat Gas Infrared Heating System - High Efficiency (DC, NY), Nat Gas Infrared Heating System - Standard Efficiency (FL), Electric Infrared Heating System (TX), No change (CA)	60%-Not Heated  25%-Nat Gas Infrared Heating System  15%-Nat Gas Conventional Furnace	No change  No change  Nat Gas Infrared Heating System - High Efficiency (DC, NY), Nat Gas Infrared Heating System - Standard Efficiency (FL), Electric Infrared Heating System (TX) or No change (CA)	60%-Not Heated  25%-Nat Gas Infrared Heating System  15%-Nat Gas Conventional Furnace	No change  Nat Gas Infrared Heating System - High Efficiency (DC, NY)  15%-Nat Gas Infrared Heating System - Standard Efficiency (FL)  15%-Electric Infrared Heating System (TX)
50%-Not Heated	No change	50%-Not Heated	No change				No change (CA)
<b>Cooling</b>		<b>Cooling</b>		<b>Cooling</b>		<b>Cooling</b>	
None	No change	None	No change	None	No change	None	No change
<b>Envelope</b>		<b>Envelope</b>		<b>Envelope</b>		<b>Envelope</b>	
Roof Insulation R-Value 14.60	No Change	Roof Insulation R-Value 0.00	No change	Roof Insulation R-Value 13.35	No change	Roof Insulation R-Value 8.90 and 0.00	No change
Wall Insulation R-Value 9.6	No change	Wall Insulation R-Value 0.00	No change	Wall Insulation R-Value 11.00 and 9.6	No change	Wall Insulation R-Value 0.00	No change
Slab on grade with no perimeter insulation Crawlspace Floor Insulation R-Value 11.00	No change	Slab on grade with no perimeter insulation, Crawlspace Floor Insulation R-Value 11.00	No change	Slab on grade with no perimeter insulation Crawlspace Floor Insulation	No change	Slab on grade with no perimeter insulation Crawlspace Floor Insulation R-Value 11.00	No change

Warehouse - Small/New		Warehouse - Small/Old		Warehouse - Large/New		Warehouse - Large/Old	
Baseline	Retrofit	Baseline	Retrofit	Baseline	Retrofit	Baseline	Retrofit
				R-Value 11.00			
<b>Window</b>		<b>Window</b>		<b>Window</b>		<b>Window</b>	
Wood or Metal Frame Single-Pane (All) AND Wood or Metal Frame Double-Pane (DC, NY)	No change	Wood or Metal Frame Single Pane	No change	Wood or Metal Frame Single Pane (All) AND Wood or Metal Frame Double-Pane (DC, NY)	No change	Wood or Metal Frame Single Pane Frame	No change

**Table A.8.** Baseline energy consumption proportions by end use (site basis)

Characteristics	Space Heating	Space Cooling	Ventilation	Lighting	Hot Water	All Other
<b>Healthcare</b>	4.9%	12.8%	8.2%	13.2%	24.6%	36.4%
Avg Vintage 1994	5.2%	14.4%	1.1%	14.1%	26.3%	38.9%
Large	4.8%	13.9%	1.1%	12.8%	27.4%	40.0%
Small	8.4%	17.7%	1.3%	24.6%	17.7%	30.2%
Avg Vintage 1957	4.7%	11.4%	14.4%	12.3%	23.1%	34.1%
Large	4.3%	11.0%	15.0%	11.0%	23.8%	34.8%
Small	8.6%	14.4%	9.0%	23.4%	16.5%	28.1%
<b>Lab</b>	5.1%	17.8%	0.2%	11.9%	15.9%	49.2%
Avg Vintage 1994	4.8%	18.7%	0.3%	11.6%	15.8%	48.8%
Large	3.9%	16.1%	0.3%	11.4%	17.3%	51.0%
Small	5.8%	21.6%	0.2%	11.7%	14.3%	46.4%
Avg Vintage 1957	5.3%	17.0%	0.1%	12.2%	15.9%	49.5%
Large	3.8%	14.4%	0.0%	11.2%	17.0%	53.6%
Small	7.1%	20.0%	0.3%	13.2%	14.6%	44.8%
<b>Office</b>	7.1%	12.4%	0.3%	26.5%	22.9%	30.8%
Avg Vintage 1994	7.0%	13.0%	0.3%	25.8%	23.0%	30.9%
Large	6.6%	11.7%	0.3%	28.8%	22.5%	30.2%
Medium	7.7%	16.9%	0.5%	16.2%	25.1%	33.6%
Small	16.2%	21.2%	0.8%	15.8%	19.6%	26.3%
Avg Vintage 1957	7.2%	11.8%	0.4%	27.2%	22.8%	30.6%
Large	6.8%	10.7%	0.3%	30.0%	22.3%	29.9%
Medium	8.1%	14.7%	0.6%	18.2%	25.0%	33.5%
Small	15.8%	22.0%	1.0%	17.7%	18.6%	25.0%
<b>Warehouse</b>	25.4%	0.0%	0.2%	0.7%	35.3%	38.4%
Avg Vintage 1994	25.3%	0.0%	0.2%	0.6%	35.4%	38.4%
Large	24.8%	0.0%	0.2%	0.4%	35.8%	38.9%
Small	29.5%	0.0%	0.4%	2.0%	32.7%	35.5%
Avg Vintage 1957	25.5%	0.0%	0.2%	0.7%	35.3%	38.3%
Large	24.9%	0.0%	0.2%	0.5%	35.7%	38.8%
Small	29.6%	0.0%	0.4%	2.4%	32.4%	35.2%

**Table A.9.** Vintages of DOD building stock modeled by region (percent of GSF)

Vintage	DC	FL	NY	CA	TX
1930s	14%	15%	0%	0%	0%
1940s	8%	4%	24%	3%	3%
1950s	11%	20%	0%	7%	7%
1960s	20%	17%	1%	17%	17%

<b>Vintage</b>	<b>DC</b>	<b>FL</b>	<b>NY</b>	<b>CA</b>	<b>TX</b>
1970s	16%	8%	3%	26%	26%
1980s	6%	25%	53%	17%	17%
1990s	22%	7%	19%	22%	22%
2000s	3%	3%	0%	8%	8%

**Table A.10.** DOD buildings proportion of energy consumption by end use by region (site basis)

<b>Region</b>	<b>Space Heating</b>	<b>Space Cooling</b>	<b>Ventilation</b>	<b>Lighting</b>	<b>Hot Water</b>	<b>All Other</b>
DC	24.6%	12.0%	25.8%	11.2%	2.1%	24.3%
FL	28.1%	26.4%	17.3%	9.7%	6.7%	11.8%
NY	61.1%	0.2%	6.3%	9.8%	10.2%	12.4%
CA	49.2%	14.0%	9.6%	10.0%	5.7%	11.4%
TX	37.7%	23.4%	9.8%	10.7%	6.1%	12.3%

**Table A.11.** DOD proportion of GSF by space heating fuel type by region

<b>Heat Fuel</b>	<b>DC</b>	<b>FL</b>	<b>NY</b>	<b>CA</b>	<b>TX</b>
Electricity	3.4%	0.0%	0.0%	1.0%	1.0%
HP	4.9%	0.0%	0.0%	2.0%	2.0%
Steam	20.3%	0.0%	0.0%	8.1%	8.1%
Hot Water	4.6%	0.0%	0.0%	4.1%	4.1%
Oil	7.4%	0.0%	21.7%	0.0%	0.0%
Natural Gas	58.1%	91.4%	65.9%	77.8%	77.8%
Other	0.0%	3.6%	3.0%	0.0%	0.0%
No Heating	1.2%	5.1%	9.4%	7.0%	7.0%

**Table A.12.** DOD proportion of GSF by water heating fuel type by region

<b>Fuel</b>	<b>TX</b>	<b>CA</b>	<b>DC</b>	<b>FL</b>	<b>NY</b>
Electricity	10.3%	10.3%	37.2%	12.9%	14.2%
Steam	3.2%	3.2%	5.6%	0.0%	0.0%
Hot Water	1.5%	1.5%	0.6%	0.0%	0.0%
Oil	0.0%	0.0%	0.9%	0.0%	15.5%
Natural Gas	65.2%	65.2%	49.6%	77.2%	57.9%
Other	0.0%	0.0%	0.0%	0.6%	2.8%
No Hot Water	19.8%	19.8%	6.1%	9.3%	9.6%



### A.2.1 Weighting and Scaling of Estimates

This assessment is designed to reflect national level estimates of potentially cost-effective EUI improvements in the federal building stock. As discussed, estimates have been built up from selecting representative geographic regions based on weather and concentrations of federal building stock in the civilian and defense sectors. One limitation is that it is not practical to develop FEDS models for all regions and building types in the country. Therefore, the regional model results required the application of weights and scaling to be adjusted to account for the breadth of building types and locations needed for a national-level assessment.

Table A.13 reflects the geographic weighting applied to the FEDS model results. These weights were developed based on the shares of the federal stock attributable to these regions of the country, as reported in the Federal Real Property Profile (FRPP) data. The geographic weights were applied to the FEDS model output for each region to create national composite EUI estimates that reflect the contribution of each region.

**Table A.13.** Geographic weights applied to FEDS model output for each region

Region	DOD	Civilian
CA	21.9%	20.3%
VA, MD, DC	39.4%	44.0%
GA, FL	16.2%	15.2%
NY	8.0%	7.8%
TX	14.6%	12.8%

The FEDS modeling of the existing federal civilian stock covered four principal building types including hospitals, laboratories, offices, and warehouses. Table A.14 presents the weights applied to FEDS model outputs. Results for each of these building types were weighted to reflect national level proportions of the floor area represented by these building types in the civilian sector. The weights were further segmented by geographic region to match the aggregate building type weight to the regional proportions presented in Table A.13.

**Table A.14.** Federal civilian building type weights applied to FEDS model output for each region

Federal Civilian Building Type	Civilian Building Type Weights	Regional Weights by Building Type				
		CA	VA, MD, DC	GA, FL	NY	TX
Hospital	10.2%	2.1%	4.5%	1.6%	0.8%	1.3%
Laboratories	14.5%	2.9%	6.4%	2.2%	1.1%	1.9%
Office	61.3%	12.4%	27.0%	9.3%	4.8%	7.8%
Warehouses	14.0%	2.8%	6.2%	2.1%	1.1%	1.8%

Results presented in the report further disaggregate the four building types for which FEDS models were developed: hospitals, laboratories, office, and warehouses. Results for additional non-modeled building types were estimated based on composites of the modeled building types. Composite weights were based on the segmentation of EUIs by building type by end use developed in a Pacific Northwest

National Laboratory (PNNL) study<sup>18</sup> for the Federal Energy Management Program (FEMP). Table A.15 presents the composite proportions used to extend the civilian building type results from the modeled building types to the additional building types presented in the report.

**Table A.15.** Federal civilian building type composites used to extend modeled EUIs to non-modeled building types

Modeled Types	Non-Modeled Building Types				
	Service	School	Other	Prison	Industrial
Storage	36.5%	8.1%	12.1%	0	39.3%
Office	63.5%	71.9%	87.9%	0	0
Hospital	0	0	0	85.0%	0
Research & Development	0	0	0	0	60.7%

Finally, the FEDS modeled results for DOD and civilian buildings were based on actual calibrated studies in the case of DOD facilities, and federal civilian prototype buildings for the civilian sector. Using the estimated baseline EUIs for just these facilities and building types would not be expected to match the weighted average aggregate EUI reported by FEMP for each sector’s goal-subject floor area. Therefore, it is necessary to simply scale the modeled results to the reported goal-subject aggregate EUI for DOD and civilian buildings. Table A.16 presents those scaling factors.

**Table A.16.** Factors applied to modeled EUIs to scale to FEMP reported goal-subject baseline EUIs

Sector	Scaling Factor
Civilian	1.399
DOD	0.754
Total Federal	0.919

## A.2 Cost Assumptions

The following tables present the electricity and gas rates used in the FEDS analysis. DOD natural gas and electricity rates were derived from data reported in the Army Energy and Water Reporting System (AEWRS) during fiscal year 2013 for the specific site modeled. It was assumed that these rates were representative for the region that each site represents. Natural gas and electricity rates for the civilian sector came based on calendar year 2012 and came from utilities in the five geographic regions where the prototype buildings were based.

<sup>18</sup> Judd KS, AR Kora, JW Henderson, BJ Russo, J Katz, M Hummon, and EM Rauch. 2010. Roadmap to a Climate Neutral Federal Government. PNNL-19643, Pacific Northwest National Laboratory, Richland, WA.

**Table A.17.** Regional natural gas rates used in the analysis

Region	Civilian	DOD
	\$/therm	\$/therm
CA	0.78	0.56
DC	1.14	0.28
FL	1.01	0.65
NY	0.92	0.55
TX	0.75	0.40

**Table A.18.** Electricity rates used for the civilian sector analysis

<b>CA</b>		<b>Winter</b>				
Weekdays						
Period	Start Time	End Time	Energy Rate	Units	Demand Rate	Units
1	800	2100	15.73	cents/kWh	9.7	\$/kW
2	2100	800	12.47	cents/kWh	0	\$/kW
Weekends						
1	100	100	12.47	cents/kWh	0	\$/kW
<b>CA</b>		<b>Summer</b>				
Weekdays						
1	800	1200	16.1	cents/kWh	14.86	\$/kW
2	1200	1800	22.06	cents/kWh	26.58	\$/kW
3	1800	2300	16.1	cents/kWh	14.86	\$/kW
4	2300	800	12.84	cents/kWh	9.7	\$/kW
Weekends						
1	100	100	5.02	cents/kWh	0	\$/kW
<b>DC</b>		<b>Winter</b>				
Weekdays						
1	700	2200	9.25	cents/kWh	11.11	\$/kW
2	2200	700	6.61	cents/kWh	0	\$/kW
Weekends						
1	100	100	6.61	cents/kWh	0	\$/kW
<b>DC</b>		<b>Summer</b>				
Weekdays						
1	1000	2200	9.25	cents/kWh	12.52	\$/kW
2	2200	1000	6.61	cents/kWh	0	\$/kW
Weekends						
1	100	100	6.61	cents/kWh	0	\$/kW
<b>FL</b>		<b>Winter</b>				
Weekdays						
1	100	100	6.13	cents/kWh	4.32	\$/kW
Weekends						
1	100	100	6.13	cents/kWh	0	\$/kW
<b>FL</b>		<b>Summer</b>				
Weekdays						
1	2100	1200	6.56	cents/kWh	0	\$/kW
2	1200	1400	9.79	cents/kWh	4.32	\$/kW
3	1400	1900	15.39	cents/kWh	12.93	\$/kW
4	1900	2100	9.79	cents/kWh	4.32	\$/kW
Weekends						

1	2200	1100	3.32	cents/kWh	0	\$/kW
2	1100	2200	5.41	cents/kWh	0	\$/kW
<b>TX</b>	<b>All Months</b>					
All Days						
1	1400	1900	15.85	cents/kWh	6.35	\$/kW
2	1900	1400	3.35	cents/kWh	0	\$/kW
<b>NY</b>	<b>Winter</b>					
Weekdays						
1	700	2300	12.56	cents/kWh	3.58	\$/kW
2	2300	700	11.17	cents/kWh	0	\$/kW
Weekends						
1	100	100	11.17	cents/kWh	0	\$/kW
<b>NY</b>	<b>Summer</b>					
Weekdays						
1	700	2300	12.56	cents/kWh	3.58	\$/kW
2	2300	700	11.17	cents/kWh	0	\$/kW
Weekends						
1	100	100	11.17	cents/kWh	0	\$/kW

**Table A.19.** Electricity rates used for the DOD sector analysis

<b>CA</b>	<b>Winter</b>					
Weekdays						
Period	Start Time	End Time	Energy Rate	Units	Demand Rate	Units
1	800	1700	7.24	cents/kWh	6.27	\$/kW
2	1700	800	5.56	cents/kWh	0	\$/kW
Weekends						
1	100	100	5.56	cents/kWh	0	\$/kW
<b>CA</b>	<b>Summer</b>					
Weekdays						
1	800	1200	6.95	cents/kWh	4.93	\$/kW
2	1200	1800	10.94	cents/kWh	24.73	\$/kW
3	1800	2300	6.95	cents/kWh	4.93	\$/kW
4	2300	800	5.02	cents/kWh	0	\$/kW
Weekends						
1	100	100	5.02	cents/kWh	0	\$/kW
<b>DC</b>	<b>Winter</b>					
Weekdays						
1	700	2200	2.99	cents/kWh	13.97	\$/kW
2	2200	700	2.86	cents/kWh	0	\$/kW
Weekends						
1	600	600	2.86	cents/kWh	0	\$/kW
<b>DC</b>	<b>Summer</b>					
Weekdays						
1	1000	2200	2.99	cents/kWh	13.97	\$/kW
2	2200	1000	2.86	cents/kWh	0	\$/kW
Weekends						
1	600	600	2.86	cents/kWh	0	\$/kW
<b>FL</b>	<b>Winter</b>					
Weekdays						
1	700	2300	3.86	cents/kWh	0	\$/kW
2	2300	700	3.04	cents/kWh	0	\$/kW
Weekends						

1	2400	800	3.01	cents/kWh	0	\$/kW
2	800	2400	3.7	cents/kWh	0	\$/kW
<b>FL</b>	<b>Summer</b>					
Weekdays						
1	2000	1200	3.51	cents/kWh	0	\$/kW
2	1200	1400	6.56	cents/kWh	0	\$/kW
3	1400	1800	11.05	cents/kWh	0	\$/kW
4	1800	2000	6.56	cents/kWh	0	\$/kW
Weekends						
1	2200	1100	3.32	cents/kWh	0	\$/kW
2	1100	2200	5.41	cents/kWh	0	\$/kW
<b>TX</b>	<b>All Months</b>					
All Days						
1	All Hours		6.51	cents/kWh	0	\$/kW
*	Ratchet				4.34	\$/kW
<b>NY</b>	<b>Winter</b>					
Weekdays						
1	2200	600	6.62	cents/kWh	0	\$/kW
2	600	1200	10.39	cents/kWh	0	\$/kW
3	1200	1600	7.53	cents/kWh	0	\$/kW
4	1600	2200	11.59	cents/kWh	3.44	\$/kW
Weekends						
1	2200	600	6.62	cents/kWh	0	\$/kW
2	600	1600	9.25	cents/kWh	0	\$/kW
3	1600	2200	11.59	cents/kWh	0	\$/kW
<b>NY</b>	<b>Summer</b>					
Weekdays						
1	2200	900	3.45	cents/kWh	0	\$/kW
2	900	2200	4.52	cents/kWh	3.44	\$/kW
Weekends						
1	2200	900	3.45	cents/kWh	0	\$/kW
2	900	2200	4.52	cents/kWh	3.44	\$/kW
3	0	0	0	cents/kWh	0	\$/kW

Other key cost assumptions include:

- No rebates or incentives were assumed to be applied to the selection of measures. Cost-effectiveness was not based on utilities subsidizing any measures.
- Life-cycle costing relied upon a 3% discount rate assumption.
- ECM costs reference RS Means and many other data sources for real costs.
- Rate schedules reflect actual energy prices in place at the sites modeled.
- Design and overhead rates were applied to all ECM costs. Rates used were informed by those typically applied by the Corps of Engineers for DOD projects and by GSA for civilian projects. These were assumed to be:
  - 10% design
  - 6% supervision, inspection, and overhead (SIOH)
  - 15% contractor profit

### A.3 Selection of Cost-effective ECMs

#### A.3.1 Civilian Buildings

Table A.20 lists the ECMs selected as cost-effective by the FEDS model for the major civilian building types modeled. Each measure’s simple payback period and savings-to-investment ratio (SIR) is provided as a basis for comparison of measures. Because the FEDS-based analysis was designed to reflect the major climate regions and representative federal building stock regions, this list reflects the list of measures expected to cost-effective at the national average. Not all measures listed will be cost-effective in all areas, but all would be cost-effective in the locations where the FEDS model estimates they would, based on the state of the existing stock, prevailing electric tariffs, fossil fuel rates, and baseline operating regimes.

The intent of the tables below is to list the measures FEDS found cost effective and illustrate at the summary level, what the economic impacts would be from their adoption at the modeled sites/buildings. Because the following tables represent a composite of all retrofits across modeled building types and regions, in some cases, retrofits shown in the table will reflect shorter paybacks for higher-end (more expensive) technologies. This is a result of the cost-effectiveness thresholds being different under differing climate and utility price regimes, and the resulting impact being higher for a specific technology at one site than at another. For example, in Table A.20, a gas boiler with an 84 percent efficiency has a weighted average simple payback of 14.8 years, while one with a 91 percent efficiency has a payback of 10.7 years. This is counterintuitive, but correct, given that the table is combining the impacts across all sites, vintages, types, and sizes.

Tables A.20 and A.21 present the measures selected from the FEDS analysis as well the estimated energy savings, SIR and simple payback by energy end use and ECM. These values have not been fully weighted or scaled to all civilian building types and locations or DOD locations. The derived payback in Table 7 in the body of the report was calculated based on the fully weighted energy analysis, which is why aggregate average payback for civilian and DOD investments are slightly different. The tables below are included to provide some numerical insight for comparing between the measures.

Naming conventions for the measures in the table below can be found in the FEDS User Guide at: [http://www.pnl.gov/feds/pdfs/FEDS\\_6-0\\_user\\_guide.pdf](http://www.pnl.gov/feds/pdfs/FEDS_6-0_user_guide.pdf).

**Table A.20.** Federal civilian buildings national average cost-effective ECMs

Cost-Effective ECMs by End Use	Percent of Aggregate Energy Savings	Energy Savings-Weighted Avg SIR	Energy Savings-Weighted Avg Simple Payback
<b>Floor</b>	1.8%	4.3	4.9
Insulate Perimeter of Slab on Grade: Increase Insulation by R-10	0.0%	1.8	8.6
Insulate Perimeter of Slab on Grade: Increase Insulation by R-15	1.8%	4.3	4.9
Insulate Perimeter of Slab on Grade: Increase Insulation by R-7.5	0.0%	3.0	4.0
<b>Windows</b>	17.8%	1.6	11.8
Add Retrofit Film	0.2%	1.7	6.1
Install Thermal Break Aluminum Frame Double Pane Argon/Super Low-e Window	2.2%	1.4	14.3

<b>Cost-Effective ECMs by End Use</b>	<b>Percent of Aggregate Energy Savings</b>	<b>Energy Savings-Weighted Avg SIR</b>	<b>Energy Savings-Weighted Avg Simple Payback</b>
Install Wood or Vinyl Frame Double Pane Argon/Low-e Window	1.7%	1.8	10.1
Install Wood or Vinyl Frame Double Pane Argon/Super Low-e Window	13.6%	1.6	11.7
<b>Heating</b>	<b>22.5%</b>	<b>3.0</b>	<b>7.5</b>
Add Automatic Electric Damper	0.6%	23.9	1.1
Add Feedwater Economizers	0.5%	1.7	11.5
Condensing Gas Boiler - 91% Combustion Efficiency	0.5%	1.9	10.7
Conventional Gas Boiler - 84% Combustion Efficiency	0.0%	1.3	14.8
Conventional Gas Furnace - 80% Efficient	-0.2%	8.5	0.9
Conventional Gas Furnace - 84% Efficient	-0.1%	10.9	0.5
Electric Infrared Heating System	4.2%	2.8	6.8
Natural Gas Infrared Heating System - High Efficiency	16.0%	2.6	6.9
Natural Gas Infrared Heating System - Standard Efficiency	0.9%	1.1	17.0
<b>Hot Water</b>	<b>12.9%</b>	<b>10.8</b>	<b>3.2</b>
Central Heat Pump Hot Water System, Wrap Tank	0.3%	1.9	8.6
Central Heat Pump Hot Water System, Wrap Tank, Aerators	0.3%	2.0	7.8
Condensing Gas Boiler - 91% Combustion Efficiency, Wrap Tank	0.3%	6.3	3.0
Condensing Gas Boiler - 91% Combustion Efficiency, Wrap Tank, LFSHs	4.8%	8.8	2.4
Conventional Gas Boiler - 84% Combustion Efficiency, Wrap Tank	1.5%	8.8	2.4
Conventional Gas Boiler - 84% Combustion Efficiency, Wrap Tank, Aerators	2.3%	9.7	2.2
Conventional Gas Boiler - 84% Combustion Efficiency, Wrap Tank, LFSHs	0.5%	8.9	2.3
Faucet Aerators, Lower Tank Temperature	0.0%	25.0	0.6
Heat Pump Water Heater (Com), Aerators, LFSHs	2.3%	1.5	6.6
Insulate Pipe Near Tank, Aerators	0.0%	12.1	1.2
Insulate Pipe Near Tank, Aerators, Lower Tank Temperature	0.0%	17.5	0.8
Insulate Pipe Near Tank, LFSHs, Aerators	0.0%	7.6	1.9
Replace Existing Water Heater with 0.78 Gas Water Heater (Com)	0.0%	1.1	7.7
Replace Existing Water Heater with 0.78 Gas Water Heater (Com), LFSHs, Aerators	-0.1%	1.5	5.4
Replace Existing Water Heater with 0.94 Gas Water Heater (Com), LFSHs, Aerators	-0.2%	2.6	3.0
Wrap Tank with Insulation	0.1%	107.3	0.3
Wrap Tank with Insulation, Aerators	0.0%	9.7	1.6
Wrap Tank with Insulation, Aerators, Lower Tank Temperature	0.0%	8.7	1.9
Wrap Tank with Insulation, Insulate Pipe Near Tank, Aerators	0.1%	10.3	1.7
Wrap Tank with Insulation, Insulate Pipe Near Tank, Aerators, Lower Tank Temperature	0.0%	15.4	1.0
Wrap Tank with Insulation, Insulate Pipe Near Tank, LFSHs, Aerators	0.2%	14.2	1.1
Wrap Tank with Insulation, LFSHs	0.3%	103.9	0.2
<b>Lighting</b>	<b>39.8%</b>	<b>29.6</b>	<b>4.7</b>
CF10: CFL 27 INTEGRAL UNIT	0.3%	105.3	0.2
CF11: CFL 30 INTEGRAL UNIT ELC	0.1%	122.0	0.3
CF13: CFL 18 GLOBE UNIT	0.0%	64.5	0.4
CF36: CFL 13 INTEGRAL UNIT ELC	1.6%	66.1	0.3
CF37: CFL 32 INTEGRAL UNIT ELC	0.0%	100.8	0.3
CF38: CFL 42 INTEGRAL UNIT ELC	7.9%	75.5	0.2
CF39: CFL 55 INTEGRAL UNIT ELC	0.4%	31.9	0.6

Cost-Effective ECMs by End Use	Percent of Aggregate Energy Savings	Energy Savings-Weighted Avg SIR	Energy Savings-Weighted Avg Simple Payback
CF4: CFL 15 INTEGRAL UNIT ELC	0.2%	61.6	0.5
CF5: CFL 18 INTEGRAL UNIT ELC	1.6%	61.2	0.3
CF6: CFL 20 INTEGRAL UNIT ELC	0.2%	86.3	0.3
CF9: CFL 26 INTEGRAL UNIT ELC	3.0%	66.6	0.3
EX11: EXIT - ELECTROLUMINESCENT PANEL	1.0%	15.2	1.5
EX12: EXIT - ELECTROLUMINESCENT PANEL RETRO KIT	1.5%	16.9	1.3
FL244: FL 2X4 4F32T8 ELC4	0.4%	2.2	8.1
FL263: FL 2X2 2F14T5 ELC2 REF	1.4%	5.5	4.2
FL273: FL 2X4 4F54T5HO ELC2 REF	0.3%	1.6	11.1
FL275: FL 2X4 2F32ST8 ELC2	0.3%	1.6	10.0
FL276: FL 2X4 3F32ST8 ELC3	0.1%	2.3	7.0
FL279: FL 2X4 2F32ST8 ELC2 REF	0.7%	1.4	11.9
FL280: FL 2X4 3F32ST8 ELC3 REF	6.7%	2.8	7.1
FL283: FL 2X4 2F30ST8 ELC2	2.6%	2.3	7.9
FL283: FL 2X4 2F30ST8 ELC2 (Component Repl.)	2.1%	1.5	11.3
FL284: FL 2X4 3F30ST8 ELC3	0.2%	3.6	4.5
FL284: FL 2X4 3F30ST8 ELC3 (Component Repl.)	1.2%	1.3	12.4
FL285: FL 2X4 4F30ST8 ELC2	0.0%	1.4	12.5
FL287: FL 2X4 2F30ST8 ELC2 REF (Component Repl.)	0.0%	1.1	15.0
FL288: FL 2X4 3F30ST8 ELC3 REF	1.2%	2.0	8.6
FL289: FL 2X4 4F30ST8 ELC2 REF	1.3%	3.4	5.3
FL303: FL 2X4 2F25ST8 ELC2 REF	1.1%	1.7	10.4
FL304: FL 2X4 3F25ST8 ELC3 REF	0.3%	3.4	4.9
FL309: FL 2X3 6F40BX ELC2 REF	0.2%	2.1	8.1
FL52: FL 1X4 2F32T8 ELC2	1.8%	2.5	7.3
FL53: FL 1X4 1F32T8 ELC1	0.1%	10.3	2.3
HS18: HPS 310 PEND	0.0%	1.2	14.6
HS97: HPS 70 WALL ELC	0.0%	1.1	15.8
MH67: MH 150 HE WALL ELC	0.0%	2.6	6.6
<b>Roof</b>	<b>0.7%</b>	<b>1.3</b>	<b>12.3</b>
Attic Ceiling: Increase Insulation by R-19 (blow-in cellulose)	0.0%	1.5	7.8
Suspended Ceiling: Increase Insulation by R-19	0.5%	1.2	12.6
Suspended Ceiling: Increase Insulation by R-38	0.2%	1.6	11.6
<b>Wall</b>	<b>4.5%</b>	<b>2.4</b>	<b>8.1</b>
Blow-in Wall Insulation to Fill Available Space	4.5%	2.4	8.1
<b>Grand Total</b>	<b>100.0%</b>	<b>14.3</b>	<b>6.6</b>

### A.3.2 DOD Buildings

Table A.21 lists the ECMs selected as cost-effective by the FEDS model for the DOD sites modeled. Each measure's simple payback period and savings-to-investment ratio (SIR) is provided as a basis for comparison of measures. Because the FEDS-based analysis was designed to reflect the major climate regions and representative federal building stock regions, this list reflects the list of measures expected to cost-effective at the national average. Not all measures listed will be cost-effective in all areas, but all would be cost-effective in the locations where the FEDS model estimates they would, based on the state of the existing stock, prevailing electric tariffs, fossil fuel rates, and baseline operating regimes.



The intent of the tables below is to list the measures FEDS found cost effective and illustrate at the summary level, what the economic impacts would be from their adoption at the modeled sites/buildings. Because the following tables represent a composite of all modeled retrofits across building types and regions, in some cases, retrofits shown in the table will reflect shorter paybacks for higher-end (more expensive) technologies. This is a result of the cost-effectiveness thresholds being different under differing climate and utility price regimes, and the resulting impact being higher for a specific technology at one site than at another. For example, in Table A.21, increasing attic insulation to R-13 has a weighted average simple payback of 12.0 years, while increasing to R-38 has a payback of 2.4 years. This is counterintuitive, but correct, given that the table is combining the impacts across all sites, vintages, types, and sizes. So for example, in some places (TX/CA/FL) it would be technically cost efficient to go to R-13 blown-in attic insulation, but no further. Going to R-13 from nothing in those areas would have a relatively long payback because there are some but not a lot of savings. However, in northern climates it is cost effective to go to R-38 and the savings are so substantial (going from no or very little insulation to R-38) that the payback is much shorter.

**Table A.21.** DOD facilities national average cost-effective ECMs

Cost-Effective ECMs by End Use	Percent of Aggregate Energy Savings	Energy Savings-Weighted Avg SIR	Energy Savings-Weighted Avg Simple Payback
<b>Floor</b>	<b>2.7%</b>	<b>1.9</b>	<b>10.3</b>
Insulate Perimeter of Slab on Grade: Increase Insulation by R-10	0.6%	1.5	12.5
Insulate Perimeter of Slab on Grade: Increase Insulation by R-15	2.1%	2.0	9.7
<b>Windows</b>	<b>3.0%</b>	<b>1.2</b>	<b>11.8</b>
Add Retrofit Film	0.0%	1.3	4.1
Install Aluminum Frame Double Pane Argon/Low-e Window	0.1%	1.0	19.1
Install Aluminum Frame Double Pane Argon/Super Low-e Window	1.1%	1.2	12.0
Install Thermal Break Aluminum Frame Double Pane Argon/Super Low-e Window	1.7%	1.3	11.5
<b>Heating</b>	<b>17.7%</b>	<b>4.3</b>	<b>10.5</b>
Add Automatic Electric Damper	1.3%	8.5	2.9
Condensing Gas Furnace - 90% Efficient	0.0%	22.7	0.9
Condensing Gas Furnace - 92% Efficient	0.0%	11.0	1.4
Conventional Gas Boiler - 80% Combustion Efficiency	0.1%	9.9	4.8
Conventional Gas Boiler - 84% Combustion Efficiency	0.2%	3.1	10.3
Conventional Gas Furnace - 80% Efficient	0.4%	25.5	0.8
Conventional Gas Furnace - 84% Efficient	0.0%	29.1	0.5
Electric Infrared Heating System	2.6%	3.2	7.8
Natural Gas Infrared Heating System - High Efficiency	4.3%	5.4	8.8
Natural Gas Infrared Heating System - Medium Efficiency	4.5%	1.8	14.1
Natural Gas Infrared Heating System - Standard Efficiency	4.3%	3.3	13.4
<b>HEATING/Cooling</b>	<b>0.2%</b>	<b>1.0</b>	<b>12.5</b>
High Efficiency Electric Air Source Heat Pump (Commercial)	0.3%	1.1	11.4
Standard Efficiency Packaged Terminal AC Unit (PTAC) with Electric Resistance Heat	-0.1%	1.4	6.9
<b>Hot Water</b>	<b>7.2%</b>	<b>37.8</b>	<b>1.2</b>
Central Heat Pump Hot Water System, Wrap Tank, LFSHs	0.1%	1.4	9.4
Condensing Gas Boiler - 91% Combustion Efficiency, Wrap Tank	0.2%	4.5	5.8
Condensing Gas Boiler - 91% Combustion Efficiency, Wrap Tank, LFSHs	0.1%	11.5	2.2

<b>Cost-Effective ECMs by End Use</b>	<b>Percent of Aggregate Energy Savings</b>	<b>Energy Savings-Weighted Avg SIR</b>	<b>Energy Savings-Weighted Avg Simple Payback</b>
Condensing Gas Boiler - 91% Combustion Efficiency, Wrap Tank, LFSHs, Aerators	0.2%	8.9	2.7
Conventional Gas Boiler - 80% Combustion Efficiency, Wrap Tank	0.0%	7.6	2.2
Conventional Gas Boiler - 80% Combustion Efficiency, Wrap Tank, LFSHs	0.0%	56.8	0.3
Conventional Gas Boiler - 81.5% Combustion Efficiency, Wrap Tank	0.0%	14.4	1.2
Conventional Gas Boiler - 84% Combustion Efficiency, Wrap Tank	0.1%	9.3	2.1
Conventional Gas Boiler - 84% Combustion Efficiency, Wrap Tank, Aerators	0.0%	11.1	1.6
Conventional Gas Boiler - 84% Combustion Efficiency, Wrap Tank, LFSHs	0.1%	11.0	1.8
Conventional Gas Boiler - 84% Combustion Efficiency, Wrap Tank, LFSHs, Aerators	0.6%	11.1	2.5
Faucet Aerators	0.0%	38.2	1.2
Faucet Aerators, Lower Tank Temperature	0.1%	48.4	0.9
Insulate Pipe Near Tank, LFSHs	0.0%	20.5	0.8
Insulate Pipe Near Tank, LFSHs, Lower Tank Temperature	0.0%	1.5	10.4
LFSHs, Aerators, Lower Tank Temperature	0.0%	7.1	2.2
Low-Flow Showerheads (LFSHs)	0.0%	98.3	1.0
Low-Flow Showerheads (LFSHs), Aerators	0.0%	49.9	0.3
Low-Flow Showerheads (LFSHs), Lower Tank Temperature	0.0%	8.8	4.5
Replace Existing Water Heater with 0.78 Gas Water Heater (Com), LFSHs, Lower Tank Temp.	0.0%	1.9	4.6
Replace Existing Water Heater with 0.94 Gas Water Heater (Com), LFSHs, Aerators	0.2%	6.0	1.4
Replace Existing Water Heater with 0.94 Gas Water Heater (Com), LFSHs, Lower Tank Temp.	0.0%	2.6	3.3
Wrap Tank with Insulation	2.1%	68.9	0.3
Wrap Tank with Insulation, Aerators	0.2%	38.4	0.9
Wrap Tank with Insulation, Aerators, Lower Tank Temperature	0.1%	15.6	2.2
Wrap Tank with Insulation, Insulate Pipe Near Tank, Aerators, Lower Tank Temperature	0.0%	14.6	1.0
Wrap Tank with Insulation, Insulate Pipe Near Tank, LFSHs	0.0%	10.8	1.5
Wrap Tank with Insulation, Insulate Pipe Near Tank, LFSHs, Lower Tank Temperature	0.0%	25.7	0.6
Wrap Tank with Insulation, LFSHs	2.3%	36.5	0.8
Wrap Tank with Insulation, LFSHs, Aerators	0.8%	18.1	1.2
Wrap Tank with Insulation, LFSHs, Aerators, Lower Tank Temperature	0.0%	9.5	1.6
<b>Lighting</b>	<b>8.4%</b>	<b>15.6</b>	<b>6.0</b>
CF10: CFL 27 INTEGRAL UNIT	0.3%	70.3	0.3
CF11: CFL 30 INTEGRAL UNIT ELC	0.0%	21.6	1.0
CF2: CFL 9 INTEGRAL UNIT ELC	0.1%	78.3	0.7
CF3: CFL 11 INTEGRAL UNIT ELC	0.0%	42.4	0.4
CF36: CFL 13 INTEGRAL UNIT ELC	1.4%	24.8	0.8
CF38: CFL 42 INTEGRAL UNIT ELC	0.0%	31.5	0.9
CF39: CFL 55 INTEGRAL UNIT ELC	0.0%	14.6	1.2
CF4: CFL 15 INTEGRAL UNIT ELC	0.2%	48.3	0.6
CF40: CFL 85 INTEGRAL UNIT ELC	0.0%	29.1	0.6
CF47: CFL 27 INTEGRAL FLOOD ELC	0.0%	26.4	0.7
CF5: CFL 18 INTEGRAL UNIT ELC	1.1%	33.2	0.6

Cost-Effective ECMs by End Use	Percent of Aggregate Energy Savings	Energy Savings-Weighted Avg SIR	Energy Savings-Weighted Avg Simple Payback
CF6: CFL 20 INTEGRAL UNIT ELC	0.1%	55.9	0.3
CF7: CFL 23 INTEGRAL UNIT ELC	0.0%	69.4	0.2
CF9: CFL 26 INTEGRAL UNIT ELC	0.0%	19.8	1.4
EX11: EXIT - ELECTROLUMINESCENT PANEL	0.2%	10.4	3.6
EX12: EXIT - ELECTROLUMINESCENT PANEL RETRO KIT	0.0%	5.2	5.3
FL244: FL 2X4 4F32T8 ELC4	0.3%	2.0	9.1
FL273: FL 2X4 4F54T5HO ELC2 REF	0.3%	1.6	11.0
FL275: FL 2X4 2F32ST8 ELC2	0.2%	1.5	12.1
FL276: FL 2X4 3F32ST8 ELC3	0.1%	1.5	11.2
FL277: FL 2X4 4F32ST8 ELC2	0.0%	7.4	4.4
FL280: FL 2X4 3F32ST8 ELC3 REF	0.9%	1.7	10.6
FL281: FL 2X4 4F32ST8 ELC2 REF	0.7%	2.5	7.4
FL283: FL 2X4 2F30ST8 ELC2	1.1%	1.7	10.4
FL283: FL 2X4 2F30ST8 ELC2 (Component Repl.)	0.0%	1.2	13.8
FL284: FL 2X4 3F30ST8 ELC3	0.2%	2.3	8.0
FL284: FL 2X4 3F30ST8 ELC3 (Component Repl.)	0.1%	1.3	13.1
FL289: FL 2X4 4F30ST8 ELC2 REF	0.1%	2.9	7.0
FL289: FL 2X4 4F30ST8 ELC2 REF (Component Repl.)	0.0%	1.1	14.8
FL291: FL 2X4 2F28ST8 ELC2	0.0%	8.7	2.0
FL305: FL 2X4 4F25ST8 ELC2 REF	0.1%	9.6	1.9
FL309: FL 2X3 6F40BX ELC2 REF	0.1%	1.7	9.7
FL52: FL 1X4 2F32T8 ELC2	0.5%	1.7	10.6
FL53: FL 1X4 1F32T8 ELC1	0.0%	1.2	14.2
FL54: FL 2X2 2F32T8U ELC2	0.1%	1.9	9.3
HS25: HPS 150 WALL	0.0%	1.5	12.0
MH67: MH 150 HE WALL ELC	0.0%	2.4	7.2
<b>Roof</b>	<b>39.6%</b>	<b>4.2</b>	<b>5.9</b>
Add Insulation to Interior Surface of Metal Roof: 2-layer Reflective Bubble Pack	1.3%	2.0	11.6
Add Insulation to Interior Surface of Metal Roof: 4 inches Fiberglass	12.4%	2.9	7.4
Attic Ceiling: Increase Insulation by R-13 (blow-in cellulose)	0.5%	1.8	12.0
Attic Ceiling: Increase Insulation by R-19 (blow-in cellulose)	1.5%	4.3	4.9
Attic Ceiling: Increase Insulation by R-30 (blow-in cellulose)	2.7%	6.8	2.4
Insulate Built-up Roof Surface (R-10) and Re-Roof	1.9%	1.9	11.7
Insulate Built-up Roof Surface (R-15) and Re-Roof	3.9%	3.1	4.6
Insulate Built-up Roof Surface (R-20) and Re-Roof	0.9%	3.6	4.3
Suspended Ceiling: Increase Insulation by R-11	0.4%	4.5	7.5
Suspended Ceiling: Increase Insulation by R-19	8.1%	5.3	5.0
Suspended Ceiling: Increase Insulation by R-38	6.1%	6.4	3.3
<b>Wall</b>	<b>21.2%</b>	<b>6.4</b>	<b>6.3</b>
Add Interior Masonry Surface Insulation: R-12.4	0.3%	1.2	14.6
Add Interior Metal Wall Surface Insulation: 2-layer Reflective Bubble Pack	2.1%	2.2	9.9
Add Interior Metal Wall Surface Insulation: 4 inches Fiberglass	15.9%	7.8	5.0
Blow-in Wall Insulation to Fill Available Space	2.8%	2.0	9.7
<b>Grand Total</b>	<b>100.0%</b>	<b>7.9</b>	<b>6.8</b>

## Appendix B. Estimating Impact of New Construction on the 2025 Federal Energy Goal: Detailed Methodology

The current method used to track improvements in building energy efficiency by federal agencies relies on an aggregate energy use intensity (EUI) as means of measuring progress. The EUI is developed for the total floor space of all buildings maintained by an agency, with the exclusion of some buildings with distinctly abnormally high process loads. There is no distinction made for buildings of different vintages.

This method thus incorporates the energy use and floor space of buildings that are constructed *during* the period established for meeting the EUI reduction targets. It is clear then that newly constructed buildings, built using the latest energy-efficient technologies and practices, will lower the overall EUI of the stock of buildings, irrespective of actions taken by the agency to reduce the energy use in older buildings. Given this situation, the setting of future goals with regard to the reduction of the stock EUI must attempt to take into account the impact that new buildings might exert on the reduction in the EUI for the stock of buildings.

An estimate of the impact of new building construction on any future EUI must consider two major factors: 1) the percentage of new building floor space in the stock at the end of the goal-setting period, and 2) the average difference of the EUI new buildings relative to the existing stock at the beginning of the goal-setting period. For the current study, the projections pertain to the share and average intensity of newly constructed federal building floor space over the period 2016-2025.

To develop values for these factors, considerable effort was devoted to understand how recently constructed buildings may have influenced the progress that has been made from 2003. Having approximate values of both the quantity and energy intensity of the floor space in buildings built over the last decade would help inform any method to extrapolate the impact from this source out to 2025. Unfortunately, the available data sources to estimate recently-built federal construction and the associated overall energy intensity were inadequate for this task. Ideally, agencies reporting floor space and energy efficiency data to the General Services Administration (GSA) and the Federal Energy Management Program (FEMP) would include building characteristics such as year built, utilization (e.g., occupant density and weekly hours), and location. This information would aid in determining how these newly constructed buildings have influenced the historical evolution of agency-level EUIs. However, data with this level of detail is not available.

With regard to simply estimating the magnitude of new (recently built) federal building floor space, the available information sources outside the agencies reporting to GSA and FEMP are also inadequate. This study examined new construction data provided by the McGraw-Hill Construction (MHC) company and by the U.S. Census Bureau. Neither of these sources can be relied upon to develop a robust estimate of recently built building floor space in the federal sector. A more complete discussion of what data are available from all sources is contained in Appendix C.

The inadequacy of the data sources to provide direct estimates of recently constructed federal floor area and associated energy intensity led to the development of alternative methods that rely heavily on analyst judgment, but use empirical data where it is available.

These alternative methods are laid out in the following two subsections. Section B.1 presents a method to project new federal construction between 2016 and 2025. The method relies primarily on an estimate of how much floor space is disposed in each year (dependent in some degree on the reporting to GSA as part of the Federal Real Property Profile, FRPP), and a projection of expected annual growth in the stock of floor space.<sup>19</sup> These values are established separately for each of the major agencies. Section B.2 lays out the methodology to estimate the relative difference in the EUI for future federal buildings (over the period 2016 to 2025) and the stock of federal buildings as of 2015. This methodology relies heavily on recent analysis of the evolution of nonresidential building energy efficiency standards since 2004. These building energy efficiency standards form the basis of how much energy efficiency new federal buildings will be required to incorporate over the coming decade.

### **B.1 Projected New Federal Construction, 2016-2025**

There is considerable uncertainty as to the growth of the federal building stock out to 2025 given continuing budget constraints and efforts to more effectively utilize existing assets. To address this question the research team considered separately the amount of floor area that might be replaced (due to demolition, sale, or transfer) as well as the annual growth of floor area that may be required to meet the agency's mission. With regard to amount of replacement square footage, some guidance is provided in the historical reporting to GSA as part of the FRPP.

The first two columns in Table B.1 present the average annual "disposals" of floor space over two recent time periods, 2007-2012, and 2011-2012.<sup>20</sup> The third column reflects a judgment as to average annual disposals that might occur out through the year 2025. Using this assumption and an assumed growth rate in total stock (the second shaded column), the simple stock accounting model yields an approximate estimate of the amount of new (2016-2025) floor space that would be part of the stock at the end of 2025 (shown in the last column of the table).

The agencies are grouped into three categories: 1) civilian agencies reporting through the FRPP, 2) the U.S. Postal Service, USPS (whose floor space is reported to FEMP), and the 3) the Department of Defense (DOD). The entries for DOD are based on the magnitude of floor space reported by means of its Base Structure Report, which was provided by the Office of the Secretary.<sup>21</sup>

The table reflects a provisional scenario. In early July 2013, FEMP requested agencies to comment on the disposal or growth assumptions pertaining to their particular agency.<sup>22</sup> The highlighted portions of the table represent analyst judgment. The darker highlighted entries identify agencies in which specific

---

<sup>19</sup> The publicly available reports related to the FRPP can be found on GSA website: <http://www.gsa.gov/portal/category/21275>

<sup>20</sup> These data were based upon special tabulations, in spreadsheets, prepared by GSA for FEMP and transmitted to PNNL via personal communication from FEMP's Chris Tremper on May 10, 2013. These tables showing floor space stock and disposals are shown as Appendix Tables B.1 and B.2.

<sup>21</sup> The DOD magnitudes were obtained via personal communication from Ariel Castillo of the DOD, via a spreadsheet sent to FEMP on September 4, 2013.

<sup>22</sup> The FEMP request was sent as a series of email messages to appropriate agency staff on July 9, 2013.

responses to this request were obtained.<sup>23</sup> With regard to the civilian buildings covered by the FRPP, the average growth rate between 2015 and 2025 is projected to be 0.9 percent per year, just slightly higher than the projected rate of population growth by the Census Bureau.<sup>24</sup>

**Table B.1.** Projected new 2016-2025 federal construction and share of 2025 stock (million square feet)

	Average Disposals/Year			Floor Space	Growth Rate	Floor Space	Total Sq.Ft.	% of 2025
	2007-2012	2011-2012	2016-2025	2012	2012-2025	2025	(2016-2025)	Stock
Civilian (FRPP)	8	20	13	1,205	0.9%	1,319	219	16.6%
Energy	1.4	4.2	1.5	117	0.3%	122	19	15.3%
GSA	3.3	10.0	5.0	417	0.8%	463	85	18.5%
Justice	0.1	0.3	0.3	71	0.8%	79	9	11.4%
VA	0.4	0.4	0.4	163	1.2%	182	18	9.9%
Agriculture	0.7	1.2	1.0	58	0.5%	62	13	21.1%
Home. Security	0.7	0.9	0.8	48	0.8%	53	12	22.7%
Interior	0.7	1.3	1.0	71	0.5%	76	14	18.0%
NASA	0.3	0.4	0.3	47	0.0%	49	5	10.9%
All Other			2.7	212	0.9%	233	44	18.7%
USPS (see Note)		Not Avail.	0.4	273	-0.2%	265	4	1.5%
Dept. of Defense			4.7	2,300		2,240	98	4.4%

**Notes:**

- 1) Shaded cells represent assumed values by PNNL. Darker shaded cells reflect specific input from an agency.
- 2) USPS floor space is not reported to GSA as part of the FRPP, but is reported to FEMP.

Annual values of new construction and disposals from DOD were given for the years 2015 to 2020. (See Table B.2.)<sup>25</sup> The projections for new construction provided are based upon 5-year budget projections. New construction floor space is projected to be 11.1 million square feet in 2016, 11.7 million square feet in 2017, and 9.5 million square feet in 2018. However, the projected construction drops off abruptly for 2019 and 2020 (0.7 million square feet in 2019 and 0.2 million square feet in 2020). These lower most likely represent periods beyond the planning period for most elements in DOD, and would not represent generally expected construction levels for these years. For the analysis here, it is assumed that construction over the 2019-2020 averages just 8 million square feet per year. As a result, the level of 2,210 million square feet for 2020 is about 15 million square feet greater than the projection provided by DOD for that year.

**Table B.2.** Projected floor space for the Department of Defense (military bases)

	2015	2020	2025	2016-2020	2021-2025	Additions as % of 2025 stock
Floor Space Stock	2,188	2,210	2,240			4.4%
New Construction				48.3	50	
Disposals				26.6	20	

<sup>23</sup> The response from the DOE was obtained via e-mail from Drew Campbell to Chris Tremper on July 18, 2013.

<sup>24</sup> The 2012 Census Bureau projection (Series NP2012-T1) showed an annual growth rate in U.S. resident population of 0.75% between 2015 and 2025. See Census Bureau website: <http://www.census.gov/population/projections/data/national/2012/summarytables.html>

<sup>25</sup> The darker shaded entries for the 2015 stock and 2016-2020 disposals are those supplied by DOD. The lighter shaded reflect adjusted values from the DOD material.

No information was provided for the years beyond 2020. For these years, it was assumed that the total construction would be similar to the previous five years, and that disposals would be somewhat smaller (owing the greater prevalence of new floor space--that built after 2000). The net increase of 30 million square feet over this period is reflected in the projected 2025 floor space of 2,240 million square feet.

Under these assumptions, these post-2015 additions would represent about 4.4 percent of the 2025 stock, as shown in the last column of Table B.2. Key entries from Table B.2 have been included in the last row of the preceding table, B.1. The DOD also reported floor area for 2012, based upon the Base Structure Report to be about 2,300 million square feet.

#### *Calibration to floor space reported to FEMP under the goal-setting process*

The values of floor space shown in Tables B.1 and B.2 are not based upon the magnitudes of floor space reported to FEMP under the energy intensity goal setting process. For purposes of projecting future floor area, the better and more transparent approach was deemed to employ the FRPP and Base Structure Report values. However, for purposes of guiding the development of future energy intensity goals, the most reasonable starting point is to adapt the floor space estimates that have been provided to FEMP.

It is assumed that the ratios of floor space reported to FEMP, as compared to floor space reported in other contexts (e.g., FRPP, and DOD Base Structure Report), will remain constant in the future. Thus, as a simple calibration procedure, a set of scaling factors was computed on the basis of the reported floor space for 2012. It should be noted that under this assumption, the fractions of 2016-2025 new floor space in the 2025 stock will be the same as those shown in the last column of Table B.1. However, for aggregations (across the civilian agencies) the calculated values may differ as the distribution of floor space by agency is different under the FEMP reporting as compared to the FRPP.

Table B.3 illustrates this calibration procedure and development of these scaling factors. The first column shows the 2012 floor space reported to GSA under the FRPP for the civilian agencies (domestic floor area only), the floor space reported to FEMP for the USPS, or the DOD floor space reported as part of the Base Structure Report. The next two columns show the floor space reported to FEMP for 2012, the first column showing only goal-subject floor space and the second column adding in the goal-excluded floor space.

The last two columns show the respective ratios of FEMP reported floor space to the floor space totals shown in column one. Scale-1 relates to goal-subject floor space and Scale-2 relates to the total floor space reported to FEMP. Clearly, the largest deviation from 1.0 in the last column is associated with GSA. Presumably, a large portion of leased space is not covered by the FEMP goal-setting process.<sup>26</sup>

---

<sup>26</sup> For the Veterans Administration (VA), the reason for larger amount of floor space reported to FEMP as compared to the FRPP was not investigated. The scope of VA floor space as reported under the FRPP differs from that used for reporting to FEMP.

**Table B.3.** Calibration of 2012 reported floor space to FEMP scope

	Total*	Reported to FEMP,		Scale-1	Scale-2
		Goal SF	All SF		
	(mill. sf)	(mill. sf)	(mill. sf)	(ratio)	(ratio)
Civilian (FRPP)	1,205	860	967		
Energy	117	101	117	0.868	1.003
GSA	417	177	208	0.424	0.499
Justice	71	70	70	0.982	0.982
VA	163	177	177	1.085	1.085
Agriculture	58	58	58	1.000	1.000
Home. Security	48	47	48	0.980	0.991
Interior	71	59	59	0.827	0.827
NASA	47	33	40	0.701	0.854
All Other	212	138	190	0.649	0.896
USPS (see Note)	273	273	273	1.000	1.000
Dept. of Defense	2,300	1,896	1,927	0.824	0.838

\*Reported to GSA under the FRPP, FEMP (for USPS), or derived from the DOD Base Structure Report

Table B.4 presents the results of applying this calibration to projected floor space and new construction to 2025. For purposes of extrapolating floor space from 2012 to 2015, the growth rates shown in column five of Table B.1 were used. The FEMP-calibrated floor spaces projections for both the goal-subject buildings and all buildings are shown in the first two columns of the table. The second pair of columns presents the floor space projections for 2025.

The last set of columns show the projected and calibrated amounts of new construction in the 2016-2025 period and what percentage of the 2025 stock that new construction represents. Because of the simple proportional calibration method, these percentages are the same for both goal-subject and total floor space, and both match the percentages in Table B.1. However, the percentages aggregated across all the civilian agencies (15.9% and 16.1%) differ from the percentage reported for the same aggregate in Table B.1 (16.6%). This difference stems from the different distribution of floor space and new construction, after calibration to the FEMP-reported values.

The highlighted entries in the last column of Table B.4 are the values that are used to measure the impact of new energy-efficient buildings on the 2025 energy intensity of the total floor space stock. From the assumptions used to project floor space stock, the impact of new buildings is projected to be much greater in the civilian sector (excluding USPS) than it will be for DOD. The much slower growth rates in the overall stock for the USPS and the DOD will minimize the influence of new, energy-efficient, buildings on the overall intensity change over the period up to 2025.



**Table B.4.** FEMP-calibrated floor space projections and new construction for goal-subject square footage and total square footage

	2015		2025		Cumulative Additions		Cumulative Additions	
	Goal SF	All SF	Goal SF	All SF	Goal Sq.Ft. (2016-2025)	% of 2025 Goal SF	Total Sq.Ft. (2016-2025)	% of 2025 Total SF
	Civilian (FRPP)	880	989	940	1,056	149.0	15.9%	169.7
Energy	102	118	106	122	16.1	15.3%	18.6	15.3%
GSA	181	213	196	231	36.2	18.5%	42.6	18.5%
Justice	72	72	78	78	8.9	11.4%	8.9	11.4%
VA	183	183	197	197	19.5	9.9%	19.5	9.9%
Agriculture	59	59	62	62	13.0	21.1%	13.0	21.1%
Home. Security	48	49	52	53	11.8	22.7%	12.0	22.7%
Interior	60	60	63	63	11.3	18.0%	11.3	18.0%
NASA	33	40	35	42	3.8	10.9%	4.6	10.9%
All Other	142	196	151	209	28.3	18.7%	39.1	18.7%
USPS	271	271	265	265	4.0	1.5%	4.0	1.5%
Dept. of Defense	1,804	1,833	1,847	1,877	81.0	4.4%	82.3	4.4%
All Federal	2,955	3,093	3,051	3,198	234.0	7.7%	256.0	8.0%
All Federal Civilian	1,151	1,260	1,205	1,321	153.0	12.7%	174	13.1%

## B.2. New Building Efficiency

This section discusses the methodology that was used to assess the reductions in EUI that would likely be related to new, more efficient federal buildings constructed over the period 2016-2025. For this element, the basic approach is to estimate the sources of the overall difference between the EUI in new buildings (built between 2016 and 2025) and the EUI that will reflect the 2015 stock.

The basic approach first involves an assessment of the various influences or sources that may affect the relative energy intensity of new versus existing buildings. These various sources are represented by the first four columns in Table B.2. The fundamental quantification of changes in the average EUI is based upon simulation analysis of prototypical buildings compliant with the American Society of Heating, Refrigerating, and Air-Conditioning Engineers (ASHRAE) Standard 90.1-2004 (ASHRAE 2004) and ASHRAE Standard 90.1-2010 (ASHRAE 2010).

**Table B.5.** Impact on 2025 stock EUI from new construction meeting federal standard based upon ASHRAE Standard 90.1-2010

		<i>Design</i>	<i>Design</i>	<i>As Built</i>	
	90.1-2004 relative to stock -- improvement (% Reduction)	90.1-2010 relative to 90.1- 2004 (% Reduction)	Federal Design over relevant standard (% Reduction)	Takeback from greater intensity, plug loads (% Increase)	Average EUI compared to 2015 Stock (% Reduction)
Low	5%	21%	5%	20%	11%
High	15%	26%	25%	10%	56%
Best Judgment	10%	24%	10%	15%	29%

The approach does not attempt to quantify absolute levels of energy intensity. While simulation studies do generate such estimates, a standard caveat in such studies is that the EUIs represent ideal operating conditions and assumed levels of electrical plug loads and typical operating schedules. For this analysis, it is sufficient to assume that changes in actual EUI's, from one energy standard to another, are approximately *proportional* to changes in simulated EUIs that conform to the building energy efficiency codes that reflect such standards.

The estimation process begins with an assumption as to how the energy intensity of buildings built to the 90.1-2004 standard compare to that of the existing stock as of 2015. As shown in column one of Table B.5, the “best judgment” estimate is that, on balance, federal buildings built to meet the 90.1-2004 standard are roughly 10% more energy efficient than the average stock of buildings with the further assumption of a roughly comparable mix of building types.

One way of rationalizing this assumption is to rely on a recent DOE-sponsored study that sought to quantify the overall energy intensity of “existing” buildings, as compared to “new” buildings. In early 2011, DOE issued a report entitled *U.S. Department of Energy Commercial Reference Building Models of the National Building Stock* (DOE 2011). This report was the result of a collaborative effort among three national laboratories: National Renewable Energy Laboratory, PNNL, and Lawrence Berkeley National Laboratory. The report sought to represent three broad vintages of nonresidential buildings: “new”, “post-1980”, and “pre-1980”. Different ASHRAE standards were used to characterize the energy-related features of the buildings in these vintages. As indicated in the report, “The new construction models comply with the minimum requirements of ANSI/ASHRAE/IESNA<sup>27</sup> Standard 90.1-2004 (ASHRAE 2004), the post-1980 models meet the minimum requirements of Standard 90.1-1989 (ASHRAE 1990), and the pre-1980 models are built to a set of requirements developed from previous standards and other studies of construction practices.” While the pre-1980 buildings are not assigned a specific ASHRAE standard, the lighting efficiencies were assumed to have been updated to be equivalent to the requirements under Standard 90.1-1989.

More recent work at PNNL has developed estimates of the overall changes in overall commercial intensity that are implied between 1989 ASHRAE standard and the 2004 standard. According to a pending PNNL report that has developed estimates of historical benefits of building energy codes, the overall reduction in the site energy intensity of newly constructed buildings meeting codes based on the ASHRAE Standard 90.1 is about 16 percent between 90.1-1989 and 90.1-2004.<sup>28</sup> The majority of this change—approximately a 13 percent change—is between the ASHRAE standard published in 1999 (90.1-1999) and that published in 2004. Thus, assuming that fewer buildings were built in the period 2000 (assumed to be earliest impact of the 1999 standard) as compared to the prior decade, the overall or average change in the energy intensity in all buildings built between 1989 and 2004 would be something less than 10 percent.

To the question of the current energy intensity of federal buildings prior to the 1989 standard, there is little empirical basis to develop quantitative estimates. According to the same PNNL report cited above, the change between the first edition of national building standards published by ASHRAE (Standard 90A-1975 [ASHRAE 1975] and 90A-1980 [ASHRAE 1980]) and Standard 90.1-1989 was in range of 15

---

<sup>27</sup> American National Standards Institute (ANSI) and Illuminating Engineering Society of North America (IESNA)

<sup>28</sup> Livingston, OV, PC Cole, DB Elliott, and R. Bartlett. 2013. “Building Energy Codes Program: National Benefits Assessment 1992-2040.” PNNL-22610 (pending).

percent. However, as noted above, the lighting efficacies these older buildings cited in the inter-laboratory report on reference buildings were assumed to have achieved a level equivalent to the 1989 standard. Moreover, it is these older building where one can presume that much of the effort of federal building energy managers have been targeted to achieve the intensity goals that are the subject of this report. Thus, it is clearly inappropriate to rely strictly on the estimated changes in the ASHRAE standards as a guide to the relative differences in energy intensity among different vintages of federally-constructed buildings.

Given these considerations, the basic judgment employed in this analysis was that the energy intensity of the current stock of federal buildings is approximately 10 percent higher than that implied by compliance with the ASHRAE Standard 90.1-2004. This value is shown in the third row of the first column of Table B.5. As also shown in the table, lower and upper bounds to this assumption are 5 percent and 15 percent.

### ***Change between ASHRAE Standard 90.1-2004 and Standard 90.1-2010***

The second step was to intuit the difference between Standard 90.1-2004 and Standard 90.1-2010. A quantitative estimate of this difference is based upon another recent PNNL report that focused on this same topic (Thornton et al. 2011). Using energy simulation analysis applied to 16 prototypical commercial buildings, this report estimated an overall reduction of about 23.2 percent in terms of site energy intensity and 25.6 percent in terms of a metric based on energy cost. “Overall” reduction is defined in terms of an estimated national distribution of all recent construction by building type. Also to be noted is that these reductions consider the impact of including process and plug loads as part of the building energy intensities.

One natural question is whether the composition of federal construction by building type is sufficiently different from the composition of privately-owned buildings as to significantly alter these calculated national average reductions. To explore this issue the percentage changes in energy intensities by specific prototypical building were reweighted to reflect the composition of federal buildings. Ideally, the composition of recently built federal buildings by floor area would be used in this reweighting. Unfortunately, such data are not available. As proxy, the distribution of overall floor area by building type at the end of FY 2012 was employed. The data for this distribution were based on a special tabulation of the FRPP database that was developed for FEMP.<sup>29</sup> Each of 19 separate building types from the FRPP was associated with a prototypical building used in the PNNL study.

For the reduction in energy intensity, site energy was used for each prototypical building. The reweighting based upon the composition of federal buildings turned out to make little difference to calculated change in the overall energy intensity. Using the building type weights associated with the 2012 federal stock yielded an average change of 24.6 percent, about a one percentage point change from the national average changes based upon composition of all (recently constructed) commercial buildings. For purpose of this analysis, this figure was rounded down to 24 percent.<sup>30</sup>

---

<sup>29</sup> Spreadsheets developed by GSA for FEMP and transmitted to PNNL via personal communication from FEMP’s Chris Tremper on May 10, 2013.

<sup>30</sup> The same calculation was also performed separately for the FY 2012 stock of civilian and military (Navy, Army, and Air Force) floor space with representing. Somewhat surprisingly, the calculated percentage reduction in intensity was somewhat greater for the military subset of federal buildings (25.1%), as compared to the total across

### ***Requirement to exceed the ASHRAE 90.1 Standard***

The third column in Table B.5 deals with the requirement that federal agencies design new buildings to significantly exceed the requirements of the ASHRAE Standard 90.1 in terms of energy efficiency. This requirement was first imposed in the 2005 Energy Policy Act (EPA 2005). This legislation calls for newly constructed federal buildings to achieve 30 percent energy savings relative to the most recently published ASHRAE Standard 90.1. The 30 percent target, however, is contingent on the additional energy efficiency design features to be cost effective.

This requirement became effective on January 3, 2007, as it applied to then prevailing ASHRAE Standard 90.1-2004. The baseline standard was updated to Standard 90.1-2007 starting August 10, 2012. According to the pending report on historical code benefits cited earlier, the overall reduction in energy intensity from 90.1-2007 was about 5 percent compared to Standard 90.1-2004.<sup>31</sup> FEMP has required agencies to indicate their success in achieving the 30 percent target reduction relative to Standard 90.1. From data supplied to FEMP on a building-by-building, many agencies reported that their designs of new buildings have been able to meet this requirement. However, there is no supporting documentation or empirical data that corroborates these declarations.

In July 2013, DOE issued an undated federal building efficiency standard based upon Standard 90.1. The provisions of EPA 2005 continue in place, thus continuing to require designs that achieve an additional 30 percent savings if cost effective. With energy standard for new federal building construction based on Standard 90.1-2010 going into effect on July 9, 2014, achieving this additional improvement, a full 30 percent, is going to be more challenging. Because there is as yet no experience with regard to compliance with this updated federal standard, this analysis has taken a conservative position. The average improvement beyond Standard 90.1-2010 is assumed to be 10 percent. However, it must be noted that there is considerable uncertainty related to this assumption, given that very few buildings (public or private) have been designed to achieve this implied level of energy efficiency. In Table B.5, the confidence bounds for this EPA-mandated requirement are deemed to be as low as 5 percent and as high as 25 percent in terms of the percentage reduction below Standard 90.1-2010.

---

all civilian agencies (23.9%). While the site intensity reduction provided in the PNNL study for high-rise residential buildings was lower than the “national average”, 12.3% vs. 25.6%, (assumed to apply to FRPP categories “family housing” and “dormitories”) and where the proportion of such buildings is higher in the military services as compared to the civilian stock, other factors offset this downward influence on the overall intensity reduction from these residential buildings. For example, the proportion of educational buildings in the military stock was greater than in the civilian stock, and estimated change in the energy intensity between 90.1-2004 and 90.1-2010 of these buildings was relatively high (36%). The overall conclusion is that the differences in the composition of buildings between the military and civilian sector in this case is not sufficiently high as to warrant independent analysis. However, a caveat is that these distributions are based on the current stock and not on any projected distribution of future federal construction in these two broad sectors.

<sup>31</sup> This discussion starts with ASHRAE Standard 90.1-2004 rather than Standard 90.1-2007 because the most detailed recent analyses of energy efficiency changes in various standards have employed 90.1-2004 as a key reference point. If, assuming the estimated 5% improvement between Standard 90.1-2004 and Standard 90.1-2007 were applied to Table B.5, the percentage reduction in the first column (“best judgment”) would change from 10% to 15%. Corresponding to this change would be a reduction in the improvement to subsequent move to a federal standard based on Standard 90.1-2010. Thus, the difference would be result in a revision from the current figure of 24% to 19% in the second column of the table. Overall, these changes would have no net impact on the overall influence of new buildings built to Standard 90.1-2010.

### ***Effect of Utilization and Occupancy in New Buildings***

The final factor considered in the analysis works in an opposing fashion to the previously discussed factors. There is strong reason to believe that new commercial buildings in general have greater energy intensity than the existing stock, a fact based simply on the notion that new buildings have higher utilization (e.g., hours of operation per week) and are more densely occupied. Moreover, it is reasonable to assume that plug loads and computer networks (including servers) are more prevalent in new buildings than in existing buildings.

With regard to utilization among all commercial buildings, the 2003 CBECS indicated that median weekly hours for buildings built after 1990 were about 8 percent greater than the median for all buildings.<sup>32</sup> From this same source, one finds that for buildings built between 1990 and 1999, the median occupant density was about 3 percent greater than the stock of all (non-mall) buildings.<sup>33</sup> Unfortunately, there are no separately published data on these metrics for federally-owned buildings, although any such values based upon the CBECS would likely be suspect owing to the small sample of federal buildings in the overall survey. The basic position in the study here is that there would be differences in utilization and occupant density in new federal buildings that would tend to increase their energy intensity relative to older federal buildings, a roughly similar situation as that observed in the entire building stock.

With regard to the intensity of plug loads and computer-related equipment, there are no available data that definitively point to the difference between the very newest buildings and the existing stock. The closest measure that might reflect this characteristic from the 2003 CBECS is the total floor space of *buildings* that contain a “separate computer area.” Across all (non-mall) commercial buildings the percentage of total floor space for buildings with such a dedicated area and built between 2000 and 2003 was about 45 percent. For all buildings (across all vintages), the corresponding average was 41 percent. Note that these values do not relate to the actual percentage of the total area devoted to computers, nor is there any indication of the relative energy intensiveness of the computer installations themselves. Nevertheless, the data are suggestive that computer-related electricity use is likely greater in newly constructed buildings, and there is no reason not to assume that this situation does not also pertain to federal buildings.

Taking into account these two considerations, the analysis here assumes that these factors might offset the increases in design efficiency by an average 15 percent. As shown in Table B.5, the uncertainty bounds for this value are set to restrict the range of this value to be between 10 percent and 20 percent.

### ***Impact of Future Increases in New Building Energy Efficiency***

The estimated impact on the 2025 stock EUI shown in Table B.5 is predicated on unchanging requirements for new federal building construction, those related to ASHRAE Standard 90.1-2010. As evident from the previous discussion, over the past decade ASHRAE has published new editions of Standard 90.1 on a consistent three-year cycle. Thus, over the next decade one may confidently predict

---

<sup>32</sup> Energy Information Administration, 2003 CBECS: Building Characteristics Tables: Table B.2. Summary Table: Totals and Medians of Floor space, Number of Workers, and Hours of Operation for Non-Mall Buildings. Downloaded from EIA CBECS website: <http://www.eia.gov/consumption/commercial/data/2003/pdf/b2.pdf>

<sup>33</sup> The median employment density for the most recently-constructed buildings in the 2003 CBECS (2000-2003) was lower than the median for all vintages, but this value presumably reflects the fact that the very newest buildings would have not yet achieved their design occupancy.

new standards to be published in 2013 (by December or before), 2016, 2019, and 2022. For purposes of this analysis, it was deemed too speculative to project increases in energy efficiency (manifest as reductions in overall EUI) for each of these code cycles. Moreover, there is no automatic assurance that these standards will be incorporated as the basis of the *federal building standard* on any type of fixed schedule. However, to ignore the likelihood for *some* increase in the stringency of the federal building standard over the next decade is unwarranted.

As a result, for this analysis, a single step increase in the federal building is posited and is assumed to have its major impact on buildings built after 2020. This increase can be roughly associated with the ASHRAE Standard that will be issued by the end of 2016. At minimum, it is assumed that this standard will become the baseline for the federal building standard by 2020.

Given this approach, the remaining question is what percentage reduction in overall EUI is reasonable to assume for 90.1-2016. One source of guidance for this projection may be derived from the (pending) PNNL report that developed estimates of historical and future benefits from DOE's buildings energy codes program.<sup>34</sup> Based upon both past experience of efficiency improvement in the standard and expert judgment as to the potential for (cost-effective) future improvement, this report suggests reductions of 7 percent over each of the Standard 90.1 (three-year) cycles over the next decade. Thus, this report would indicate a reduction of 14 percent in the overall EUI between the current Standard 90.1 and the Standard to be published in 2016.

Given this background, this analysis takes as a conservative estimate of future improvement a value of 10 percent to apply to the 2016 edition of ASHRAE Standard 90.1. This judgment seems warranted in light of the fact that the work to estimate the cost-effectiveness of proposed changes in the next (2013) 90.1 Standard is not yet available.<sup>35</sup>

Table B.6 illustrates the impact on the stock EUI if, *hypothetically*, a federal standard based on Standard 90.1-2016 were in force for the entire decade from 2016-2025. The only difference between this table and Table B.5 relates to the percentage changes from Standard 90.1-2004 to the relevant standard, as shown in column 2. To maintain simplicity, the 10 percentage point increment is added to figures in Table B.5. Thus, for the "best judgment" case, the 29 percent difference under the Standard 90.1-2010 scenario becomes a 39 percent difference for the Standard 90.1-2016 case.

---

<sup>34</sup> See preceding footnote 4.

<sup>35</sup> This activity is part of PNNL's support of DOE's code program. PNNL will develop cost-effectiveness analysis of proposed changes in the 90.1 Standards, to be presented to ASHRAE and DOE by the end of calendar 2013. When completed, this analysis will likely provide a more defensible basis for projecting additional stringency in 90.1 over the next several cycles.

**Table B.6.** Impact on 2025 stock EUI from new construction meeting federal standard based upon a hypothetical ASHRAE Standard 90.1-2016

		<i>Design</i>	<i>Design</i>	<i>As Built</i>	
	90.1-2004 relative to stock -- improvement	90.1-2016 relative to 90.1- 2004	Federal Design over relevant standard	Takeback from greater intensity, plug loads	Average EUI compared to 2015 Stock
	(% Reduction)	(% Reduction)	(% Reduction)	(% Increase)	(% Reduction)
Low	5%	25%	5%	20%	15%
High	15%	40%	25%	10%	70%
Best Judgment	10%	34%	10%	15%	39%

The final step involved estimating the impact that new building construction has on the average EUI of the 2025 federal building stock. First, the relative amount of floor space built under the two efficiency standards discussed above was established. It was assumed that half of the new floor space constructed between 2016 and 2025 is effectively built to meet the baseline ASHRAE Standard 90.1-2010 and the other half meets the more stringent ASHRAE Standard 90.1-2016. The average reduction in EUI is then assumed to be 34 percent (i.e., an average of values in the highlighted cells in the last columns of Table 10).

The average expected reduction in EUI was then applied to the 13.1 percent of all newly constructed floor space that civilian federal agencies were estimated to add to their building stock by 2015 (see “All Civilian” in

Table 9). The product of these two percentages (13.1% x 34%) yields a value of 4.5 percent. Over the 10-year period, this reduction translates into an annual average reduction of approximately 0.4 percent.

The same type of calculation was performed for the military sector and for the total of all federal buildings. As shown in Table 11, the smaller projected percentage of new construction for all military buildings (4.4%) yields a lower impact on the overall EUI, estimated to be 1.5 percent. For the combination of federal civilian and military categories, the new building impact is calculated to be 2.7 percent.

The highlighted values in Table 11 indicate best judgment point estimates. The second and third columns show the estimates of “high” and “low” values that reflect the informal uncertainty analysis pertaining to the underlying elements of EUI reductions for new buildings (as shown in the first two rows in Tables B.5 and B.6).

**Table B.19.** Impact of new building construction on the 2025 stock EUI, by sector

	2025 Impact on Stock EUI (%)		
	Best judgment	Low	High
All Civilian	4.5%	1.7%	8.3%
Military (DOD)	1.5%	0.6%	2.8%
All Federal	2.7%	1.0%	5.0%



## Appendix C. Data Sources to Estimate Recent Additions of Federal Floor Space

To assess the potential impact of new federal construction on the overall EUI of future floor stock maintained by the federal government, an effort was made estimate the amount floor space in recently constructed federal buildings. Several data sources were examined in this effort, as described briefly in the following sections.

### C.1 McGraw-Hill Construction—F.W. Dodge

Unfortunately, there are no publicly available data sources that report annual new floor space of commercial buildings and by ownership class (private, federal, state, local). Building project-level data from the F.W. Dodge group of McGraw-Hill Construction (MHC) covering nonresidential building projects over the period 2003 through 2010, have been used to support the development of nonresidential building energy codes. They provide a basis for allocating the amount of construction by geographic and climate zones across the U.S.

The project-level records available from Dodge show the type of building, value, floor space, type of owner (private + 3 classes of public buildings listed above), and location (at the county level). MHC/Dodge has collected this data for many decades; it is primarily used as a means of disseminating building specifications for proposed new buildings to facilitate the construction solicitation and bid process. The data pertain to the new building contracts and the timing of the data is based upon the award of such contracts, not on the subsequent construction activity or project completion. As such, the MHC/Dodge data differ as to their timing as compared to the construction estimates published by the U.S. Census Bureau. The Census Bureau attempts to estimate the actual amount of construction activity (measured in dollars) by month.

Table C.1 is based on aggregation of buildings shown as being built under federal ownership from the MHC/Dodge project-level data. The amount of construction activity funded by federal agencies and the branches of the military increased dramatically over the last years of the previous decade. The square footage associated with construction contracts more than doubled between the 2005-2006 period and the 2008-2009 period.<sup>36</sup>

Because MHC/Dodge only has a single category for all federally-owned buildings, there is no definitive way to discriminate between military and civilian construction. The numbers shown in Table C.1 for military are the sum of two building classifications by Dodge: 1) Armories/Military Buildings and 2) Dormitories. It is reasonable to expect that the majority of dormitories reported by MHC/Dodge pertain to military housing. In each year over the 2005-2009 interval, these two categories showed the two largest amounts of floor space. Moreover, it must be noted that these estimates likely understate actual military construction because some portion of offices, “food/beverage service” buildings, stores, and schools were also built on military bases.

---

<sup>36</sup> The 2010 data were transmitted to PNNL in a separate data file, and were not integrated into the analysis here. There is a question as to whether the level of 2010 federal construction may have been influenced by federal stimulus that was initiated in 2009.

**Table C.1.** New federal construction reported by MHC/Dodge, 2005-2009 (million square feet)

	All Federal	Military	Non-Military
2005	20.7	7.4	13.3
2006	20.9	10.2	10.7
2007	30.6	17.9	12.8
2008	43.7	22.8	20.9
2009	51.7	23.2	28.5

## C.2 Value Put in Place – Census Bureau

A second potential data source is the data collected by the Census Bureau on the value of new federal construction. The data published by the Census Bureau are estimates of the value (expenditures) on construction that are made in each time period. These estimates are developed on a monthly basis.

Table C.2 shows this data on an annual basis from 2002 through 2012.<sup>37</sup> The values shown are in millions of dollars and not adjusted for price change. This shows that the volume of federal construction, even after considering inflation increased substantially between the early years of the last decade and the most recent years.

**Table C.2.** Value of new federal construction put in place, 2002-2012 (millions of dollars)

Year	Total Federal Construction	Residential	Total Nonresidential	Non-buildings	Nonresidential Buildings	All Buildings
2002	16,578	1,510	15,068	5,314	9,754	11,264
2003	17,913	1,491	16,422	6,101	10,321	11,812
2004	18,342	1,398	16,944	6,115	10,829	12,227
2005	17,300	1,561	15,739	5,717	10,022	11,583
2006	17,555	1,734	15,821	6,022	9,799	11,533
2007	20,580	2,127	18,452	5,964	12,488	14,615
2008	23,731	2,595	21,136	6,813	14,323	16,918
2009	28,439	2,243	26,196	7,713	18,483	20,726
2010	31,133	2,717	28,416	9,231	19,185	21,902
2011	31,654	2,562	29,092	9,378	19,714	22,276
2012	27,367	1,584	25,783	8,010	17,773	19,357

The value put in place (VPI) data from the census are shown for a number of different types of construction, and include both building and non-building construction. To develop a rough estimate of building construction values, the following categories were subtracted from the Census Bureau's published total for nonresidential construction: 1) Transportation, 2) Power, 3) Highway and Street, and 4) Conservation and Development. The sum of these non-building categories is shown in the fifth column of Table C.2. After this adjustment, the remainder of the nonresidential construction value was added to the residential value, yielding the estimates shown in the last column of the table.

<sup>37</sup> These data were taken from the U.S. Census Bureau website, with selection of historical annual value put in place for the federal sector. The relevant website is [http://www.census.gov/construction/c30/historical\\_data.html](http://www.census.gov/construction/c30/historical_data.html), accessed on August 29, 2013.

### *Comparison with MHC/Dodge Data*

To assess whether the VPIP estimates can be used to make an approximate estimates of newly-constructed federal floor space, it is necessary to compare the VPIP numbers with those available from MHC/Dodge over a comparable time period. For this comparison it assumed that there is generally a one-year lag between the contract values reported by Dodge and the actual construction expenditures reflected in VPIP data. In part, this assumption is based on the generally larger types of building projects undertaken for the federal government as compared to private construction.

Using this assumption, the value of MHC/Dodge value of construction projects over the five-year period 2005 through 2009 was 36.0 billion dollars. From Table C.2, over the five-year period 2006 through 2010, total VPIP for federal construction activity was 85.7 billion dollars.

This difference suggests that a significant share of federal construction may not be included in the MHC/Dodge database. Projects in agencies that undertake construction by their employees or use alternative methods to disseminate requests for bids would not find their way into the Dodge database.

From other PNNL work to support the DOE's activities related to commercial building energy codes, it is known that the MHC/Dodge database does not cover all projects in the private sector as well. In developing its VPIP data for the private nonresidential construction in the U.S. the data from MHC/Dodge is adjusted up by 25 percent to account for under-coverage of projects.<sup>38</sup> Moreover, in terms of comparing value estimates, the MHC/Dodge data do not includes some important cost elements, including site preparation, architectural and engineering (A&E) fees, and other miscellaneous costs. To compare the VPIP and MHC/Dodge data for the *private* sector over the same (five) years as above, the equivalent calculations yield a total of 999.6 billion dollars for VPIP and 610.4 billion dollars for MHC/Dodge.

If the ratios between estimated for VPIP and the Dodge/MHC contract value are compared over the five-year periods, the calculated ratio is 1.64 for the private sector, and 2.37 for the federal sector. The difference in these two ratios is likely accounted for by both greater under-coverage of MHC/Dodge for federal sector projects and higher architectural and engineering costs that one could expect to be associated with federal projects. Unfortunately, there is no publicly available information to distinguish between these factors.<sup>39</sup>

A very rough method to adjust MHC/Dodge estimates is used to estimate recent floor space additions. Several key assumptions are required, however. This begins with the estimates for the private sector. Using the published factor of 1.25 to represent under-coverage by MHC, then a second factor to account for additional cost elements (e.g., Architectural and Engineering [A&E] fees) would be 1.31 (1.64/1.25). Next, it is assumed that the A&E costs for federal construction are, on average, twice as high as for

---

<sup>38</sup> See the methodology description on <http://www.census.gov/const/www/methodpage.html>.

<sup>39</sup> This situation was confirmed in a discussion with a Census Bureau staff member responsible for the federal VPIP estimates. As noted in the Census Bureau documentation, the volume of construction activity in the federal sector is less reliant on MHC/Dodge as in the private sector, and involves collecting information directly from many federal agencies. Thus, there is no constant adjustment factor (e.g., the 25% alluded to above) to account for under-coverage by MHC/Dodge. Due to confidentiality the Census Bureau is unable to release information that would identify the difference between MHC/Dodge data and the overall estimate of federal construction expenditure over any given time period. Source: personal communication with Rachel Hammond, Manufacturing and Construction Division, U.S. Bureau of the Census, June 13, 2013.

typical private nonresidential construction. With this assumption the approximate level of under-coverage for federal construction for this particular time period is backed out. That step involves dividing 1.62 (1 + 2 x 0.31) into the overall VPIP/(MHC) ratio of 2.37, which yields a value of about 1.5. Thus, on the basis of this highly simplified analysis, the MHC/Dodge value of construction represented about two-thirds of all federal construction over this period.

Before considering how to translate this result into an estimate of floor space in recently built federal buildings, one additional aspect of the VPIP data should be noted. The VPIP estimates include expenditures for both new buildings and renovations of existing buildings. According to the Census Bureau, no effort has ever been made to distinguish these two types of construction as part of the VPIP methodology.<sup>40</sup> The MHC/Dodge database does distinguish between these types of construction. However, for the analysis here, these two categories for federal expenditures were not broken out separately, helping to make the comparisons between the MHC/Dodge and VPIP data consistent in terms of scope.

### **C.3 Federal Real Property Profile Database**

The third potential source of information concerning floor space built and maintained by the federal government are data collected by the General Service Administration's Office of Government-wide Policy (GSA/OGP). Data on the number of buildings and structures and building square footage by agency have been published annually since 2002 in publication entitled the "Federal Real Property Report (FRPR),"<sup>41</sup> which are based on the FRPP database.

The FRPR includes a table of the number of disposed assets during the preceding fiscal year. However, as published, this table shows only the disposed assets rolled up across the entire federal government. Moreover, only the number of disposed building are shown, and not the associated floor space.

As part of a special request from the FEMP to GSA/OGP to support this project, two spreadsheets were prepared that showed total floor space by agency and the total amount disposed square footage for each fiscal year between 2006 and 2012.<sup>42</sup> The intent of this request was to determine if information on the amount of total floor space in different years, combined with disposals of floor space, could be used to estimate the amount of new floor space added over particular time intervals.

In order to smooth out year-to-year fluctuations in the amount of disposed floor area, the analysis focused on the beginning (2006) and ending years (2012) of the supplied FRPP data. If the data on dispositions and floor space stock were internally consistent, then the additions to floor space (new

---

<sup>40</sup> See previous footnote.

<sup>41</sup> All of these reports can be found on the GSA website: <http://www.gsa.gov/portal/content/102880>. The data prior to 2005 was collected somewhat differently than the more recent data, and so comparability across all categories of assets is not available. As of June 2013, the latest report included on this website is for FY 2010.

<sup>42</sup> These data were based upon special tabulations, summarized in two separate spreadsheets, prepared by the GSA for FEMP and transmitted to PNNL via personal communication from FEMP's Chris Tremper on May 10, 2013. The relevant file names are: 1) FRPP FY 2006 2011tremper non disposed by agency use legal interest.xlsx, and 2) FRPP FY 2006 2011tremper disposed by agency use legal interest.xlsx.

construction + newly leased space) between 2006 and 2012 could be estimated as the difference between the stocks in those years plus the disposed assets over the 2007 through 2012 period.<sup>43</sup>

Before examining the reported data in detail, it should be noted that the floor space numbers provided by GSA/OGP in this request do not include the amount of square footage outside U.S. states and territories. In the last available FRPR for fiscal year (FY) 2010, the total reported square footage was 3.402 billion. In the data provided for this analysis, the total square footage for FY 2010 was 2.922 billion. This difference is accounted for primarily by military facilities overseas, as well as State Department buildings.<sup>44</sup>

Table C.3 shows the results of the calculation procedure used to infer additions to floor space. The first two columns of the table show the total floor space by agency reported for 2006 and 2012. A perusal down these two columns indicates that there is not uniform reporting across all agencies in the FRPP. Nine agencies reporting square footage in 2012 did not report in 2006; however, the floor space represented by these agencies is relatively small.

The third column in the table shows the calculated amount of disposals summed over the fiscal years 2007 through 2012. The uneven pattern of disposals is reflected in the notes in right-most column of the tables. However, generally years in which no disposals are reported relate to the relatively small agencies, and so it would not be unexpected that no buildings would have been disposed in a single year or over a short period of consecutive years.

The last column shows the implied additions over this six-year period, based upon the reported stock and disposal values however caution should be applied in interpreting the implied additions from this procedure. For five agencies, the implied additions are negative, clearly indicating inconsistencies in the stock and disposal reporting over this period. This largest issue relates to the Navy where the reported disposals are not sufficient to explain the large decline in the reported stock between 2006 and 2012.

The bottom rows in the table provide some aggregations of agency data. For the uniformed services, the total of the implied additions is approximately 70 million square feet over this period. However, this value is clearly too low, as it includes the implausible results for the Navy (negative additions). The last two rows of the table attempt to develop an approximate estimate of new additions for the civilian agencies as whole. In the second-to-last row, the sum is calculated for agencies in which the disposal data was deemed to be credible (reporting all or most years, without significant gaps). Using this criterion, total additions are estimated to have been in about 86 million square feet between 2006 and 2012 (built in 2007 or later). The last column excludes agencies where the implied additions were negative. Using this additional criterion, the total increases to 96 million square feet (or about 16 million square feet per year).

In an effort to better understand some of the limitations of the FRPP data, particularly related to disposals, some questions were directed at the staff member at GSA charged with assembling the database.<sup>45</sup> Among other issues, it was learned that the disposal values can be distorted by short-term leases that are started and stopped within a fiscal year. A related issue in general is the treatment of the

---

<sup>43</sup> The 2006 disposals would have occurred prior to reporting of the stock at the end of FY 2006.

<sup>44</sup> The Department of State total shown in the 2010 FRPR was 74.1 million square feet, while the value reported via this special extract was 1.7 million square feet (presumably primarily covering agency buildings in Washington, D.C.).

<sup>45</sup> Personal communication, via conference call, with Chris Coneeny of GSA on May 30, 2013.

expiration of leased buildings. Finally, it was acknowledged that agencies may have applied different criteria over the years as how to classify active buildings as part of their stock.

With the notion that the reporting of both stock and disposals may have improved in the most recent years, another processing of the FRPP was undertaken to include only the most recent two years. Table C.3 shows the same information as Table C.2, but where the implied additions are estimated only for 2011 and 2012. In general, the numbers are more plausible. For only four agencies does the calculation of implied additions imply a negative value. With regard to disposals, those agencies not reporting any disposals are relatively small and thus reasonable to expect no disposals over a two-year period.

Unfortunately, as an aggregate estimate for the uniformed services, the implied additions cannot be used, as the implied additions for the Army is negative. The Army has provided detailed information on construction, and so reliance on the FRPP reporting is not necessary.

The last two rows of the table provide approximate estimates of the implied additions for 2011-2012 period for all civilian agencies. Similar to the discussion related to Table C.3, the estimate is performed by first including and then excluding agencies where the implied additions are negative. In the latter case, the results indicate that about 54 million square feet may have been added over this period. The implied annual average of 27 million square feet is more than 50 percent greater than the 2007-2012 estimate derived from Table C.3. This magnitude is likely influenced by some construction financed by the federal economic stimulus program, but is probably a more accurate representation than that yielded by the analysis of the 2006-2012 dataset. The longer data is more likely to be less consistent in reporting practices over time. Based upon the overall analysis, it appears reasonable to suggest that additions of new construction of federal civilian agency buildings have ranged between 20 and 30 million square feet in recent years.

**Table C.3. Building floor space by agency for 2006 and 2012 and implied additions**


Agency	Square Feet (Thousands)				Notes
	Reported	Reported	2007-2012	Implied	
	2006 Stock	2012 Stock	Disposed	Additions	
Agriculture Total	59,477	57,779	4,350	2,652	
Air Force Total	558,525	492,961	133,066	67,502	
Army Total	790,574	738,104	79,165	26,695	
Broadcasting Board of Governors Total	2	137			No disposals reported
Commerce Total	7,730	8,968	552	1,790	
Commodity Futures Trading Commission Total	0	435			No disposals reported
Corps of Engineers Total	15,108	11,878	795	-2,434	
Defense/WHS Total	7,751	8,269	77	595	Disposals only reported for 2012
DC Court Services & Offender Supervision Agency Total	0	348			No disposals reported
Energy Total	132,515	116,940	8,488	-7,087	
Environmental Protection Agency Total	3,993	4,356			No disposals reported
Federal Communications Commission Total	0	112			Only 1 small building disposed, ignored
General Services Administration Total	384,409	420,545	20,032	56,168	No disposals reported for 2008-2010
Health and Human Services Total	32,713	34,538	2,406	4,232	
Homeland Security Total	42,098	48,107	4,002	10,011	
Independent Government Offices Total	135	0			No disposals reported
Interior Total	110,939	105,865	4,369	-705	
John F. Kennedy Center for the Performing Arts Total	0	1,500			No disposals reported
Justice Total	68,379	71,424	716	3,760	
Labor Total	20,545	25,042	516	5,013	No disposals reported for 2007, 2009-2010
Merit Systems Protection Board Total	0	8			Only 1 small building disposed, ignored
National Aeronautics And Space Administration Total	44,298	46,779	1,594	4,075	
National Archives and Records Administration Total	4,475	5,292			No disposals reported
National Gallery of Art Total	0	1,420			No disposals reported
National Science Foundation Total	1,100	1,321	16	833	No disposals reported for 2007-2009
Navy Total	534,055	437,368	72,011	-24,676	
Office of Personnel Management Total	91	81			No disposals reported
Smithsonian Total	0	11,866	222		No disposals reported for 2007-2008, 2010-2011
State Total	1,257	1,748			No disposals reported
State (USAID) Total	4	4			No disposals reported
Tennessee Valley Authority Total	4,315	27,883			
Transportation Total	27,632	25,723	1,008	-901	No disposals reported for 2007-2010
Treasury Total	5,744	6,786	375	866	
United States Holocaust Memorial Council Total	0	320			No disposals reported
Veterans Affairs Total	150,275	162,702	2,473	14,900	
Grand Total	3,008,138	2,876,608	336,233	204,704	
Grand Total, as published (used for check)	3,008,138	2,876,608			
<b>Uniform Services</b>	1,883,153	1,668,432	284,242	69,521	Issue with negative implied additions for Navy
All other, reporting in both years	1,124,984	1,204,788			
All other, reporting in both years, with credible disposal data	1,045,955	1,083,342	49,601	86,988	
All other, reporting in both years, with credible disposal data, add. > 0	787,393	848,659	35,949	97,215	

**Table C.4. Building floor space by agency for 2011 and 2012 and implied additions**

Agency	Square Feet (Thousands)				Notes
	Reported 2010 Stock	Reported 2012 Stock	2011-2012 Disposed	Implied Additions	
Agriculture Total	58,531	57,779	2,468	1,716	
Air Force Total	499,635	492,961	37,336	30,661	
Army Total	775,596	738,104	24,444	-13,048	
Broadcasting Board of Governors Total	137	137			No disposals reported
Commerce Total	7,800	8,968	37	1,205	
Commodity Futures Trading Commission Total	412	435			No disposals reported
Corps of Engineers Total	9,751	11,878	86	2,214	
Defense/WHHS Total	8,081	8,269	77	266	Disposals reported only for 2012
DC Court Services & Offender Supervision Agency Total	232	348			No disposals reported
Energy Total	129,000	116,940	8,488	-3,572	
Environmental Protection Agency Total	4,293	4,356			No disposals reported
Federal Communications Commission Total	170	112	0.10		Only 1 small building disposed, ignored
General Services Administration Total	417,438	420,545	20,020	23,127	
Health and Human Services Total	36,083	34,538	966	-579	
Homeland Security Total	46,974	48,107	1,748	2,881	
Independent Government Offices Total					No disposals reported
Interior Total	102,995	105,865	2,548	5,419	
John F. Kennedy Center for the Performing Arts Total	1,500	1,500			No disposals reported
Justice Total	70,053	71,424	564	1,934	
Labor Total	24,942	25,042	448	548	
Merit Systems Protection Board Total	59	8			Only 1 small building disposed, ignored
National Aeronautics And Space Administration Total	45,572	46,779	749	1,955	
National Archives and Records Administration Total	5,270	5,292			No disposals reported
National Gallery of Art Total	1,425	1,420			No disposals reported
National Science Foundation Total	1,345	1,321	14	37	
Navy Total	447,609	437,368	12,863	2,622	
Office of Personnel Management Total	81	81			No disposals reported
Smithsonian Total	11,601	11,866	121		No disposals reported for 2011
State Total	1,660	1,748			No disposals reported
State (USAID) Total	4	4			No disposals reported
Tennessee Valley Authority Total	26,939	27,883			
Transportation Total	27,851	25,723	1,008	-1,120	
Treasury Total	6,128	6,786	318	406	
United States Holocaust Memorial Council Total	320	320			No disposals reported
Veterans Affairs Total	153,255	162,702	879	10,327	
Grand Total	2,922,743	2,876,608	115,184	69,050	
Grand Total, as published (used for check)	2,922,743	2,876,608			
<b>Uniform Services</b>	1,722,841	1,668,432	74,643	20,234	Issue with negative implied additions for Army
All other, reporting in both years	1,196,516	1,204,788	40,541	48,814	
All other, reporting in both years, with credible disposal data	1,196,516	1,204,788	40,541	48,814	
All other, reporting in both years, with credible disposal data, add. > 0	1,003,581	1,027,587	30,080	54,086	



## Appendix D. Heat Map of Fossil Energy Intensity based on eGRID 2012



Note: Darker shades represent more fossil-energy intensive regions.



**Pacific Northwest**  
NATIONAL LABORATORY

*Proudly Operated by **Battelle** Since 1965*

902 Battelle Boulevard  
P.O. Box 999  
Richland, WA 99352  
1-888-375-PNNL (7665)  
[www.pnnl.gov](http://www.pnnl.gov)



U.S. DEPARTMENT OF  
**ENERGY**