



# Illinois Distributed Generation Rebate Calculation Considerations

**June 2018**

AC Orrell  
JS Homer

DC Prezioso  
A Somani

## DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor Battelle Memorial Institute, nor any of their employees, makes **any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights.** Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof, or Battelle Memorial Institute. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

PACIFIC NORTHWEST NATIONAL LABORATORY

*operated by*

BATTELLE

*for the*

UNITED STATES DEPARTMENT OF ENERGY

*under Contract DE-AC05-76RL01830*

Printed in the United States of America

Available to DOE and DOE contractors from the  
Office of Scientific and Technical Information,  
P.O. Box 62, Oak Ridge, TN 37831-0062;  
ph: (865) 576-8401  
fax: (865) 576-5728  
email: [reports@adonis.osti.gov](mailto:reports@adonis.osti.gov)

Available to the public from the National Technical Information Service  
5301 Shawnee Rd., Alexandria, VA 22312  
ph: (800) 553-NTIS (6847)  
email: [orders@ntis.gov](mailto:orders@ntis.gov) <<http://www.ntis.gov/about/form.aspx>>  
Online ordering: <http://www.ntis.gov>



This document was printed on recycled paper.

(8/2010)

# **Illinois Distributed Generation Rebate Calculation Considerations**

June 2018

AC Orrell  
JS Homer

DC Prezioso  
A Somani

Prepared for  
the U.S. Department of Energy  
under Contract DE-AC05-76RL01830

Pacific Northwest National Laboratory  
Richland, Washington 99352



# Executive Summary

What is the value of distributed generation to the distribution system and how do we assign that value to a rebate? This white paper provides a preliminary look at potential distributed generation valuation methodologies and compensation options for Illinois, taking into consideration data needs and availability, as well as stakeholder input.

Pacific Northwest National Laboratory (PNNL) is supporting the Illinois Commerce Commission (ICC) with initial stakeholder engagement to advance the conversation around distributed generation valuation in Illinois. PNNL's educational support will help set the stage for a productive formal process as the ICC will be called upon, in potentially relatively short order, to start formal distributed generation valuation proceedings in response to Illinois Public Act 99-0906, also known as the Future Energy Jobs Act (FEJA), and codified in Illinois Public Utilities Act Section 16-107.6.

Stakeholder comments received thus far regarding Illinois' approach to distributed generation valuation hold the common themes of addressing issues unique to Illinois; having data transparency, privacy, and availability; creating a clear stakeholder engagement process; and the possibility of taking an incremental approach to the valuation. The primary point of disagreement revolve around the interpretation of the law relative to impacts beyond the distribution system.

Because the law says "the value of such rebates shall reflect the value of the distributed generation...", this white paper focuses specifically on the distributed generation value elements to the distribution system associated with distribution capacity, reduction in losses, ancillary services (including operating reserves and voltage support), and reliability and resiliency. However, because some of the language in the law leaves room for interpretation, it is important for the ICC and stakeholders to consider the legal interpretation of the law more carefully going forward.

Other states, such as California, New York, and Minnesota, provide examples of how to address data transparency and privacy issues, stakeholder engagement processes, valuation approaches, and the required data needs to accomplish a valuation. Based on a review of these states' approaches and stakeholder feedback, the datasets that will be needed to understand the geographic, time-based, and performance-based benefits of distributed generation in Illinois include the following:

- Load growth projections
- System capacity planning studies - from distribution transformer to bulk system sub-transmission
- Existing and projected distributed generation deployment and production by location
- Line loss studies
- System reliability studies (including voltages, protection, phase balancing)
- System-wide and location-specific cost information
- System-wide and location-specific peak demand growth rates
- Marginal cost of service studies.

As the ICC and stakeholders work together to develop a distributed generation rebate for Illinois, fundamental questions will need to be answered regarding the extent to which analysis methods will be standardized, datasets will be created, and investment plans, load and distributed generation projections, cost information, and analysis results will be made publicly available.



## **Acknowledgments**

The authors wish to acknowledge the contributions and valuable assistance provided by Cholly Smith, Jim Zolnierak, Torsten Clausen, Katharine McErlean, Victoria Crawford, and Terrance Garmon at the Illinois Commerce Commission. This work was made possible by funding from the U.S. Department of Energy Solar Energy Technology Office (SETO) as part of a program to provide analytical support to state public utility commissions. Special thanks to Michele Boyd, Elaine Ulrich, and Garrett Nilsen at SETO. Internal review and editing were provided by Dave Anderson and Heather Culley.





## Acronyms and Abbreviations

CPR	Clean Power Research
DDOR	Distribution Deferral Opportunity Report
DER	distributed energy resource
DOE	Department of Energy
DLS	distributed loss savings
DRV	demand reduction value
ELCC	effective load-carrying capacity
FEJA	Future Energy Jobs Act
FERC	Federal Energy Regulatory Commission
GNA	grid needs assessment
ICA	integration capacity analysis
ICC	Illinois Commerce Commission
IPA	Illinois Power Agency
LNBA	locational net benefits analysis
LSRV	locational system relief value
MCOS	marginal cost of service
NREL	National Renewable Energy Laboratory
O&M	operations and maintenance
PLR	peak load reduction
PNNL	Pacific Northwest National Laboratory
PUC	public utility commissions
PV	photovoltaics
REC	renewable energy certificate
RGGI	Regional Greenhouse Gas Initiative
RPS	renewable portfolio standard
RVOS	resource value of solar
SETO	Solar Energy Technology Office
VDER	value of distributed energy resource
VOS	value of solar



# Contents

Executive Summary .....	iii
Acknowledgments.....	v
Acronyms and Abbreviations .....	vii
1.0 Introduction .....	1
1.1 Report Scope .....	1
1.2 Report Purpose .....	1
1.3 Legal Basis and Language.....	1
1.3.1 Distributed Generation and Distributed Energy Resource .....	2
1.3.2 The Distribution System and the Grid.....	2
1.3.3 Smart Inverter.....	4
2.0 Stakeholder Comments .....	5
2.1 Issues Specific to Illinois.....	5
2.2 Data Transparency, Privacy, and Availability.....	5
2.3 Stakeholder Engagement Process.....	7
2.4 Incremental Approach .....	8
3.0 Valuation Components .....	9
3.1 Distribution System Value Components .....	10
3.1.1 Distribution Capacity Value.....	10
3.1.2 Reduction in Losses .....	12
3.1.3 Voltage Support, Operating Reserves, and Other Ancillary Services.....	13
3.1.4 Reliability and Resiliency .....	14
3.2 Non-Distribution System Value Elements of Distributed Generation .....	14
4.0 Example Approaches.....	16
4.1 Ameren Illinois Calculation Suggestions .....	16
4.2 California Locational Net Benefits Analysis.....	16
4.3 New York – Value of DER Tariff Calculation.....	17
4.4 Minnesota Example Calculation .....	17
5.0 Data Needs and Key Questions .....	19
6.0 Summary and Conclusions .....	21
7.0 References .....	22
Appendix A – New York VDER Tariff Calculation Example .....	25
Appendix B – Minnesota VOS Tariff Avoided Distribution Capacity Cost Calculation Methodology.....	26
Appendix C – Minnesota Valuation Components and Data Sources.....	29

## Figures

1	Average Monthly Value of Energy in California.....	15
2	Minnesota Distribution Capacity Value Calculation .....	18

## Tables

1	New York’s VDER Components.....	9
2	Distribution System Value Elements .....	10
3	Methods for Estimating Distributed Generation Capacity Value .....	11
4	Approaches for Estimating Impact of Distributed PV on Ancillary Services .....	14

# 1.0 Introduction

This white paper addresses the following questions: what is the value of distributed generation to the distribution system and how do we assign that value to a rebate?

## 1.1 Report Scope

Pacific Northwest National Laboratory (PNNL), along with Lawrence Berkeley National Laboratory and National Renewable Energy Laboratory, is collaborating with the U.S. Department of Energy's (DOE) Solar Energy Technology Office (SETO) to provide high-impact research and analysis for state public utility commissions (PUCs) on technical issues related to the integration of solar photovoltaics (PV) and other distributed energy resources (DERs) within the U.S. electricity system.

To that end, PNNL is supporting the Illinois Commerce Commission (ICC) with initial stakeholder engagement to advance the conversation around distributed generation valuation in Illinois. This assistance will lay the foundation for the ICC and Illinois stakeholders' understanding of the technical, financial, and policy implications of distributed generation deployment as outlined in Illinois Public Act 99-0906, also known as the Future Energy Jobs Act (FEJA), and codified in Illinois Public Utilities Act Section 16-107.6. PNNL's educational support will help set the stage for a productive formal process, as the ICC will be called upon, in potentially relatively short order, to start formal distributed generation valuation proceedings.

## 1.2 Report Purpose

This white paper provides a preliminary look at distributed generation valuation methodologies and compensation options for Illinois, taking into consideration data needs and availability, as well as input received at the March 1, 2018 stakeholder workshop and subsequent informal written comments.

This white paper may also be informative to other states and PUCs—one of the objectives of the SETO's analytical support program is to share research findings with stakeholders nationally.

## 1.3 Legal Basis and Language

This section cites key language from the Illinois Public Utilities Act relevant to the distributed generation rebate valuation.

Illinois Public Utilities Act Section 16-107.6 states the following:

*The investigation shall include diverse sets of stakeholders, calculations for valuing distributed energy resource benefits to the grid based on best practices, and assessments of present and future technological capabilities of distributed energy resources. The value of such rebates shall reflect the value of the distributed generation to the distribution system at the location at which it is interconnected, taking into account the geographic, time-based, and performance-based benefits, as well as technological capabilities and present and future grid needs.*

*Until the utility files its tariff or tariffs to place into effect the rebate values established by the Commission...The value of the rebate shall be \$250 per kilowatt of nameplate generating capacity, measured as nominal DC power output, of a non-residential customer's distributed generation.*

*The tariff shall also provide for additional uses of the smart inverter that shall be separately compensated and which may include, but are not limited to, voltage and VAR support, regulation, and other grid services.*

Illinois Public Utilities Act Section 16-107.5 states the following:

*After such time as the load of the electricity provider's net metering customers equals 5% of the total peak demand supplied by that electricity provider during the previous year, eligible customers that begin taking net metering shall only be eligible for netting of energy.*

*Upon approval of a rebate application submitted under this subsection (c), the retail customer shall no longer be entitled to receive any delivery service credits for the excess electricity generated by its facility and shall be subject to the provisions of subsection (n) of Section 16-107.5 of this Act.*

### **1.3.1 Distributed Generation and Distributed Energy Resource**

The language in Section 16-107.6 includes both the terms “distributed generation” and “DER,” but the terms are not interchangeable, as distributed generation is one type of DER.

Section 16-107.6 states that "distributed generation" shall satisfy the definition of distributed renewable energy generation device set forth in Section 1-10 of the Illinois Power Agency (IPA) Act. This IPA definition is summarized as a device that is powered by wind, solar thermal energy, PV cells or panels, biodiesel, crops and untreated and unadulterated organic waste biomass, tree waste, and hydropower that does not involve new construction or significant expansion of hydropower dams; is interconnected at the distribution system level; is located on the customer side of the customer's electric meter and is primarily used to offset that customer's electricity load; and is limited in nameplate capacity to less than or equal to 2,000 kilowatts (kW).

A DER, as noted in Ameren Illinois’ comments, “is a more widely used term that may better encompass the full breadth of technologies and applications that may be connected to the distribution grid...Ameren Illinois considers a broad definition of DER in which DER is defined to broadly encompass any generation, storage, or other load managing resource connected to the distribution grid” (Ameren 2018).

Because the law says “the value of such rebates shall reflect the value of the distributed generation...,” this white paper focuses on the costs and benefits of distributed generation specifically, but it is important for the ICC to consider the legal interpretation of the law more carefully going forward.

### **1.3.2 The Distribution System and the Grid**

The language in Section 16-107.6 also refers to both the distribution system and the grid.

#### **1.3.2.1 Broad vs. Narrow Interpretation**

Per Section 16-107.6, the rebate is intended for distributed generation, but there are some different, reasonable interpretations because of the varying language used in the law. As noted by Joint Solar Parties, “The statute both identifies a narrow set of values — ‘value of the distributed generation to the distribution system at the location where it is interconnected’ — and also a far broader set of values ‘benefits to the grid’” (Joint Solar Parties 2018).

### 1.3.2.2 Impacts Outside of the Distribution System

All parties acknowledged that DERs can provide additional benefits beyond those provided to the distribution network. These benefits could be to the environment, society, the larger grid system, and customers (Ameren 2018; ComEd 2018; ELPC et al. 2018; Illinois PIRG 2018; Joint Solar Parties 2018; REACT 2018). Some parties suggest that the distributed generation rebate should encompass these values (ELPC et al. 2018; Illinois PIRG 2018; Joint Solar Parties 2018), while some acknowledged that alternative compensation mechanisms could be utilized to recognize those other benefits (ComEd 2018; ELPC et al. 2018; Joint Solar Parties 2018). Some suggest that attempting to quantify the full range of benefits that DERs provide would guide the Commission in fairly compensating DER customers (ELPC et al. 2018). ComEd suggested renewable portfolio standards, wholesale energy and capacity markets, ancillary service markets, and tax incentives as potential alternative compensation mechanisms to capture the additional benefits (ComEd 2018), and other parties highlighted the need for further evolution of DER policy in order for this to occur (ELPC et al. 2018).

Other compensation mechanisms that already exist include the net metering energy credit and the purchase of renewable energy certificates (RECs) through the Adjustable Block Program, Illinois Solar for All Program, Community Renewable Generation Program, and other competitive REC procurement programs.

The REC pricing models for the Adjustable Block Program, Illinois Solar for All Program, and Community Renewable Generation Program, as established by the IPA, will establish REC prices as the difference between a system's expected, calculated cost of energy and the system's expected revenue from the net metering energy credit. REC prices in these programs will be adjusted for factors such as system size, the additional costs of small subscribers to community solar, and the additional costs to low-income consumers; these potentially will account for any changes to net metering compensation, the distributed generation rebate, and federal tax credits. (IPA 2017). As a result, the REC value is intended to bridge the gap between cost of energy and net metering revenue to ensure the distributed generation systems will be cost effective, thus encouraging customer adoption.

An alternate perspective, from Joint Solar Parties, considers the REC to represent the renewable portfolio standard (RPS) compliance value, but not all environmental or societal benefits. ComEd disagrees and suggests that purchasing RECs for RPS compliance is essentially compensating distributed generation for its environmental attributes. Either way, RECs are one example of a mechanism to compensate distributed generation beyond its direct impact to the distribution system.

### 1.3.2.3 Net Metering

Currently, most net metering customers in Illinois with excess generation sent back to the grid receive a net metering credit equivalent to the full retail rate. This full retail rate compensation reflects energy, delivery, and transmission costs.

Per Illinois Public Utilities Act Section 16-107.5, once the utility's 5% cap is reached and the new distributed generation rebate is in effect, *eligible customers that begin taking net metering shall only be eligible for netting of energy*; the credit will reflect the energy supply rate only. With the exception of some grandfathered residential net metering customers that elect to forgo distributed generation rebates, net metering customers will no longer receive any delivery service credits for the excess electricity generated by their facility. In addition, the ICC's Order in Docket No. 17-0350 concluded that the net metering credit for "electricity produced" should only include credit for the energy supplied (and should not compensate for other types of services, such as transmission service) (ICC 2017). Therefore, customers will also no longer receive a transmission credit as part of their net metering credit.

### **1.3.3 Smart Inverter**

While the IPA's Long-Term Renewable Resources Procurement Plan refers to the distributed generation rebate of Section 16-107.6 as a "smart inverter rebate," this characterization is imprecise. While it is true that the law says that new customers who enroll in net metering after June 1, 2017 are required to have a smart inverter to be eligible for the rebate, net metering customers who enrolled prior to that date are also eligible to apply for the rebate without having a smart inverter. Therefore, calling the rebate a smart inverter rebate is technically incorrect.

In addition, the presence of smart inverters significantly changes the impact of distributed generation on the need for or provision of ancillary services. Because some grandfathered net metering customers will still be eligible for a distributed generation rebate without a smart inverter, it is possible that the rebate value calculation will be different for systems with smart inverters and without smart inverters.



## **2.0 Stakeholder Comments**

The stakeholder comments revealed the common themes of addressing issues unique to Illinois; having data transparency, privacy, and availability; and creating a clear stakeholder engagement process, as well as the possibility of taking an incremental approach to the valuation. The primary point of disagreement revolves around the interpretation of the law relative to impacts beyond the distribution system, as discussed in Sections 1.3.2.1 and 1.3.2.2, respectively.

### **2.1 Issues Specific to Illinois**

The two key issues specific to Illinois that were expressed in stakeholder comments are that the valuation building blocks must consider the deregulated electricity market conditions in the state and that the compensation is to be in the form of an upfront rebate, rather than generation-based payments. As a result, some lessons learned from New York and California, which also have electricity choice markets, may be more relevant to Illinois than issues from Minnesota, which has a vertically-integrated utility structure. As noted by the Joint Solar Parties, the valuation methodology for Illinois does not have to differ significantly from other states' methodologies, but the rebate value should represent the levelized, life-cycle value of the distributed generation.

### **2.2 Data Transparency, Privacy, and Availability**

Data privacy, transparency, and accessibility are issues that need to be addressed in the valuation process. While there is a general need for transparency, communication, and collaboration, this must be balanced with protecting customers' privacy as well as business sensitive data. Developing hosting capacity analyses provides an example of how other states have dealt with data privacy. A hosting capacity analysis is used to establish a baseline of the maximum amount of DERs that an existing distribution grid (feeder through substation) can safely accommodate without requiring infrastructure upgrades (Homer et al. 2017). Understanding the current infrastructure's capabilities allows stakeholders to make informed decisions when considering generating energy on-site.

At least two stakeholders called for regularly updated hosting capacity analyses (ELPC et al. 2018; Illinois PIRG 2018) and noted that both New York and California put forth considerable effort to create reliable hosting capacity analyses early in their valuation processes.

There are typically two types of data needed to analyze hosting capacity—system data and customer consumption data (Trabish 2017). In New York, utilities maintain much of the information necessary for analyzing hosting capacity (NYPSC 2017a). They possess the most extensive understanding of, and access to, the data needed to analyze the locational benefits that DERs contribute to the distribution system. With this type of unilateral access, the need for transparency is important. Hosting capacity maps at the system level and the underlying data aid distributed energy providers in decision making (Trabish 2017).

New York utilities published hosting capacity analyses for solar PV in October 2017. The hosting capacity analyses evaluated distribution circuits greater than or equal to 12 kV and large PV systems at the feeder level (JU NY 2017). The publication of the analyses marks the second of four stages to create reliable hosting capacity analyses. Utilities used the Electric Power Research Institute's DRIVE tool and created their results in the geographic information system-based map environment for accessibility and transparency (JU NY 2017). Steps three and four in the process will expand and improve upon the results in stage two (JU NY 2016).

In order to maintain customer privacy, New York utilities proposed, and the New York Public Service Commission approved, a “15/15” privacy standard that would keep customer’s identities anonymous when reporting aggregated data sets (Homer et al. 2017). This standard would only permit a data set to be shared if it contains at least 15 customers, with no single customer representing more than 15% of the total load. In Docket No. 13-0506, the ICC approved a similar 15/15 rule when it decided on the electric utilities’ release of anonymous individual customer interval usage data in aggregated form (ICC 2014).

Capital investment plans, load forecasts, reliability statistics, and planned reliability and resiliency projects are available in New York’s Public Service Commission filings, and customer energy data are shared with customers and their authorized third parties through utility bills and online platforms. New York utilities recognize that an analysis service that makes data more granular and customized for developers and market participants could become a value-added service. This value-added service would be treated separately from basic data that is accessible at no charge (JU NY 2016).

In addition to a hosting capacity analysis, or integration capacity analysis (ICA) as it is referred to in California, California investor-owned utilities (IOUs) must file a grid needs assessment (GNA) and Distribution Deferral Opportunity Report (DDOR) each year. The objective of the annual GNA is to identify specific deficiencies of the distribution system, identify the cause of the deficiency, and form the basis for annual project lists of needed distribution system upgrades (CPUC 2018a). The DDOR separately addresses planned investments and candidate deferral opportunities (CPUC 2018b).

The California Public Utilities Commission is asking utilities to “share more data, at greater detail and at faster speeds, than utilities have ever had to provide before” (St. John 2015). Specifically, these reports and analyses are asking utilities to provide feeder-level conditions, such as ‘coincident and non-coincident peaks, capacity levels, outage data, real and reactive power profiles, impedances and transformer thermal and loading histories, and projected investment needs over the following 10 years’” (St. John 2015).

California IOUs are not expected to disclose distribution planning data that would breach customer privacy provisions or pose a threat to the security of the electrical system. However, the GNA and DDOR must fulfill specific parameters and both are required to be available in map form and as downloadable datasets. For the GNA, the following must be included relative to specific grid needs (CPUC 2018b):

1. *Substation, circuit, and/or facility ID: identify the location and system granularity of grid need*
2. *Distribution service required: capacity, reactive power, voltage, reliability, resiliency, etc.*
3. *Anticipated season or date by which distribution upgrade must be installed*
4. *Existing facility/equipment rating: MW, kVA, or other*
5. *Forecasted percentage deficiency above the existing facility/equipment rating over five years.*

In the DDOR, planned investments should be classified by:

1. *Project description*
2. *Substation*
3. *Circuit*
4. *Deficiency (MW/kVA, %)*
5. *Project type: Type of equipment to be installed*
6. *Project description: Additional identifying information*
7. *Distribution service required: capacity, reactive power, voltage, reliability, resiliency, etc.*

8. *In-Service Date*
9. *Deferrable by DERs, Y/N?*
10. *Estimated locational net benefits analysis (LNBA)<sup>1</sup> range.*

Candidate deferral projects will be identified by:

1. *General geographic region of deferral opportunity, where appropriate, and/or specific location, (e.g., substation, circuit, and/or facility ID)*
2. *In-service date*
3. *Distribution service required*
4. *Expected performance and operational requirements (e.g., season needed, day(s) needed, range of expected exceedances/year, expected duration of exceedances)*
5. *Expected magnitude of service provision (MW/kVA)*
6. *Estimated LNBA range*
7. *Unit cost of traditional mitigation.*

As of February 2018, California IOUs are required to develop a Distribution Resources Planning Data Access Portal that will include the ICA, GNA, DDOR, and LNBA on a circuit map. The underlying data will be exportable in tabular form, and the portal will include an Application Programming Interface to allow users to access data in a functional format from back-end servers in bulk (CPUC 2018b). The utilities' plans for implementing these portals were due to the California Public Utilities Commission in mid-May.

In Minnesota, utilities who want to move forward with the Value of Solar (VOS) tariff must develop a utility-specific VOS input assumptions table as part of their application, and that table is made public. Additionally, a utility-specific VOS output calculation table that breaks out individual components and calculates total levelized value must also be developed and made public (Cory 2014).

## 2.3 Stakeholder Engagement Process

In the comments provided after the March 1, 2018 workshop, a couple of parties suggested establishing stakeholder working group(s) to determine the rebate valuation methodologies and calculations (Joint Solar Parties 2018; ELPC et al. 2018), similar to what other states have done.

Using a working group format could establish some common ground among stakeholders, and therefore minimize the number of contested issues brought before the ICC during formal proceedings (ELPC et al. 2018). The comments also noted that the working group should have a formal mandate and timeline (Joint Solar Parties 2018), and possibly a budget to employ third-party consultants (ELPC 2018), similar to what California, Minnesota, and Oregon have done.

Working group examples in California include Smart Inverter, LNBA, and Integration Capacity Analysis. The Smart Inverter working group focuses on the development of advanced inverter functionality as an

---

<sup>1</sup> A locational net benefits analysis systematically analyzes the costs and benefits of DERs from a locational perspective. The value of DERs on the distribution system may be associated with a distribution substation, an individual feeder, a section of a feeder, or a combination of these components (Homer et al. 2017). See Section 4.2 for more about the LNBA approach in California.

important strategy to mitigate the impact of high penetrations of DERs (CPUC 2018c). The LNBA and Integration Capacity Analysis working groups are managed by IOUs and facilitated by More Than Smart (DRPWG 2018), a non-profit whose mission is to pursue “cleaner, more reliable, and more affordable electricity service through the integration of DERs into electricity grids” (More Than Smart 2017). The LNBA and ICA working groups were organized with two primary purposes in mind. In the short term, each group was tasked with supporting the utilities with required demonstration projects, specifically reviewing project plans and monitoring and supporting implementation. In the longer-term, the ICA and LNBA working groups were tasked with helping to refine the ICA and LNBA methodologies, respectively (More than Smart 2016).

For stakeholder engagement in New York, the Joint Utilities of New York<sup>2</sup> had a 15-organization advisory group and nine implementation teams that addressed customer data, DERs and non-wires alternatives suitability, electric vehicle supply equipment, system data, monitoring and control, NYISO/distributed system platform, hosting capacity, load/DERs forecasting, and interconnection. The goals of the stakeholder engagement process were to inform stakeholders of implementation progress, solicit feedback on implementation progress, achieve alignment for moving forward, and incorporate stakeholder input into implementation plans as applicable (Homer et al. 2018).

The stakeholder process conducted in Minnesota was mentioned in stakeholder comments as a potential model for Illinois (ELPC et al. 2018). The Minnesota Department of Commerce selected a third-party consulting firm, Clean Power Research (CPR), to support the process of developing a valuation methodology. Stakeholders participated in four public workshops facilitated by the Department of Commerce and provided comments through workshop panels, workshop Q&A sessions, and written comments (CPR 2014). Stakeholders included Minnesota utilities, local and national solar and environmental organizations, local solar manufacturers and installers, and private parties (CPR 2014).

## **2.4 Incremental Approach**

New York and California had an evolutionary approach to their valuation process, and the Joint Solar Parties suggested an incremental process may be appropriate for Illinois as well. Joint Solar Parties advised that a “first-generation” valuation model that can be deployed by the threshold date may be necessary (Joint Solar Parties 2018). Other stakeholders also noted a gradual implementation with interim steps could help prevent market uncertainty (ELPC et al. 2018) and a valuation model that allows utilities to adjust to changing circumstances should be considered (ComEd 2018). Keeping Illinois’ particular market and policy goals in perspective throughout the process will be essential.

---

<sup>2</sup> The Joint Utilities are comprised of Central Hudson Gas and Electric Corporation, Consolidated Edison Company of New York, Inc. (“Con Edison”), New York State Electric & Gas Corporation, Niagara Mohawk Power Corporation doing business as National Grid (“National Grid”), Orange and Rockland Utilities, Inc., and Rochester Gas and Electric Corporation.

### 3.0 Valuation Components

As presented in PNNL's *Distributed Generation Valuation and Compensation White Paper* (Orrell et al. 2018), the first step in typical value of distributed generation calculations is to survey the different value components, and their associated costs and benefits, that could be used as the valuation building blocks. States include different elements in their calculations based on state-specific policy goals or legislation.

New York's value of distributed energy resources (VDER) tariff components are presented in Table 1 as an example of a comprehensive list of valuation components (beyond just value to the distribution system) with details on how the calculations are accomplished. New York's demand reduction value (DRV) and locational system relief value (LSRV) are unique when compared to the Minnesota VOS tariff, and represent one aspect of direct value to the distribution system.

**Table 1.** New York's VDER Components (NYPSC 2017b)

Component	Calculation Based On
Energy value	Day-ahead hourly locational based marginal price grossed up for losses (eventually moving to subzonal prices)
Capacity value – market value	Monthly NY Independent System Operator auction price
Capacity value – out of market value	The difference between the market value and the total generating capacity payments made to value stack customers
Environmental value – market value	Higher of Tier 1 renewable energy certificate (REC) price per kWh, or social cost of carbon per kWh less Regional Greenhouse Gas Initiative (RGGI); customers who want to retain RECs will not receive compensation
Environmental value – out of market value	Difference between compensation and market will be recovered from customers within the same service class as the customers receiving benefits from the DER
Demand reduction value	Compensation based on marginal cost of service studies and eligible DER performance during 10 highest usage hours at \$ per kW-year value
Locational system relief value	Compensation based on marginal cost of service studies and static rate per kW-year value applied to net injected kW
Market transition credit	Static rate per kWh applied to net injected kWh; steps down by tranche

A National Renewable Energy Laboratory (NREL) report, *Methods for Analyzing the Benefits and Costs of Distributed Photovoltaic Generation to the U.S. Electricity Utility System*, classifies the sources of distributed solar benefits and costs in a more traditional way that includes the following (Denholm et al. 2014):

- Energy
- Environmental
- Transmission and distribution (T&D) losses
- Generation capacity

- T&D capacity
- Ancillary services
- Other factors.

### 3.1 Distribution System Value Components

With respect to costs and benefits specific to the distribution grid, Table 2 lays out the common value elements identified for Illinois in the stakeholder comments resulting from the initial white paper and the workshop on distributed generation valuation and compensation. In general terms, these are presented in relative order of value from left to right.

**Table 2.** Distribution System Value Elements

Commentator	Value Element				
	Avoided Distribution Capacity Costs	Reduction in Distribution Losses	Distribution Voltage Support	Reliability and Resiliency	Standby Capacity
Ameren Illinois	X	X	X		
ComEd	X		X	X	X
Joint Solar Parties	X		X	X	

Each of these distribution system value elements are described in more detail below

#### 3.1.1 Distribution Capacity Value

The distribution capacity value resulting from the addition of distributed generation represents the net change in distribution infrastructure requirements (RMI 2013). The presence of distributed generation may increase or decrease distribution system investments needed to meet system needs and keep the system running safely and reliably (Denholm et al. 2014). In certain instances, distributed generation can help to meet rising demand locally, relieving capacity constraints and avoiding upgrades. In other circumstances, added costs are incurred when additional distribution investments are necessary to upgrade wires, transformers, voltage-regulating devices, control systems, and/or protection equipment (RMI 2013; Denholm et al. 2014). There can be significant variations in the value of distributed generation from one location to another.

The value of deferring or avoiding distribution investments is a function of “load growth, distributed generation configuration and energy production, peak coincidence, and effective capacity” (RMI 2013). Calculating distribution system capacity value requires comparing expected capital investments or expansion costs with distributed generation and without distributed generation. Power flow analysis is typically the basis of this type of analysis.

In other value of distributed generation related dockets around the country, there is disagreement as to whether system-wide average avoided distribution attributable costs should be used or whether location-specific investments should be considered. In other proceedings, there has also been disagreement about whether only growth-related distribution investments should be considered, or all potentially deferrable distribution system investments (OPUC 2017).

To assess locational aspects of distributed capacity deferral, granular planning information is needed. A first step in this regard is for utilities to compile capital expenditure plans in each geographic area and

then assess what may be deferred or avoided due to distributed generation in those areas. In the absence of specific values, marginal cost of service (MCOS) studies provide a reasonable basis for calculating avoided distribution capacity value. MCOS quantifies the marginal cost of electricity service by calculating the additional costs associated with changes in kilowatt-hours of energy, kilowatts of demand, and number of customers. Using MCOS studies, the value of an avoided distribution asset can be estimated to be the cost of sub-transmission costs plus substation costs, in dollars per kW-year.

NREL summarizes a number of methods that can be used to approximate the capacity value of distributed generation (Denholm et al. 2014). Six different potential methods are summarized in Table 3 in increasing order of detail and complexity.

**Table 3.** Methods for Estimating Distributed Generation Capacity Value (Denholm et al. 2014)

Name	Description	Tools Required
1. PV capacity limited to current hosting capacity	Assumes DGPV does not impact distribution capacity investments at small penetrations, consistent with current hosting capacity analyses that require no changes to the existing grid	None
2. Average deferred investment for peak reduction	Estimates amount of capital investment deferred by DGPV reduction of peak load based on average distribution investment costs	Spreadsheet
3. Marginal analysis based on curve-fits	Estimates capital value and costs based on non-linear curve-fits, requires results from one of the more complex approaches below	Current: Data not available Future: Spreadsheet
4. Least-cost adaptation for higher PV penetration	Compares a fixed set of design options for each feeder and PV scenario	Distribution power flow model with prescribed options
5. Deferred expansion value	Estimates value based on the ability of DGPV to reduce net load growth and defer upgrade investments	Distribution power flow models combined with growth projections and economic analysis
6. Automated distribution scenario planning (ADSP)	Optimizes distribution expansion using detailed power flow and reliability models as sub-models to compute operations costs	Current: No tools for U.S. system. Only utility/system-specific tools and academic research publications on optimization of small-scale distribution systems. In practice, distribution planning uses manual/engineering analysis Future: Run ADSP 2+ times with and without solar

The most basic way to consider distribution system capacity value (item 1 in Table 3 above) is to assume that at very low levels of distributed generation, where total distributed generation is less than the hosting capacity of a circuit, there is minimal impact (positive or negative) on distribution capacity investments. This is consistent with the definition of hosting capacity as the amount of distributed generation that can be integrated into the system without changes to capacity or operations. In these cases, it can reasonably be assumed that the distribution capacity value is zero. It is important to note that this approach only

applies at very low penetration rates of distributed generation and it does not capture potential costs or benefits from peak reduction (Denholm et al. 2014).

The second method described in Table 3 approximates the value of deferred distribution system investments for reducing peak demand. A key assumption is that a fraction of distribution capital investments is used to address load growth. Costs reported to Federal Energy Regulatory Commission (FERC) on Form 1 (accounts 360-368) cover categories of costs that each include a fraction used for load growth. Summing load growth costs in each FERC cost category allows for the calculation of average capital costs per kilowatt. From here, the peak reduction from distributed generation can be translated into a capacity value (Denholm et al. 2014). The Minnesota VOS example in Section 4.4 is an example of this method for estimating distribution capacity value. There are various methods for calculating the peak reduction attributable to distributed generation, including capacity factor approximation using net load, capacity factor approximation using loss of load probability, effective load-carrying capacity (ELCC) approximation, and full ELCC (Denholm et al. 2014).

Methods 3 through 6 in Table 3 increase in level of detail and complexity, and in each case the type of analysis is novel and/or still in the research and development phase. Method 3 entails conducting in depth studies of a large representative set of distribution feeders (using one of Methods 4–6 described below) and then creating curve fits that estimate the marginal benefits and costs based on feeder and PV system characteristics. This type of analysis has been conducted in research settings, but to the best of our knowledge, not yet in commercial applications. Method 4 entails looking at the least-cost ways to provide mitigation when distributed generation interconnection exceeds feeder hosting capacity. Rather than upgrading transformers or conductors or adding voltage regulators, the least-cost adaptation option considers enabling or requiring smart inverter functionality in addition to or in lieu of other mitigations for each feeder and PV scenario. Method 5 entails computing the feeder-specific value of deferred distribution investments when distributed generation offsets load growth. The difference between this and Method 2 is that rather than using aggregate data, this is a bottom up approach where load and distributed generation growth for all feeders or a representative sample are calculated along with the corresponding avoided costs (Denholm et al. 2014). Method 5 is similar to California’s LNBA approach and New York’s LSRV approach.

Finally, Method 6 from Table 3 proposes using computer models to directly calculate multi-year capital investments needed to accommodate growth and other load changes, such as an increase in electric vehicles. The net present value of a no distributed generation baseline would be compared to scenarios with distributed generation to estimate the distribution capacity value. This analysis includes the use of detailed power flow and reliability models to compute operations costs. There are presently no comprehensive and automated tools available to conduct this type of analysis for systems in the United States (Denholm et al. 2014).

Until such time that detailed and automated models to automatically calculate distribution capacity value of distributed generation become available, it is recommended that a reasonable approximation method be used to estimate distribution capacity value. Examples from other states are provided in Section 4.0.

### **3.1.2 Reduction in Losses**

Because distributed generation is typically located near loads, it can result in avoided distribution losses. In some studies, such as the Minnesota VOS study, losses are included in avoided capacity cost calculations. At very high penetrations, however, where there is reverse power flow, distributed generation can result in increased losses. There are different methods for computing loss rates in distributed generation studies. The most basic approach is to assume that distributed generation avoids an



average distribution loss rate. Increasing in complexity, the average loss rate can be modified with a non-linear curve fit representing marginal loss rate as a function of time. Increasing in complexity further, the marginal loss rates at various locations in the system can be computed using curve fits and measured data. Finally, loss rates can be calculated using power flow models and a detailed time series analysis (Denholm et al. 2014).

PNNL conducted a study for Duke Energy to simulate the effects of high-PV penetration rates and to initiate the process of quantifying the generation, transmission, and distribution impacts. In the model simulations, both real and reactive losses on the distribution feeders decreased during higher load periods, typically in the summer. During lower load periods, both real and reactive losses tended to increase. On average, feeders show a reduction in losses due to the addition of solar distributed generation, particularly in the summer season. The study concluded that any net benefit is dependent on feeder topology, PV penetration level, and interconnection point, and should be evaluated on a case-by-case basis before assigning associated costs or benefits (Lu et al. 2014).

### **3.1.3 Voltage Support, Operating Reserves, and Other Ancillary Services**

Ancillary services, also referred to as grid support services, are those services required to enable the grid to operate reliably and typically include operating reserves, reactive supply and voltage control, frequency regulation, energy imbalance, and scheduling (RMI 2013). The two ancillary services that are most commonly associated with distributed generation are voltage control and operating reserves.

Voltage levels must be kept within acceptable values at all locations in the distribution system. Without advanced inverters, large distributed generation power injections can contribute to overvoltage conditions that may require new voltage-regulating equipment or controllers. Variable distributed generation power production can also lead to increased wear and tear on switches and voltage-control equipment. However, distributed generation with smart inverters can actively support voltage regulation on the distribution system and mitigate distributed generation-produced voltage issues, reducing the mechanical wear on transformer tap changers and capacitor switches and conceivably replacing traditional voltage-control equipment (Denholm et al. 2014). When reactive power is provided by smart inverters, it reduces the amount of reactive power that is required from large central generators, allowing them to operate at more efficient (real) power output levels, reducing transmission losses and increasing the (real) power capacity of transmission lines (Denholm et al. 2014).

Operating reserves address short-term variability and plant outages. Although they are traditionally required at the transmission level and provided by traditional generators, some types of operating reserves can also be provided by distributed resources. Operating reserves are often estimated by assessing the reliable capacity that can be counted on from distributed generation when needed over the year. The higher the reliable capacity of distributed generation that is available when needed, the less operating reserves are necessary. Where wholesale markets exist, the value of ancillary services can be determined based on the market prices. While variability and uncertainty from large amounts of distributed generation may introduce operations forecast error and increase the need for certain types of reserves, distributed generation may also reduce the load that must be served by central generation and reduce the needed reserves (RMI 2013).

Denholm et al. (2014) proposed three different approaches to estimating the impact of distributed generation solar PV on ancillary services value (see Table 4). The first approach is to assume no impact due to the penetration of PV being too small to have a quantifiable impact and/or due to the fact that PV's impact on ancillary services is poorly understood. Table 4 also lists a simple cost-based method and a detailed cost-based method for estimating impacts of distributed generation on ancillary services value.

The simple method estimates changes in ancillary service requirements (such as reduced spinning reserve requirement as a result of reduction in net load) and applies cost estimates or market prices for corresponding services. The detailed method includes running simulations with increasing distributed generation and calculating the impacts on reserve requirements and ancillary services provided by the distributed generation.

**Table 4.** Approaches for Estimating Impact of Distributed PV on Ancillary Services (Denholm et al. 2014)

Name	Description	Tools Required
1. Assumes no impact	Assumes PV penetration is too small to have a quantifiable impact	None
2. Simple cost-based methods	Estimates change in ancillary service requirements and applies cost estimates or market prices for corresponding services	None
3. Detailed cost-benefit analysis	Performs system simulations with added solar and calculates the impact of added reserves requirements; considers the impact of DGPV providing ancillary services	Multiple tools for transmission- and distribution-level simulations, possibly including PCM, AC power flow, and distribution power flow tools


### 3.1.4 Reliability and Resiliency

In the Oregon Resource Value of Solar (RVOS) docket, security, reliability, and resiliency were originally included as a separate category in the RVOS calculation. However, following parties' comments, the Commission decided to fold reliability, security, and resiliency into a new category, simply named grid services. The consulting firm Energy and Environmental Economics, Inc. (E3) who provided comments in the Oregon RVOS docket, said that solar generators "with advanced and uncommon infrastructure such as microgrids are capable of islanding during an outage event, but this benefit accrues to the owner and not to the general utility ratepayers" (OPUC 2017). E3 recommends that security and reliability benefits should not be valued in Oregon's RVOS calculation because "reserve" benefits are already accounted for as part of ancillary services. Likewise, Denholm et al. (2014) addresses reliability in terms of distribution and transmission capacity investments, but not as a separate value category.

## 3.2 Non-Distribution System Value Elements of Distributed Generation

The value distributed generation provides to the distribution system is only one part of the overall value proposition of distributed generation to the electric system. Figure 1 shows the average monthly value of energy (\$/MWh) from an avoided cost perspective in California. These values were computed from an E3-developed avoided cost calculator that all the large IOUs in California are obligated to use. The figure shows that, in California, potentially avoided distribution costs are greater in the summer than in other months. Figure 1 also shows that the distribution system portion of the overall value proposition is relatively small. The language in the Illinois law arguably leaves room for interpretation as to what the distributed generation rebate should ultimately include. The rebate calculation will vary significantly based on whether it represents the distribution system value alone or other value components. How the

rebate interacts with REC pricing and ultimately what is valued in the REC pricing are also of importance as this work proceeds.



**Figure 1.** Average Monthly Value of Energy in California (E3 2017)

Distributed generation value elements other than distribution system impacts are not addressed in detail in this report. However, if detailed value calculations for other categories of impacts are desired going forward, Denholm et al. 2014 offers an excellent detailed summary of approaches ranging from simple to complex for calculating benefits and costs associated with energy, environment, transmission losses, generation capacity, transmission capacity, and ancillary services resulting from distributed PV systems (Denholm et al. 2014). California, New York, and Minnesota also provide good examples of calculations for value elements beyond impacts to the distribution system.

## 4.0 Example Approaches

This section provides specific calculation approach recommendations and examples that are applicable to Illinois.

### 4.1 Ameren Illinois Calculation Suggestions

To calculate the value of the distribution system elements Ameren identified, Ameren suggested the following process (Ameren 2018):

1. *System capacity studies starting at the smallest distribution system asset level (distribution line transformer) then aggregate results upstream towards the bulk supply sub-transmission power transformer. These studies could compare baseline system capacity (current state of the distribution system) against cases of distributed generation penetration at specific locations on the distribution system.*
2. *System line loss study comparing baseline (current state of the distribution system) against cases with distributed generation penetration at specific locations of the distribution system.*
3. *System reliability studies including voltage, protection and phase balance comparing baseline (current state of the distribution system) against cases with distributed generation penetration at specific locations of the distribution system.*
4. *Using the above results, an economic analysis could be used to determine the value of distributed generation at the specified location on the distribution system.*

This process would require accurate distribution system models down to the distribution line transformer level for conducting system capacity, line loss, and reliability studies; identifying the specific distributed generation scenarios to model; and obtaining cost information. There are distinct similarities between this proposed approach and the Minnesota example described in Section 4.4. Both methods call for an evaluation of differences in distribution system capacity and line losses between a “business as usual” case and a distributed generation development case; both methodologies allow for the potential to identify and evaluate impacts at a local level as well as at an aggregate level.

### 4.2 California Locational Net Benefits Analysis

The three large IOUs in California (Pacific Gas & Electric, San Diego Gas & Electric, and Southern California Edison) jointly engaged the consulting firm E3 to develop a technology-agnostic Excel tool for estimating location-specific avoided costs of DER for LNBA demonstration projects. The LNBA tool has two major parts—a project deferral benefit module, which calculates the values of deferring a specific capital project, and a system-level avoided cost module, which estimates the system-level avoided costs given a user-defined DER solution. The summation of the quantitative results provided by the two modules provides an estimate of the total achievable avoidable cost for a given DER solution at a specific location. Demonstration projects are underway with each of the large IOUs to test tools for locational benefits analysis. Completion of final LNBA models is expected in mid-2018.

As part of the LNBA work in California, utilities are developing public tools and heat maps that will be made available online to enable customers and developers to identify optimal locations for installing DERs. Results from LNBA will also be used to prioritize candidate distribution deferral opportunities. In June 2017, the California Public Utility Commission recommended refinements to the LNBA analysis to include valuing location-specific grid services provided by smart inverters, evaluating the effect on

avoided cost of DER working in concert within the same substation footprint, and increasing granularity in avoided cost values (CPUC 2017).

Strategically targeted distributed PV can relieve distribution capacity constraints. In a series of benefit cost studies, dispersed deployment of PV has been found to provide less benefit than targeted deployment. Therefore, in order to access any significant capacity deferral benefit, proactive distribution planning for DERs is required (RMI 2013).

### **4.3 New York – Value of DER Tariff Calculation**

In New York’s value of DER proceeding, the New York Public Service Commission ordered the implementation of a successor to Net Energy Metering tariffs that will provide incentives reflecting the locational value of DER. New York’s value of DER tariffs, also called value stack tariffs, are being designed to replace net metering for larger-scale community solar PV projects (up to 5 MW) in the short term, and will eventually be applied to all DERs across the grid. In addition to the other value components listed in Table 1 (i.e., energy value, environmental value, and capacity value), a DRV and LSRV are being developed as a means to identify, quantify, and compensate for value specific to the distribution system.

To calculate LSRVs and DRVs, New York utilities used a three step process of first identifying LSRV areas, then setting a cap to limit the amount of DER capacity that may receive LSRV compensation, and finally calculating LSRV and DRV rates. Utilities were required to look at their systems and identify thresholds beyond which areas would be identified as LSRV areas or zones and community solar projects in those areas that would receive additional compensation, up to a cap.<sup>1</sup> Additional compensation would then be provided to DER owners in these constrained areas up until the threshold conditions were no longer met.

Compensation amounts for the DRV and LSRV are based on each utility’s own MCOS studies. As such, value calculations can be significantly different from one utility to the next. Goals for phase 2 of the value of DER proceeding include improving the MCOS studies and LSRV methodology and standardizing them to the extent possible, while recognizing that “symmetry across all utilities in all aspects of the distribution planning methods is not realistic or necessarily desirable” (NY PSC 2017b). More details on the DRV and LSRV calculations in New York are contained in Appendix A.

### **4.4 Minnesota Example Calculation**


Although Minnesota has a vertically-integrated electricity supply market, its VOS tariff calculations provide an example of calculating distribution system values associated with distributed generation that can be applicable to Illinois.

Minnesota allows utilities to take a system-wide or location-specific approach when calculating the avoided distribution capacity costs. A location-specific approach would allow utilities to provide more compensation to systems located in high-needs areas. If a utility decides to use the location-specific

---

<sup>1</sup> For example, Con Edison’s LSRV threshold was established as those areas in the year 2021 where projected energy use reaches or exceeds 98% of current capability in sub-transmission, 98% of current capability in area stations or 90% of current capability in distribution network areas. According to this threshold, 19% of Con Edison’s service territory qualify as LSRV zones. National Grid’s threshold was established by scaling loads on all distribution substations to 2020 and then screening against planning ratings to identify potential loadings above those ratings. Applying criteria, 16% of National Grid substations were identified as LSRV areas.

approach, it must follow the guidance provided within the system-wide calculation and use location-specific technical and cost data (CPR 2014). Figure 2 contains a flowchart created by PNNL that illustrates the distribution capacity value calculation. The detailed breakdown of how to calculate avoided distribution capacity costs per Minnesota's VOS tariff is included as Appendix B. A complete breakdown of value components for Minnesota mapped to data sources is included in Appendix C.



**Figure 2.** Minnesota Distribution Capacity Value Calculation

## 5.0 Data Needs and Key Questions

Different datasets are needed to calculate the value of each element; the data availability, analysis approach, and balance between transparency and privacy for each are also different. Some data and input values are readily available. These include escalation rates based on U.S. Treasury bonds or references, natural gas prices, and solar PV generation data that can be modeled in tools such as the National Renewable Energy Laboratory's System Advisor Model or PVWatts® Calculator. Other state- and utility-specific datasets needed will vary based on the specific methods used. Data types that likely will be needed to understand the locational and temporal value of distributed generation in Illinois include:

- Load growth projections
- System capacity planning studies – from distribution transformer to bulk system sub-transmission
- Existing and projected distributed generation deployment and production by location
- Line loss studies
- System reliability studies (including voltages, protection, phase balancing)
- System-wide and location-specific cost information
- System-wide and location-specific peak demand growth rates
- Marginal cost of service studies.

The entirety of data necessary for completing the rebate calculations will become clearer as the valuation elements are decided upon (ComEd 2018; Joint Solar Parties 2018). The availability and transparency of data that depict the distribution planning process will allow non-utility stakeholders to better understand the type and granularity of data that currently exist (Joint Solar Parties 2018). Ameren noted that electrical models, measurement data, and account and costs models will be necessary in order to calculate the rebate, although they are not often available to the public for safety concerns (Ameren 2018). Other stakeholders emphasized that a regularly updated hosting capacity analysis, DER growth projections, and a GNA will be essential (ELPC et al. 2018).

Joint Solar Parties also noted that Illinois utilities use embedded cost of service studies in their ratemaking, rather than MCOS studies, but marginal costs are typically used when calculating the value of avoided or deferred investments (Joint Solar Parties 2018). The difference between embedded and MCOS studies is that embedded cost studies rely on historic or actual costs the utility incurs (the same costs that are used to determine the revenue requirement), whereas MCOS studies calculate what it *would* cost to provide incremental service at the current cost of adding equipment and securing additional power. For each method, there are many different ways to determine relevant costs and their allocations (RAP 2011).

Based on research performed in the development of this white paper, it is likely that as the ICC and stakeholders work together to develop a distributed generation rebate for Illinois, they should be prepared to address the following questions:

- How will distribution areas be defined for the characterization of locational value?
- Will there be standardization and transparency requirements around projecting load growth and distributed generation by distribution area?
- Will utility capital investment plans for distribution areas be required to be developed, filed, and shared? Will they be 5 or 10 year plans? How often will they be updated?

- Will a standardized methodology be developed for calculating components of avoided cost?
- Will details on candidate deferral projects be communicated and made public?
- Will information, data, and analysis results be made available through an online portal?
- Will a consultant be hired to help with developing a rebate value methodology?
- Will there be different distributed generation rebate values for systems with smart inverters and systems without smart inverters?
- Will the distributed generation rebate development be explicitly coordinated with the Adjustable Block Program and other competitive REC procurement programs? Does Illinois want to start broadly by looking at the value of DER to the whole grid and then narrow the discussion to the value of distributed generation to the distribution system to put all compensation options (e.g., rebate, REC price, energy supply credit, and future smart inverter compensation) in context?
- Will utilities be required to develop marginal cost of service studies?
- To what extent will data, calculations, and results from analysis and simulation be made public?
- Which, if any, value elements will initially be set to zero and then revisited? What will the time frame be for revisiting?
- How often will value calculations be updated?
- Will a designated working group process be established for developing the distributed generation rebate? If so, how will it be governed and carried out?



## 6.0 Summary and Conclusions

As details of the rebate valuation process are determined, stakeholders can recognize that shared viewpoints do exist. Both broad and specific ideas were common among parties throughout their submitted comments. All participants called for transparency and fairness in the development process (Ameren 2018; ComEd 2018; ELPC et al. 2018; Illinois PIRG 2018; Joint Solar Parties 2018; REACT 2018), and several highlighted the importance of ensuring market predictability and promoting a gradual, evolutionary rebate (ELPC et al. 2018; Illinois PIRG 2018; Joint Solar Parties 2018). More explicit ideas, including a hosting capacity analysis and GNA, were also suggested by groups of stakeholders (ELPC et al. 2018; Illinois PIRG 2018). Common ground may serve as a starting point for discussion to stimulate progress.

Understanding locational benefits of distributed generation requires understanding infrastructure requirements with and without distributed generation. There are a variety of ways to calculate avoided costs and these are shared in this white paper. In some states, simplified approximations are being used until more detailed modeling and analysis tools become available. In some states, placeholder values are being used and/or certain value elements are set to zero to be revisited in the future. This paper specifically addresses calculations options for the specific value elements of distribution capacity, reduction in losses, ancillary services (including operating reserves and voltage support), and reliability and resiliency.

Data transparency and privacy are issues that also need to be addressed. Stakeholder engagement is important as this process unfolds. California, New York, and Minnesota provide examples of valuation processes that included structured stakeholder engagement and, in the case of California and New York, a deliberate attempt to balance data transparency and privacy.

As the ICC and energy stakeholders work together to develop a distributed generation rebate for Illinois, fundamental questions will need to be answered regarding the extent to which analysis methods will be standardized, datasets will be created, and investment plans, load and distributed generation projections, cost information, and analysis results will be made publicly available.

## 7.0 References

Ameren – Ameren Illinois. 2018. *Ameren Illinois Responses to March 1, 2018 ICC Distributed Generation Workshop*. March 29, 2018. Available at <https://www.icc.illinois.gov/Electricity/workshops/DistributedGenerationValuation.aspx>.

ComEd – Commonwealth Edison Company. 2018. *Distributed Generation Valuation and Compensation Workshop Comments of Commonwealth Edison Company*. March 30, 2018. Signed by Michael R. Lee, Attorney. Available at <https://www.icc.illinois.gov/Electricity/workshops/DistributedGenerationValuation.aspx>.

Cory, K. 2014. *Minnesota Values Solar Generation with New “Value of Solar” Tariff*. October 3, 2014. NREL webpage/State, Local & Tribal Governments/Blog. Available at: <https://www.nrel.gov/technical-assistance/blog/posts/vos-series-minnesota.html> (published October 3, 2014).

CPR – Clean Power Research. 2014. *Minnesota Value of Solar: Methodology*. Prepared for Minnesota Department of Commerce, Division of Energy Resources. Available at <http://mn.gov/commerce-stat/pdfs/vos-methodology.pdf> (published April 1, 2014).

CPUC – California Public Utilities Commission. 2017. *Assigned Commissioner’s Ruling Setting Scope and Schedule for Continued Long Term Refinement Discussions Pertaining to the Integration Capacity Analysis and Locational Net Benefits Analysis in Track One of the Distribution Resources Plan Proceedings*. San Francisco, California. Filed June 7, 2017. Available at [http://drpwg.org/wp-content/uploads/2016/07/189819375\\_ACR\\_06.08.17.pdf](http://drpwg.org/wp-content/uploads/2016/07/189819375_ACR_06.08.17.pdf).

CPUC – California Public Utilities Commission. 2018a. *Decision 18-02-004, Decision on Track 3 Policy Issues, Sub-Track 1 (Growth Scenarios) and Sub-Track 3 (Distribution Investment and Deferral Process)*. Issued February 8, 2018. San Francisco, California. <http://docs.cpuc.ca.gov/PublishedDocs/Published/G000/M209/K858/209858586.PDF>.

CPUC – California Public Utilities Commission. 2018b. *Order Instituting Rulemaking Regarding Policies, Procedures and Rules for Development of Distribution Resource Plans Pursuant to Public Utilities Code Section 769*. Available at <http://docs.cpuc.ca.gov/PublishedDocs/Published/G000/M209/K858/209858586.PDF> (Date of Issuance 2/15/18).

CPUC – California Public Utilities Commission. 2018c. *Smart Inverter Working Group*. Available at <http://www.cpuc.ca.gov/General.aspx?id=4154>.

Denholm P, R Margolis, B Palmintier, C Barrows, E Ibanez, L Bird, and J Zuboy. 2014. *Methods for Analyzing the Benefits and Costs of Distributed Photovoltaic Generation to the U.S. Electric Utility System*. National Renewable Energy Laboratory. NREL/TP-6A20-62447. September 2014. Available at: <https://www.nrel.gov/docs/fy14osti/62447.pdf>.

DRPWG – Distribution Resources Plan Working Group. 2018. *California’s Distribution Resources Plan (R.14-08-013)*. Accessed April 18, 2018 at <https://drpwg.org/sample-page/drpf/> (last update unknown).

E3 - Energy + Environmental Economics. 2017. *Workshop Discussion: California LNBA Update*. September 20, 2017. Available at:

[http://www3.dps.ny.gov/W/PSCWeb.nsf/96f0fec0b45a3c6485257688006a701a/8a5f3592472a270c8525808800517bdd/\\$FILE/E3%20VDER%20Workshop%20California%20LNBA.pdf](http://www3.dps.ny.gov/W/PSCWeb.nsf/96f0fec0b45a3c6485257688006a701a/8a5f3592472a270c8525808800517bdd/$FILE/E3%20VDER%20Workshop%20California%20LNBA.pdf)

ELPC et al. – Environmental Law and Policy Center, Environment Illinois Research and Policy Center, Vote Solar and the Union of Concerned Scientists. 2018. *Comments of the Environmental Law and Policy Center, Environment Illinois Research and Policy Center, Vote Solar and the Union of Concerned Scientists to the Illinois Commerce Commission Regarding the Distributed Generation Valuation and Compensation Workshop, March 30, 2018*. Available at <https://www.icc.illinois.gov/Electricity/workshops/DistributedGenerationValuation.aspx>.

Homer J, A Cooke, L Schwartz, G Leventis, F Flores-Espino, M Coddington. 2017. *State Engagement in Electric Distribution System Planning*. Richland, WA: Pacific Northwest National Laboratory. PNNL-27066. Available at [https://epe.pnnl.gov/pdfs/State\\_Engagement\\_in\\_Electric\\_Distribution\\_System\\_Planning\\_PNNL\\_27066.pdf](https://epe.pnnl.gov/pdfs/State_Engagement_in_Electric_Distribution_System_Planning_PNNL_27066.pdf).

ICC – Illinois Commerce Commission. 2014. *Final Order 13-0506*. Available at <https://www.icc.illinois.gov/docket/files.aspx?no=13-0506&docId=208612> (January 28, 2014).

ICC – Illinois Commerce Commission. 2017. *Final Order 17-0350*. Available at <https://www.icc.illinois.gov/docket/files.aspx?no=17-0350&docId=256982> (September 27, 2017).

IPA - Illinois Power Agency. 2017. *Long-Term Renewable Resources Procurement Plan*. Filed for Illinois Commerce Commission Approval December 4, 2017.

Illinois PIRG – Illinois Public Interest Research Group. 2018. *Distributed Generation Valuation and Compensation, dated April 1, 2018*. From Abraham Scarr, Director. Available at <https://www.icc.illinois.gov/Electricity/workshops/DistributedGenerationValuation.aspx>.

Joint Solar Parties. 2018. *Informal Comments on Behalf of the Solar Energy Industries Association, the Illinois Solar Energy Association, and the Coalition for Community Solar Access* (The Joint Solar Parties). Available at <https://www.icc.illinois.gov/Electricity/workshops/DistributedGenerationValuation.aspx>.

JU NY - Joint Utilities of New York. 2016. *Supplemental Distributed System Implementation Plan. In the Matter of Distributed System Implementation Plans*. Accessed May 9, 2018 at <http://jointutilitiesofny.org/wp-content/uploads/2016/10/3A80BFC9-CBD4-4DFD-AE62-831271013816.pdf>.

JU NY - Joint Utilities of New York. 2017. *Stage 2 Hosting Capacity Update (October 1<sup>st</sup> Release)*. Accessed May 9, 2018 at <http://jointutilitiesofny.org/utility-specific-pages/hosting-capacity/>.

Lu S, N Samaan, D Meng, F Chassin, Y Zhang, B Vyakaranam, M Warwick, J Fuller, R Diao, T Nguyen, and C Jin. 2014. *Duke Energy Photovoltaic Integration Study: Carolina Service Areas*. Richland, WA: Pacific Northwest National Laboratory. PNNL 23226. Available at [https://www.pnnl.gov/main/publications/external/technical\\_reports/PNNL-23226.pdf](https://www.pnnl.gov/main/publications/external/technical_reports/PNNL-23226.pdf).

More Than Smart. 2016. *Integration Capacity Analysis & Locational Net Benefits Analysis Working Groups Kick-off Meeting May 12, 2016*. Available at <https://drpwg.org/wp-content/uploads/2016/05/R1408013-Joint-WGs-kick-off-deck-presentation-0512162.pptx>.

More Than Smart. 2017. *More Than Smart – About Us*. Accessed April 18, 2018 at <http://morethansmart.org/about-us/>.

NYPSC – State of New York Public Service Commission. 2017a. *Order on Net Energy Metering Transition, Phase One of Distributed Energy Resources, and Related Matters*. New York State Department of Public Service, Albany, New York. March 9, 2017. Available at <http://documents.dps.ny.gov/public/Common/ViewDoc.aspx?DocRefId=%7bA04D9EF3-9779-477E-9D98-43C7B060DAEB%7d>.

NYPSC – State of New York Public Service Commission. 2017b. *Order on Phase One Value of Distributed Energy Resources Implementation Proposals, Cost Mitigation Issues, and Related Matters*. New York State Department of Public Service, Albany, New York. September 14, 2017. Available at <https://www.nyserda.ny.gov/-/media/NYSun/files/VDER-Implementation-Order.pdf>.

OPUC – Oregon Public Utility Commission. 2017. *In the Matter of Investigation to Determine the Resource Value of Solar. Disposition: Straw Proposal Modified and Adopted, Phase 1 Closed, Additional Proceedings Ordered*. UM 1716. Order No. 17-357. September 15, 2017. Available at <http://apps.puc.state.or.us/orders/2017ords/17-357.pdf>.

Orrell AC, JS Homer, Y Tang. 2018. *Distributed Generation Valuation and Compensation*. Richland, WA: Pacific Northwest National Laboratory. PNNL-27271. Available at <https://www.icc.illinois.gov/Electricity/workshops/DistributedGenerationValuation.aspx>.

RAP – The Regulatory Assistance Project. 2011. *Electricity Regulation in the U.S.: A Guide*. March 2011. Available here: <http://www.raponline.org/wp-content/uploads/2016/05/rap-lazar-electricityregulationintheus-guide-2011-03.pdf>

REACT – Coalition to Request Equitable Allocation of Costs Together. 2018. *Informal Initial Written Comments of the Coalition to Request Equitable Allocation of Costs Together (REACT)*. Available at <https://www.icc.illinois.gov/Electricity/workshops/DistributedGenerationValuation.aspx>.

RMI - Rocky Mountain Institute. 2013. *A Review of Solar PV Benefit & Cost Studies, 2nd Edition*. Boulder, CO: Rocky Mountain Institute. Available at [https://rmi.org/wp-content/uploads/2017/05/RMI\\_Document\\_Repository\\_Public-Reprts\\_eLab-DER-Benefit-Cost-Deck\\_2nd\\_Edition131015.pdf](https://rmi.org/wp-content/uploads/2017/05/RMI_Document_Repository_Public-Reprts_eLab-DER-Benefit-Cost-Deck_2nd_Edition131015.pdf).

St. John J. 2015. *California's Distributed Energy Challenge: Sharing the Data*. Greentech Media. Accessed May 11, 2018 at <https://www.greentechmedia.com/articles/featured/Californias-Distributed-Energy-Challenge-Sharing-the-Data#gs.vtbtTII> (posted May 18, 2015).

Trabish HK. 2017. *How utility data sharing is helping the New York REV build the grid of the future*. Utility Dive: February 8, 2017. Available at <https://www.utilitydive.com/news/how-utility-data-sharing-is-helping-the-new-york-rev-build-the-grid-of-the/434972/>.

## Appendix A

### New York VDER Tariff Calculation Example

New York's value of distributed energy resource (VDER) tariffs, also referred to as value stack tariffs, are intended to replace net metering for larger-scale community solar PV projects in the short term, and will eventually be applied to all DERs across the grid. To calculate locational system relief value (LSRV), one of the value components dictated by the New York Public Service Commission, utilities took a multi-step approach. These approaches are described in Table A.1 to provide a specific calculation example from another state with relevance for Illinois, as Illinois statute requires that geographic benefits be considered in the rebate valuation.

**Table A.1.** Example DER Valuation Specifics from Implementation Plans for Two New York Utilities: Con Edison<sup>1</sup> and National Grid<sup>2</sup>

Step	ConEdison Approach	National Grid Approach
Identification of Locational System Relief Value (LSRV) areas	<p>LSRV areas are those where projected energy use in 2021 reaches or exceeds</p> <ul style="list-style-type: none"> <li>98% of the current capability for high voltage sub-transmission lines that supply area stations; or</li> <li>98% of the current capability for area stations that supply distribution network or non-network load areas; or</li> <li>90% of the current capability in distribution network areas.</li> </ul> <p>Applying these thresholds, just over <b>19%</b> of Con Edison service territory is eligible to qualify for an LSRV.</p> <p>Actual qualification of a project for LSRV compensation will be determined on a project-by-project basis at the time an interconnection agreement is executed with the company.</p>	<p>To identify LSRV areas, the company scaled loads on all distribution substations to 2020 and then screened against planning ratings to identify potential loadings above those ratings.</p> <p>53 specific substations were identified as LSRV areas, representing <b>16.4%</b> of the Company's total system load.</p>
Cap limiting the amount of DER capacity that may receive LSRV compensation	Amount of coincident relief that would reduce projected energy use to the point that usage falls below the threshold criteria.	Lesser of the load reduction necessary to reduce peak loading to 100% of planning rating or DER penetration equal to substation minimum load levels (assumed to be 25% of peak load).
Calculation of LSRV and demand reduction value (DRV) rates	Combined LSRV and DRV value in the constrained areas shall be 150% of the current system-wide marginal cost of service level. This technique yields a "de-averaged" <b>DRV value of \$199/kW-year</b> and an incremental <b>LSRV of \$141/kW-year</b> .	<p>LSRV set to 50% of its DRV, thereby establishing the combined compensation (i.e., LSRV and DRV) received by LSRV-eligible projects as being equal to 150% of the DRV. Calculations yield an initial proposed <b>DRV of \$61.44/kW-year</b> and an <b>LSRV rate of \$30.72/kW-year</b>.</p> <p>Rates to be updated every three years.</p>

<sup>1</sup> Con Edison Implementation Proposal for Value of Distributed Energy Resources Framework, May 1, 2017. Case 15-E-0751 and Case 15-E-0082

<sup>2</sup> National Grid (Niagara Mohawk Power Corporation) National Grid Value Stack Implementation Proposal, May 1, 2017. (Date filed shown as May 3, 2017) Case 15-E-0751 and Case 15-E-0082.

## Appendix B

### Minnesota VOS Tariff Avoided Distribution Capacity Cost Calculation Methodology

To calculate the system-wide distribution capacity costs, system-wide costs and peak load data must be available for a historical 10 year period. The data sets must represent the same period in time to preserve the inherent connection between growth and investment.

Distribution capacity expansion must be calculated for two cases when determining the associated value of solar in Minnesota—the conventional plan, where traditional development occurs, and the deferred plan, where the conventional plan is delayed for a year because of the introduction of the solar PV system. The difference between these two cases is used to calculate a value of capacity deferral per unit of PV capacity.

Peak load growth rate is necessary to calculate distribution capacity expansion. The methodology requires that


$$GrowthRate = \left( \frac{P_{15}}{P_1} \right)^{1/14} - 1,$$

where  $P_1$  and  $P_{15}$  are the peak loads from year 1 and year 15 of the estimated future growth time period.

Beginning with the peak load of the current year,  $Cap_0$ , the capacity expansion is calculated for 25 years, the assumed lifetime of the PV system. Thus,

$$Cap_t = Cap_0(1 + GR)^t - Cap_0(1 + GR)^{t-1},$$

where  $t$  is the current year being evaluated,  $Cap_t$  is the capacity of the current year,  $Cap_0$  is the peak load before the analysis begins, and  $GR$  is the growth rate determined above. This is represented through the blue boxes in the flowchart created by PNNL in Figure B.1.



**Figure B.1.** Minnesota Distribution Capacity Value Calculation

The total net present value of both the conventional expansion plan and the deferred expansion plan are then calculated. The following series of steps is necessary to do so.

Cost per unit growth (\$/kW) for the first year of analysis is determined by the historical data. Avoided distribution capacity costs take into consideration costs associated with land and land rights; structures and improvements; station equipment, overhead conductors, and devices; underground conduits; and underground conductors. These values are defined by FERC accounts 360, 361, 362, 365, 366, and 367; however, each utility must determine which portion of the mentioned accounts specifically pertains to distribution capacity and multiply each account by a representative percentage. The sum of the accounts produces the total deferrable costs. After adjusting for inflation, the total deferrable costs value is divided by the kW increase in peak annual load during that 10 year period. The outcome produces the distribution cost per unit growth for the first year.

The subsequent costs per unit growth for the 25 years of analysis (the assumed lifetime of a PV system) are found by escalating the initial cost per unit growth by a utility-provided distribution capital cost escalation rate. This allows the utility to calculate the capital cost for each year by multiplying the year's new distribution capacity by the cost per unit growth. The yearly capital cost is discounted by the utility's weighted average cost of capital. An amortized value for each year is then found from the sum of all discounted capacity costs. The same procedure is performed for the deferred case with the corresponding data (values C and D in the green boxes in Figure B.1).

A value of capacity deferral per unit of PV capacity (kW) is calculated for each year by finding the difference between the conventional plan amortized cost and the deferred plan amortized costs (green boxes in Figure B.1) and then dividing by the conventional distribution planning capacity for the year (orange box in Figure B.1).

This value is divided by the year's per unit PV production to produce the economic value of capacity deferral per unit of PV output (E7 in Figure B.2 and the orange box in Figure B.1). Note that PV



production can be either measured or simulated data, provided it complies with the methodology's specifications. Production from the PV system is assumed to degrade by 5% each year (CPR 2014).

The price per kWh is then multiplied by a load match factor and distributed loss savings (DLS) factor (black box in Figure B.1). The load match factors and distributed loss savings factors in the methodology depend on three categories of time series data over a load analysis period that spans at least a year—hourly generation load, hourly distribution load, and hourly PV fleet production.

Peak load reduction (PLR) is defined as

$$PLR = \max(D_1) - \max(D_2),$$

where  $D_1$  is the hourly distribution load time series and  $D_2$  is the hourly distribution load time series minus the effect of the marginal PV resource. The PLR essentially represents the capability of the marginal PV resource to reduce the peak distribution load over the load analysis period. It is expressed in kW peak reduced per kW PV installed as measured on the alternating current (AC) side.

Similarly, a distributed loss savings factor is calculated with the PLR. It is defined as

$$DistributedLossSavings_{PLR} = \frac{PLR_{WithLosses}}{PLR_{WithoutLosses}} - 1.$$

The loss savings factor considers the avoided distribution losses (not transmission) at peak load.

Multiplying E7 by the load match factor and distributed loss savings factor produces the distributed PV value of avoided distribution capacity costs (V7 in Figure B.2).

25 Year Levelized Value				
	Economic Value (\$/kWh)	Load Match (No Losses) (%)	(1 + Distributed Loss Savings (%))	Distributed PV Value (\$/kWh)
Avoided Fuel Cost	E1			DLS-Energy V1
Avoided Plant O&M - Fixed	E2	ELCC		DLS-ELCC V2
Avoided Plant O&M - Variable	E3			DLS-Energy V3
Avoided Gen Capacity Cost	E4	ELCC		DLS-ELCC V4
Avoided Reserve Capacity Cost	E5	ELCC		DLS-ELCC V5
Avoided Trans. Capacity Cost	E6	ELCC		DLS-ELCC V6
Avoided Dist. Capacity Cost	E7	PLR		DLS-PLR V7
Avoided Environmental Cost	E8			DLS-Energy V8
Avoided Voltage Control Cost				
Solar Integration Cost				
				Lev. VOS

**Figure B.2.** Minnesota Value of Solar Calculation Table (CPR 2014)

The methodology described above is for calculating the system costs and potential savings for distribution. The same basic methodology could be followed with local technical and cost data instead for identified distribution system planning areas, where distribution planning areas are areas where load cannot be easily switched outside of the area (CPR 2014).



## Appendix C

### Minnesota Valuation Components and Data Sources

**Table C.1.** Minnesota Valuation Components and Data Sources

Legislative Guidance	Basis	Value Component	Data Sources	Applicable Links and Resources	Notes
Required (energy)	Energy market costs (portion attributed to fuel)	Avoided Fuel Cost	NYMEX (NG Futures), AA-rated Natural Gas Supplier, or Utility Standard PV degradation value Metered production data from PV plants, Technical applications of PV plants, or PV fleets outside of utility territory  US Treasury (escalation rate)	VOS Data Table  0.50%  <a href="http://www.treasury.gov/resource-center/data-chart-center/interest-rates/Pages/TextView.aspx?data=yield">http://www.treasury.gov/resource-center/data-chart-center/interest-rates/Pages/TextView.aspx?data=yield</a>	
Required (energy)	Energy market costs (portion attributed to O&M)	Avoided Plant O&M Costs	Utility Standard PV degradation value Metered production data from PV plants, Technical applications of PV plants, or PV fleets outside of utility territory	VOS Data Table 0.50%	
Required (capacity)	Capital cost of generation to meet peak load	Avoided Generation Capacity Cost	Utility Standard PV degradation value Metered production data from PV plants, Technical applications of PV plants, or PV fleets outside of utility territory	VOS Data Table 0.50%	
Required (capacity)	Capital cost of generation to meet planning margins and ensure reliability	Avoided Reserve Capacity Cost	Utility Standard PV degradation value  Metered production data from PV plants, Technical applications of PV plants, or PV fleets outside of utility territory	VOS Data Table 0.50%	

Legislative Guidance	Basis	Value Component	Data Sources	Applicable Links and Resources	Notes
Required (transmission capacity)	Capital cost of transmission	Avoided Transmission Capacity Cost	Utility	VOS Data Table	
			MISO OATT Schedule 9 Charge		
			Standard PV degradation value	0.50%	
			Metered production data from PV plants, Technical applications of PV plants, or PV fleets outside of utility territory		
Required (environmental)	Externality costs	Avoided Environmental Cost	Utility	VOS Data Table	
			Standard PV degradation value	0.50%	
			Metered production data from PV plants, Technical applications of PV plants, or PV fleets outside of utility territory		
				<a href="http://www.epa.gov/climatechange/ghgemissions/ind-assumptions.html">http://www.epa.gov/climatechange/ghgemissions/ind-assumptions.html</a>	
			EPA	<a href="http://www.epa.gov/ttnchie1/ap42/">http://www.epa.gov/ttnchie1/ap42/</a>	
				<a href="http://www.epa.gov/oms/climate/regulations/scc-tsd.pdf">http://www.epa.gov/oms/climate/regulations/scc-tsd.pdf</a>	
			NaturalGas.org	<a href="http://www.naturalgas.org/environment/naturalgas.asp">http://www.naturalgas.org/environment/naturalgas.asp</a>	
			Federal Social Cost of CO <sub>2</sub>	<a href="http://www.epa.gov/climatechange/EPAactivities/economics/scc.html">http://www.epa.gov/climatechange/EPAactivities/economics/scc.html</a>	
			Minnesota PUC-established externality costs for non-CO <sub>2</sub> emissions	“Notice of Updated Environmental Externality Values,” issued June 5, 2013, PUC docket numbers E-999/CI-93-583 and E-999/CI-00-1636.	
			Bureau of Labor and Statistics	<a href="ftp://ftp.bls.gov/pub/special.requests/cpi/cpiait.txt">ftp://ftp.bls.gov/pub/special.requests/cpi/cpiait.txt</a>	

Legislative Guidance	Basis	Value Component	Data Sources	Applicable Links and Resources	Notes
Required (delivery)	Capital cost of distribution	Avoided Distribution Capacity Cost	Utility Standard PV degradation value Metered production data from PV plants, Technical applications of PV plants, or PV fleets outside of utility territory FERC Accounts 360, 361, 362, 365, 366, 367	0.50%	
Required (capacity)	Load Match Factor	Effective Load-Carrying Capacity (no loss)	Metered production data from PV plants, Technical applications of PV plants, or PV fleets outside of utility territory  PTC Rating - California Energy Commission, or standard values provided by methodology  Inverter Efficiency Rating - California Energy Commission, or standard values provided by methodology  Internal PV Array losses - measured or design	  <a href="http://www.gosolarcalifornia.ca.gov/equipment/pv_modules.php">http://www.gosolarcalifornia.ca.gov/equipment/pv_modules.php</a> <a href="http://www.gosolarcalifornia.ca.gov/equipment/pv_modules.php">http://www.gosolarcalifornia.ca.gov/equipment/pv_modules.php</a>          <a href="https://www.misoenergy.org/Library/BusinessPracticesManuals/Pages/BusinessPracticesManuals.aspx">https://www.misoenergy.org/Library/BusinessPracticesManuals/Pages/BusinessPracticesManuals.aspx</a>	Applied to Avoided Generation Capacity Cost, Avoided Reserve Capacity Cost, Avoided Transmission Capacity Cost
Required (capacity)	Load Match Factor	Peak Load Reduction (no loss)	Utility Metered production data from PV plants, Technical applications of PV plants, or PV fleets outside of utility territory  PTC Rating - California Energy Commission, or standard values provided by methodology  Inverter Efficiency Rating - California Energy Commission, or standard values provided by methodology  Internal PV Array losses - measured or design	  <a href="http://www.gosolarcalifornia.ca.gov/equipment/pv_modules.php">http://www.gosolarcalifornia.ca.gov/equipment/pv_modules.php</a> <a href="http://www.gosolarcalifornia.ca.gov/equipment/pv_modules.php">http://www.gosolarcalifornia.ca.gov/equipment/pv_modules.php</a>	Applied to Avoided Distribution Capacity Cost

Legislative Guidance	Basis	Value Component	Data Sources	Applicable Links and Resources	Notes
Required (losses)	Loss Savings Factor	Loss Savings - Energy	Metered production data from PV plants, Technical applications of PV plants, or PV fleets outside of utility territory		Applied to Avoided Fuel Cost, Avoided Plant O&M Cost, Avoided Environmental Cost
Required (losses)	Loss Savings Factor	Loss Savings - PLR	Utility Metered production data from PV plants, Technical applications of PV plants, or PV fleets outside of utility territory PTC Rating - California Energy Commission, or standard values provided by methodology Inverter Efficiency Rating - California Energy Commission, or standard values provided by methodology Internal PV Array losses - measured or design	<a href="http://www.gosolarcalifornia.ca.gov/equipment/pv_modules.php">http://www.gosolarcalifornia.ca.gov/equipment/pv_modules.php</a> <a href="http://www.gosolarcalifornia.ca.gov/equipment/pv_modules.php">http://www.gosolarcalifornia.ca.gov/equipment/pv_modules.php</a>	Applied to Avoided Distribution Capacity Cost
Required (losses)	Loss Savings Factor	Loss Savings - ELCC	Metered production data from PV plants, Technical applications of PV plants, or PV fleets outside of utility territory PTC Rating - California Energy Commission, or standard values provided by methodology Inverter Efficiency Rating - California Energy Commission, or standard values provided by methodology Internal PV Array losses - measured or design MISO BPM-011, Section 4.2.2.4, page 35 -- Hours ending in 2, 3, 4 PM CST in June, July, August	<a href="http://www.gosolarcalifornia.ca.gov/equipment/pv_modules.php">http://www.gosolarcalifornia.ca.gov/equipment/pv_modules.php</a> <a href="http://www.gosolarcalifornia.ca.gov/equipment/pv_modules.php">http://www.gosolarcalifornia.ca.gov/equipment/pv_modules.php</a> <a href="https://www.misoenergy.org/Library/BusinessPracticesManuals/Pages/BusinessPracticesManuals.aspx">https://www.misoenergy.org/Library/BusinessPracticesManuals/Pages/BusinessPracticesManuals.aspx</a>	Applied to Avoided Generation Capacity Cost, Avoided Reserve Capacity Cost, Avoided Transmission Capacity Cost

Legislative Guidance	Basis	Value Component	Data Sources	Applicable Links and Resources	Notes
	Cost to regulate distribution (future inverter designs)	Voltage Control			Future (TBD)
	Added cost to regulate system frequency with variable solar	Integration Cost			Future (TBD)



**Pacific Northwest**  
NATIONAL LABORATORY

*Proudly Operated by **Battelle** Since 1965*

902 Battelle Boulevard  
P.O. Box 999  
Richland, WA 99352  
1-888-375-PNNL (7665)

U.S. DEPARTMENT OF  
**ENERGY**

---

**[www.pnnl.gov](http://www.pnnl.gov)**